

TABLE 1—CRITERIA FOR QUALIFYING CONDUIT HYDROPOWER FACILITY

Statutory provision	Description	Satisfies (Y/N)
FPA 30(a)(3)(A), as amended by HREA.	The conduit the facility uses is a tunnel, canal, pipeline, aqueduct, flume, ditch, or similar man-made water conveyance that is operated for the distribution of water for agricultural, municipal, or industrial consumption and not primarily for the generation of electricity.	Y
FPA 30(a)(3)(C)(i), as amended by HREA.	The facility is constructed, operated, or maintained for the generation of electric power and uses for such generation only the hydroelectric potential of a non-federally owned conduit.	Y
FPA 30(a)(3)(C)(ii), as amended by HREA.	The facility has an installed capacity that does not exceed 5 megawatts	Y
FPA 30(a)(3)(C)(iii), as amended by HREA.	On or before August 9, 2013, the facility is not licensed, or exempted from the licensing requirements of Part I of the FPA.	Y

Preliminary Determination: Based upon the above criteria, Commission staff preliminarily determines that the proposal satisfies the requirements for a qualifying conduit hydropower facility, which is not required to be licensed or exempted from licensing.

Comments and Motions to Intervene: Deadline for filing comments contesting whether the facility meets the qualifying criteria is 45 days from the issuance date of this notice.

Deadline for filing motions to intervene is 30 days from the issuance date of this notice.

Anyone may submit comments or a motion to intervene in accordance with the requirements of Rules of Practice and Procedure, 18 CFR 385.210 and 385.214. Any motions to intervene must be received on or before the specified deadline date for the particular proceeding.

Filing and Service of Responsive Documents: All filings must (1) bear in all capital letters the “COMMENTS CONTESTING QUALIFICATION FOR A CONDUIT HYDROPOWER FACILITY” or “MOTION TO INTERVENE,” as applicable; (2) state in the heading the name of the applicant and the project number of the application to which the filing responds; (3) state the name, address, and telephone number of the person filing; and (4) otherwise comply with the requirements of sections 385.2001 through 385.2005 of the Commission’s regulations.¹ All comments contesting Commission staff’s preliminary determination that the facility meets the qualifying criteria must set forth their evidentiary basis.

The Commission strongly encourages electronic filing. Please file motions to intervene and comments using the Commission’s eFiling system at <http://www.ferc.gov/docs-filing/efiling.asp>. Commenters can submit brief comments up to 6,000 characters, without prior registration, using the eComment system at <http://www.ferc.gov/docs-filing/ecomment.asp>. You must include your

name and contact information at the end of your comments. For assistance, please contact FERC Online Support at FERCOnlineSupport@ferc.gov, (866) 208-3676 (toll free), or (202) 502-8659 (TTY). In lieu of electronic filing, please send a paper copy to: Secretary, Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426. A copy of all other filings in reference to this application must be accompanied by proof of service on all persons listed in the service list prepared by the Commission in this proceeding, in accordance with 18 CFR 4.34(b) and 385.2010.

Locations of Notice of Intent: Copies of the notice of intent can be obtained directly from the applicant or such copies can be viewed and reproduced at the Commission in its Public Reference Room, Room 2A, 888 First Street NE., Washington, DC 20426. The filing may also be viewed on the web at <http://www.ferc.gov/docs-filing/elibrary.asp> using the “eLibrary” link. Enter the docket number (e.g., CD15-27-000) in the docket number field to access the document. For assistance, call toll-free 1-866-208-3676 or email FERCOnlineSupport@ferc.gov. For TTY, call (202) 502-8659.

Dated: June 15, 2015.

Kimberly D. Bose,
Secretary.

[FR Doc. 2015-15099 Filed 6-18-15; 8:45 am]

BILLING CODE 6717-01-P

DEPARTMENT OF ENERGY

Federal Energy Regulatory Commission

Notice of Commission Staff Attendance

The Federal Energy Regulatory Commission (Commission) hereby gives notice that members of the Commission’s staff may attend the following meeting related to the transmission planning activities of the

New York Independent System Operator, Inc.

The New York Independent System Operator, Inc. Electric System Planning Working Group Meeting

June 25, 2015, 10:00 a.m.–4:00 p.m. (EST)

The above-referenced meeting will be via web conference and teleconference.

The above-referenced meeting is open to stakeholders.

Further information may be found at: http://www.nyiso.com/public/markets_operations/services/planning/index.jsp.

The discussions at the meeting described above may address matters at issue in the following proceedings:

- Docket Nos. ER13-102, ER13-1942, ER13-1946, New York Independent System Operator, Inc. and New York Transmission Owners
- Docket No. ER13-1926, PJM Transmission Owners
- Docket Nos. ER13-1947, ER13-198, PJM Interconnection, L.L.C.
- Docket Nos. ER13-1957, ER13-193, ER13-196, ISO New England Inc.
- Docket No. ER13-1960, ISO New England Inc., Participating Transmission Owners Administrative Committee, and New England Power Pool Participants Committee

For more information, contact James Eason, Office of Energy Market Regulation, Federal Energy Regulatory Commission at (202) 502-8622 or James.Eason@ferc.gov.

Dated: June 15, 2015.

Kimberly D. Bose,
Secretary.

[FR Doc. 2015-15108 Filed 6-18-15; 8:45 am]

BILLING CODE 6717-01-P

¹ 18 CFR 385.2001-2005 (2014).