



FEDERAL REGISTER

Vol. 81

Wednesday,

No. 110

June 8, 2016

Part II

Department of Energy

10 CFR Parts 429 and 430

Energy Conservation Program: Test Procedures for Central Air Conditioners and Heat Pumps; Final Rule

DEPARTMENT OF ENERGY**10 CFR Parts 429 and 430****[Docket No. EERE-2009-BT-TP-0004]****RIN 1904-AB94****Energy Conservation Program: Test Procedures for Central Air Conditioners and Heat Pumps****AGENCY:** Office of Energy Efficiency and Renewable Energy, Department of Energy.**ACTION:** Final rule.

SUMMARY: On November 9, 2015, the U.S. Department of Energy (DOE) issued a supplemental notice of proposed rulemaking (SNOPR) to amend the test procedure for central air conditioners and heat pumps. That proposed rulemaking serves as the basis for the final rule. The final rule, in addition to satisfying the agency's obligation to periodically review its test procedures for covered equipment, amends specific certification, compliance, and enforcement provisions related to this product. In the final rule DOE makes the following amendments to the current test procedure: a new basic model definition as it pertains to central air conditioners and heat pumps and revised requirements for represented values; revised alternative efficiency determination methods; termination of active waivers and interim waivers; procedures to determine off mode power consumption; changes to the test procedure that would improve test repeatability and reduce test burden; and clarifications to ambiguous sections of the test procedure intended also to improve test repeatability and reproducibility. Some of these amendments also include incorporation by reference of updated industry standards.

DATES: The effective date of this rule is July 8, 2016. The final rule changes will be mandatory for representations of efficiency starting December 5, 2016. The incorporation by reference of certain publications listed in this rule was approved by the Director of the Federal Register on July 8, 2016.

ADDRESSES: The docket, which includes **Federal Register** notices, public meeting attendee lists and transcripts, comments, and other supporting documents/materials, is available for review at [regulations.gov](http://www.regulations.gov). All documents in the docket are listed in the [regulations.gov](http://www.regulations.gov) index. However, some documents listed in the index, such as those containing information that is exempt from public disclosure, may not be publicly available.

A link to the docket Web page can be found at: www1.eere.energy.gov/buildings/appliance_standards/rulemaking.aspx/ruleid/72. This Web page will contain a link to the docket for this notice on the [regulations.gov](http://www.regulations.gov) site. The [regulations.gov](http://www.regulations.gov) Web page will contain simple instructions on how to access all documents, including public comments, in the docket.

For further information on how to review the docket, contact Ms. Brenda Edwards at (202) 586-2945 or by email: Brenda.Edwards@ee.doe.gov.

FOR FURTHER INFORMATION CONTACT: Ashley Armstrong, U.S. Department of Energy, Office of Energy Efficiency and Renewable Energy, Building Technologies Program, EE-2J, 1000 Independence Avenue SW., Washington, DC 20585-0121. Telephone: (202) 586-6590. Email: Ashley.Armstrong@ee.doe.gov.

Johanna Jochum, U.S. Department of Energy, Office of the General Counsel, GC-33, 1000 Independence Avenue SW., Washington, DC, 20585-0121. Telephone: (202) 287-6307. Email: Johanna.Jochum@hq.doe.gov.

For further information on how to submit a comment, review other public comments and the docket, or participate in the public meeting, contact Ms. Brenda Edwards at (202) 586-2945 or by email: Brenda.Edwards@ee.doe.gov.

SUPPLEMENTARY INFORMATION: This final rule incorporates by reference into part 430 specific sections, figures, and tables in the following industry standards:

(1) ANSI/AHRI 210/240-2008 with Addenda 1 and 2, ("AHRI 210/240-2008"): 2008 Standard for Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment, ANSI approved 27 October 2011;

(2) ANSI/AHRI 1230-2010 with Addendum 2, ("AHRI 1230-2010"): 2010 Standard for Performance Rating of Variable Refrigerant Flow (VRF) Multi-Split Air-Conditioning and Heat Pump Equipment, ANSI approved August 2, 2010;

Copies of AHRI 210/240-2008 and AHRI 1230-2010 can be obtained from the Air-Conditioning, Heating, and Refrigeration Institute, 2111 Wilson Boulevard, Suite 500, Arlington, VA 22201, USA, 703-524-8800, or by going to <http://www.ahrinet.org/site/686/Standards/HVACR-Industry-Standards/Search-Standards>.

(3) ANSI/ASHRAE 23.1-2010, ("ASHRAE 23.1-2010"): Methods of Testing for Rating the Performance of Positive Displacement Refrigerant Compressors and Condensing Units that Operate at Subcritical Temperatures of the Refrigerant, ANSI approved January 28, 2010;

(4) ANSI/ASHRAE Standard 37-2009, ("ANSI/ASHRAE 37-2009"), Methods of Testing for Rating Electrically Driven Unitary Air-Conditioning and Heat Pump Equipment, ANSI approved June 25, 2009;

(5) ANSI/ASHRAE 41.1-2013, ("ANSI/ASHRAE 41.1-2013"): Standard Method for Temperature Measurement, ANSI approved January 30, 2013;

(6) ANSI/ASHRAE 41.6-2014, ("ASHRAE 41.6-2014"): Standard Method for Humidity Measurement, ANSI approved July 3, 2014;

(7) ANSI/ASHRAE 41.9-2011, ("ASHRAE 41.9-2011"): Standard Methods for Volatile-Refrigerant Mass Flow Measurements Using Calorimeters, ANSI approved February 3, 2011

(8) ANSI/ASHRAE 116-2010, ("ASHRAE 116-2010"): Methods of Testing for Rating Seasonal Efficiency of Unitary Air Conditioners and Heat Pumps, ANSI approved February 24, 2010.

(9) ANSI/ASHRAE 41.2-1987 (Reaffirmed 1992), ("ASHRAE 41.2-1987 (RA 1992)"): "Standard Methods for Laboratory Airflow Measurement", ANSI approved October 1, 1987.

Copies of ASHRAE 23.1-2010, ANSI/ASHRAE 37-2009, ANSI/ASHRAE 41.1-2013, ASHRAE 41.6-2014, ASHRAE 41.9-2011, ASHRAE 116-2010, and ASHRAE 41.2-1987 (RA 1992) can be purchased from ASHRAE's Web site at <https://www.ashrae.org/resources-publications>.

(10) ANSI/AMCA 210-2007, ANSI/ASHRAE 51-2007, ("AMCA 210-2007") Laboratory Methods of Testing Fans for Certified Aerodynamic Performance Rating, August 17, 2007;

Copies of AMCA 210-2007 can be purchased from AMCA's Web site at <http://www.amca.org/store/index.php>.

For a further discussion of these standards, see section IV.N.

Table of Contents

- I. Authority and Background
 - A. Authority
 - B. Background
- II. Summary of the Final Rule
- III. Discussion
 - A. Definitions, Testing, Represented Values, and Compliance of Basic Models of Central Air Conditioners and Heat Pumps
 - 1. Basic Model Definition
 - 2. Additional Definitions
 - 3. Determination of Represented Values
 - 4. Compliance with Federal (National or Regional) Standards
 - 5. Certification Reports
 - 6. Represented Values
 - 7. Product-Specific Enforcement Provisions
 - B. Alternative Efficiency Determination Methods
 - 1. General Background
 - 2. Terminology

3. Elimination of the Pre-Approval Requirement
4. AEDM Validation
5. AEDM Verification Testing
6. Failure to Meet Certified Represented Values
7. Action Following a Determination of Noncompliance
8. AEDM for Off Mode
- C. Waiver Procedures
 1. Air-to-Water Heat Pumps and Air Conditioners
 2. Clarification of the Test Procedure Pertaining to Multi-Circuit Products
 3. Clarification of the Test Procedure Pertaining to Multi-Blower Products
- D. Measurement of Off Mode Power Consumption
 1. Test Temperatures
 2. Calculation and Weighting of P1 and P2
 3. Time Delay Credit and Removal of Calculations for Off Mode Energy Consumption and Annual Performance Factor
 4. Impacts on Product Reliability
 5. Off Mode Power Consumption for Intelligent Compressor Heat Control
 6. Off Mode Test Voltage for Dual-Voltage Units
 7. Off Mode Test Tolerance
 8. Organization of Off Mode Test Procedure
 9. Certification
 10. Compliance Dates
- E. Test Repeatability Improvement and Test Burden Reduction
 1. Indoor Fan Speed Settings for Blower Coil or Single-Package Systems
 2. Air Volume Rate Adjustment for Coil-Only Systems
 3. Requirements for the Refrigerant Lines and Mass Flow Meter
 4. Outdoor Room Temperature Variation
 5. Method of Measuring Inlet Air Temperature on the Outdoor Side
 6. Requirements for the Air Sampling Device
 7. Variation in Maximum Compressor Speed with Outdoor Temperature
 8. Refrigerant Charging Requirements
 9. Alternative Arrangement for Thermal Loss Prevention for Cyclic Tests
 10. Test Unit Voltage Supply
 11. Coefficient of Cyclic Degradation
 12. Break-in Periods Prior to Testing
 13. Industry Standards that are Incorporated by Reference
 14. References to ASHRAE 116–1995 (RA 2005)
 15. Additional Changes Based on AHRI 210/240-Draft
 16. Damping Pressure Transducer Signals
 17. Clarify Inputs for the Demand Defrost Credit Equation
 18. Improving Test Consistency Associated with Indoor Unit Air Inlet Geometry
- F. Clarification of Test Procedure Provisions
 1. Manufacturer Consultation
 2. Incorporation by Reference of AHRI 1230–2010
 3. Replacement of the Informative Guidance Table for Using the Federal Test Procedure
 4. Clarifying the Definition of a Mini-Split System
 5. Clarifying the Definition of a Multi-Split System

6. Clarifying the Housing for Uncased Coil
7. Test Procedure Reprint
- G. Additional Comments from Interested Parties
 1. Wet Coil Performance
 2. Barometric Pressure Correction
 3. Inlet Screen
- H. Compliance with other Energy Policy and Conservation Act Requirements
 1. Dates
 2. Measured Energy Use
 3. Test Burden
 4. Potential Incorporation of International Electrotechnical Commission Standard 62301 and International Electrotechnical Commission Standard 62087
- IV. Procedural Issues and Regulatory Review
 - A. Review Under Executive Order 12866
 - B. Review Under the Regulatory Flexibility Act
 - C. Review Under the Paperwork Reduction Act of 1995
 - D. Review Under the National Environmental Policy Act of 1969
 - E. Review Under Executive Order 13132
 - F. Review Under Executive Order 12988
 - G. Review Under the Unfunded Mandates Reform Act of 1995
 - H. Review Under the Treasury and General Government Appropriations Act, 1999
 - I. Review Under Executive Order 12630
 - J. Review Under the Treasury and General Government Appropriations Act, 2001
 - K. Review Under Executive Order 13211
 - L. Review Under Section 32 of the Federal Energy Administration Act of 1974
 - M. Congressional Notification
 - N. Description of Materials Incorporated by Reference
- V. Approval of the Office of the Secretary

I. Authority and Background

A. Authority

Title III, Part B¹ of the Energy Policy and Conservation Act of 1975 (“EPCA” or “the Act”), Public Law 94–163 (42 U.S.C. 6291–6309, as codified) sets forth a variety of provisions designed to improve energy efficiency and established the Energy Conservation Program for Consumer Products Other Than Automobiles.² These products include single-phase central air conditioners and central air conditioning heat pumps³ with rated cooling capacities less than 65,000 British thermal units per hour (Btu/h), which are the focus of this Final Rule. (42 U.S.C. 6291(1)–(2), (21) and 6292(a)(3))

Under EPCA, DOE’s energy conservation program generally consists of four parts: (1) testing; (2) labeling; (3) Federal energy conservation standards;

¹ For editorial reasons, Part B was codified as Part A in the U.S. Code.

² All references to EPCA in this document refer to the statute as amended through the Energy Efficiency Improvement Act of 2015, Public Law 114–11 (Apr. 30, 2015).

³ Where this notice uses the term “CAC/HP”, they are in reference specifically to central air conditioners and heat pumps as defined by EPCA.

and (4) certification and enforcement. The testing requirements consist of test procedures that manufacturers of covered products must use as the basis for: (1) certifying to DOE that their products comply with applicable energy conservation standards adopted pursuant to EPCA, and (2) making other representations about the efficiency of those products. (42 U.S.C. 6293(c); 42 U.S.C. 6295(s)) Similarly, DOE must use these test procedures to determine whether covered products comply with any relevant standards promulgated under EPCA. (42 U.S.C. 6295(s))

EPCA sets forth criteria and procedures DOE must follow when prescribing or amending test procedures for covered products. (42 U.S.C. 6293(b)(3)) EPCA provides, in relevant part, that any test procedures prescribed or amended under this section shall be reasonably designed to produce test results which measure the energy efficiency, energy use, or estimated annual operating cost of a covered product during a representative average use cycle or period of use, and shall not be unduly burdensome to conduct. *Id.*

In addition, if DOE determines that a test procedure amendment is warranted, it must publish proposed test procedures and offer the public an opportunity to present oral and written comments on them. (42 U.S.C. 6293(b)(2)) Finally, in any rulemaking to amend a test procedure, DOE must determine to what extent, if any, the amended test procedure would alter the measured energy efficiency of any covered product as determined under the existing test procedure. (42 U.S.C. 6293(e)(1))

The Energy Independence and Security Act of 2007 (EISA 2007), Public Law 110–140, amended EPCA to require that, at least once every 7 years, DOE must review test procedures for all covered products and either amend the test procedures (if the Secretary determines that amended test procedures would more accurately or fully comply with the requirements of 42 U.S.C. 6293(b)(3)) or publish a notice in the **Federal Register** of any determination not to amend a test procedure. (42 U.S.C. 6293(b)(1)(A))

DOE last published a test procedure final rule for central air conditioners and heat pumps on October 22, 2007. 72 FR 59906. The existing DOE test method for central air conditioners and heat pumps adopted pursuant to that rule appears at Title 10 of the Code of Federal Regulations (CFR) Part 430, Subpart B, Appendix M (“Uniform Test Method for Measuring the Energy Consumption of Central Air Conditioners and Heat Pumps”). That

procedure establishes the currently permitted means for determining energy efficiency and annual energy consumption of these products. The amendments in this final rule will not alter the measured efficiency of central air conditioners and heat pumps.

EISA 2007 also established that the Department's test procedures for all covered products must account for standby mode and off mode energy consumption. (42 U.S.C. 6295(gg)(2)(A)) For central air conditioners and heat pumps, standby mode is incorporated into the SEER metric, while off mode power consumption is separately regulated. This final rule includes modifications relevant to the determination of both SEER (including standby mode) and off mode power consumption.

10 CFR 430.27 allows manufacturers to submit an application for an interim waiver and/or a petition for a waiver granting relief from adhering to the test procedure requirements found under 10 CFR part 430, subpart B, appendix M. For those waivers that are active, however, 10 CFR 430.27(l) requires DOE to amend its regulations so as to eliminate any need for the continuation of such waivers. To this end, this final rule amends the test procedure concerning several waivers.

B. Background

This final rule addresses proposals and comments from three separate rulemakings, two guidance documents, and two working groups: (1) proposals for off mode test procedures made in earlier notices as part of this rulemaking (Docket No. EERE-2009-BT-TP-0004); (2) proposals regarding alternative efficiency determination methods (AEDMs) (Docket No. EERE-2011-BT-TP-0024); (3) the recommendations of the regional standards enforcement Working Group (Regional Standards Enforcement Working Group) (Docket No. EERE-2011-BT-CE-0077); (4) a draft guidance document related to testing and rating split systems with blower coil units (Docket No. EERE-2014-BT-GUID-0033); (5) a draft guidance document that deals with selecting units for testing, rating, and certifying split-system combinations, including discussion of basic models and of condensing units and evaporator coils sold separately for replacement installation (Docket No. EERE-2014-BT-GUID-0032); and (6) stakeholder comments from a request for information regarding energy conservation standards as well as the recommendations of the central air conditioner and heat pump energy conservation standards Working Group

(CAC/HP ECS Working Group) (Docket No. EERE-2014-BT-STD-0048).

1. Proposals for Off Mode Test Procedures

DOE's initial proposals for estimating off mode power consumption in the test procedure for central air conditioners and heat pumps were shared with the public in a notice of proposed rulemaking published in the **Federal Register** on June 2, 2010 (June 2010 NOPR; 75 FR 31224) and at a public meeting at DOE headquarters in Washington, DC, on June 11, 2010 (Public Meeting Transcript, Doc. ID. EERE-2009-BT-TP-0004-0005). Subsequently, DOE published a supplemental notice of proposed rulemaking (SNOPR) on April 1, 2011, in response to comments received on the June 2010 NOPR and due to the results of additional laboratory testing conducted by DOE. (April 2011 SNOPR) 76 FR 18105, 18127. DOE received additional comments in response to the April 2011 SNOPR and proposed an amended version of the off mode procedure that addressed those comments in a second SNOPR on October 24, 2011 (October 2011 SNOPR). 76 FR 65616. DOE received additional comments during the comment period of the October 24, 2011 SNOPR and the subsequent extended comment period. 76 FR 79135.

Between the April 2011 and October 2011 SNOPRs, DOE published a direct final rule (DFR) in the **Federal Register** on June 27, 2011, that set forth amended energy conservation standards for central air conditioners and central air conditioning heat pumps, including a new standard for off mode electrical power consumption. (June 2011 DFR) 76 FR 37408. Under the June 2011 DFR, central air conditioning and heat pump units manufactured on or after January 1, 2015, would be subject to the published standard for off mode electrical power consumption. 10 CFR 430.32(c)(6). However, DOE has issued an enforcement policy statement regarding off mode standards for central air conditioners and central air conditioning heat pumps⁴ (July 2014 Enforcement Policy Statement) specifying that DOE will not assert civil penalty authority for violation of the off mode standard until 180 days following publication of a final rule establishing a test method for measuring off mode electrical power consumption.

⁴ Available at: <http://energy.gov/sites/prod/files/2014/07/f17/Enforcement%20Policy%20Statement%20-%20cac%20off%20mode.pdf> (Last accessed March 30, 2015.)

2. Proposals for AEDMs

DOE also pursued, in a request for information (RFI) published on April 18, 2011, (AEDM RFI) (76 FR 21673) and a NOPR published on May 31, 2012, (AEDM NOPR) (77 FR 32038) revisions to its existing alternative efficiency determination methods (AEDM) and alternative rating methods (ARM) requirements to improve the approach by which manufacturers may use modeling techniques as the basis to certify consumer products and commercial and industrial equipment covered under EPCA. DOE also published a final rule regarding AEDM requirements for commercial and industrial equipment only (Commercial Equipment AEDM FR). 78 FR 79579 (Dec. 31, 2013).

3. Regional Enforcement Standards Working Group and Guidance Documents

On June 13, 2014, DOE published a notice of intent to form a working group to negotiate enforcement of regional standards for central air conditioners and requested nominations from parties interested in serving as members of the Regional Standards Enforcement Working Group. 79 FR 33870. On July 16, 2014, the Department published a notice of membership announcing the eighteen nominees that were selected to serve as members of the Regional Standards Enforcement Working Group, in addition to two members from Appliance Standards and Rulemaking Federal Advisory Committee (ASRAC), and one DOE representative. 79 FR 41456. The Regional Standards Enforcement Working Group identified a number of issues related to testing and certification that are being addressed in this rule. In addition, all nongovernmental participants of the Regional Standards Enforcement Working Group approved the final report contingent on upon the issuance of the final guidance on Docket No. EERE-2014-BT-GUID-0032 0032 and Docket No. EERE-2014-BT-GUID-0033 consistent with the understanding of the Regional Standards Enforcement Working Group as set forth in its recommendations. (Docket No. EERE-2011-BT-CE-0077-0070, Attachment) The amendments in this final rule supplant the August 19 and 20, 2014 draft guidance documents; DOE will not finalize the draft guidance documents and instead has provided any necessary clarity through this final rule. DOE believes the amendments are consistent with the intent of the Regional Standards Enforcement Working Group.

4. Energy Conservation Standards and Working Group

On November 5, 2014, DOE published a request for information for energy conservation standards (ECS) for central air conditioners and heat pumps (November 2014 ECS RFI). 79 FR 65603. In response, several stakeholders provided comments suggesting that DOE amend the current test procedure.

On July 14, 2015, DOE published a notice of intent to establish the central air conditioners and heat pumps working group (CAC/HP ECS Working Group) to negotiate a notice of proposed rulemaking (NPR) for energy conservation standards. 80 FR 40938. This working group was established under ASRAC. Ultimately, the CAC/HP ECS Working Group consisted of 15 members, including one member from ASRAC and one DOE representative. On January 19, 2016, the CAC/HP ECS Working Group successfully reached consensus on amended energy conservation standards and the associated compliance date for certain product classes of central air conditioners and central air conditioning heat pumps, on limited aspects of the proposed, amended test procedure appendix M1, and also on a handful of other miscellaneous issues related to the standards rulemaking as well as to this test procedure final rule. (ASRAC Working Group Term Sheet, Docket No. EERE-2014-BT-STD-0048, No. 0076)

5. Current Rulemaking

Prior to the conclusion of the CAC/HP ECS Working Group, on November 9, 2015, DOE published a third supplemental notice of proposed rulemaking (November 2015 SNOPR) for the test procedure of central air conditioners and heat pumps. 80 FR 69278. The SNOPR responded to relevant comments from the guidance documents and rulemaking dockets discussed in this section.

This final rule addresses certain comments received in response to the November 2015 SNOPR. Some of the provisions of the SNOPR, particularly related to changes proposed for appendix M1, will be addressed in a separate notice. This final rule, along with the separate final rule addressing Appendix M1, will fulfill DOE's obligation to periodically review its test procedures under 42 U.S.C. 6293(b)(1)(A).

II. Summary of the Final Rule

This final rule clarifies aspects of DOE's test procedure for central air conditioners and heat pumps to

improve the consistency and accuracy of the results generated when using that procedure. The rule primarily clarifies how to test for compliance with the current energy conservation standards. The rule also amends certain certification, compliance, and enforcement provisions. While the changes adopted in this rulemaking may impact test burden in certain cases, as discussed in section III.H.3, DOE has determined that this final rule will not change the measured energy efficiency of central air conditioners and heat pumps when compared to the current test procedure. Any proposed amendments that would change the measured energy efficiency will be addressed as part of the new appendix M1, in a separate notice, which will be used in conjunction with amended standards.

DOE revises the basic model definition, adds additional definitions for clarity, makes certain revisions to the testing requirements for determination of represented values, adds certain certification reporting requirements, revises requirements for determination of represented values, and adds product-specific enforcement provisions.

DOE updates requirements for Alternative Rating Methods (ARMs) used to determine performance metrics for central air conditioners and heat pumps based on the regulations for Alternative Efficiency Determination Methods (AEDMs) that are used to estimate performance for commercial HVAC equipment. Specifically, for central air conditioners and heat pumps, DOE makes the following amendments: (1) Revising the nomenclature regarding ARMs; (2) rescinding DOE's pre-approval of an ARM prior to use; (3) creating AEDM validation requirements; (4) revising the AEDM verification testing process; (5) specifying actions a manufacturer could take following a verification test failure; and (6) clarifying consequences to manufacturers for invalid represented values.

DOE revises the test procedure such that tests of multi-circuit products, triple-capacity northern heat pump products, and multi-blower products can be performed without the need of an interim waiver or a waiver. Existing interim waivers and waivers for these products, as applicable, regarding these products will terminate 180 days after publication of this final rule.

DOE also terminates the existing waivers for air-to-water heat pump products integrated with domestic water heating because, as discussed in section III.C.1, DOE has determined that these

waivers are not valid because they do not provide a method for measurement of the efficiency metrics used to determine compliance with applicable standards.

DOE adopts test methods and calculations for off mode power that do not impact the measured energy with respect to the current energy conservation standard. Specifically, the adopted test procedure includes the following:

- (1) Provision of an option to conduct the off mode tests in a temperature-controlled room rather than a psychrometric room;
- (2) Elimination of ambient condition requirements for units whose off mode power consumption can be measured without control of ambient temperature;
- (3) Alteration of the off mode multiplier for modulated compressors;
- (4) Addition of requirements on the heating season off mode power measurement for units having a crankcase heater whose controls cycle or vary crankcase heater power over time;
- (5) Clarification of test sample set-up and power measurement testing methodology and components;
- (6) Addition of requirement to eliminate the time delay effect on the off mode power measurement; and
- (7) Elimination of the condition where P2 is equal to zero in the off mode power consumption calculation.

In this final rule DOE also improves the repeatability/reproducibility and reduces the test burden of the test procedure. Specifically, DOE amends the following:

- (1) Clarification of fan speed settings;
- (2) Clarification of insulation requirements for refrigerant lines and addition of a requirement for insulating mass flow meters;
- (3) Addition of a requirement to demonstrate inlet air temperature uniformity for the outdoor unit using thermocouples;
- (4) Addition of a requirement that outdoor air conditions be measured using sensors measuring the air captured by the air sampling device(s) rather than the temperature sensors located in the air stream approaching the inlets;
- (5) Addition of a requirement that the air sampling device and the tubing that transfers the collected air to the dry bulb temperature sensor be at least two inches from the test chamber floor, and a requirement that humidity measurements be based on dry bulb temperature measurements made at the same location as the corresponding wet bulb temperature measurements used to determine humidity;

(6) Clarification of maximum speed for variable-speed compressors;

(7) Addition of requirements that improve consistency of refrigerant charging procedures;

(8) Allowance of an alternative arrangement for cyclic tests to replace the currently-required damper in the inlet portion of the indoor air ductwork for single-package ducted units;

(9) Clarification of the proper supply voltage for testing;

(10) Revision of the determination of the coefficient of cyclic degradation (C_D);

(11) Option for a break-in period of up to 20 hours;

(12) Update of references to industry standards where appropriate;

(13) Inclusion of information from the draft AHRI 210/240;

(14) Addition of provisions regarding damping of pressure transducer signals to avoid exceeding test operating tolerances due to high frequency fluctuations;

(15) Clarification of inputs for the demand defrost credit equation; and

(16) Improvement of test consistency associated with indoor unit air inlet geometry.

DOE also provides additional detail and specificity with respect to several provisions. Specifically, DOE adds reference to an industry standard for testing variable refrigerant flow multi-split systems; replaces the informative guidance table for using the test procedure; clarifies the definition of multi-split systems; clarifies the definition of mini-split systems, which DOE now calls multi-head mini-split systems; and clarifies the housing for uncased coils.

Lastly, DOE addresses comments received from stakeholders in response to the November 2015 SNOPR that were unrelated to any of DOE's proposals. Specifically, this includes the following:

- (1) Water condensation metric;
 - (2) Barometric pressure correction ;
- and
- (3) Inlet screen.

Given the difficulty of writing amendatory instructions to implement the many small changes throughout appendix M, DOE has provided a full reprint of appendix M in the regulatory text of this final rule.

DOE revises the test procedure in this final rule as reflected in the revised Appendix M to Subpart B of 10 CFR part 430 effective on July 8, 2016. The amended test procedure is mandatory for representations of efficiency as of December 5, 2016.

III. Discussion

This final rule amends the test procedure for central air conditioners

and heat pumps in appendix M to subpart B of Part 430 and adds new product-specific certification and enforcement provisions in 10 CFR 429.12, 429.16, 429.70, and 429.134.

The rule also amends certain definitions found in 10 CFR 430.2 and updates certain materials incorporated by reference in 10 CFR 430.3.

In response to the November 2015 SNOPR, the following 25 interested parties submitted written comments: Advanced Distributor Products LLC; Air-Conditioning, Heating, and Refrigeration Institute (AHRI); American Council for an Energy Efficient Economy (ACEEE); Appliance Standards Awareness Project (ASAP); First Co.; Goodman Global, Inc.; Heating, Air Conditioning & Refrigeration Distributors International (HARDI); Ingersoll Rand; Johnson Controls Inc. (JCI); Lennox International Inc; LG Electronics U.S.A., Inc; Mitsubishi Electric Cooling & Heating; Natural Resources Defense Council (NRDC); Nortek Global HVAC; Northwest Energy Efficiency Alliance (NEEA); Northwest Power and Conservation Council (NPCC); Pacific Gas and Electric Company (PG&E); Rheem Manufacturing Company (Rheem); San Diego Gas and Electric Company (SDG&E); Southern California Edison (SCE); Southern California Gas Company (SCG); Unico, Inc.; United Refrigeration, Inc. (URI); United Technologies Climate, Controls & Security (UTC), also known as Carrier Corporation. NEEA and NPCC submitted a joint comment. PG&E, SDG&E, SCG, and SCE, hereafter referred to as the California Investor-Owned Utilities (California IOUs), also submitted a joint comment. ACEEE, ASAP, and NRDC, hereafter referred to as the Efficiency Advocates, also submitted a joint comment.

Interested parties provided comments on a range of issues, including those DOE identified in the November 2015 SNOPR, as well as several other pertinent issues related to DOE's proposal. Commenters also offered thoughts on further opportunities to improve the clarity of the test procedure. These issues, as well as DOE's responses to them and the resulting changes to DOE's proposal, are discussed in the subsequent sections. A parenthetical reference at the end of a comment quotation or paraphrase provides the location of the item in the public record.⁵

⁵ The parenthetical reference provides a reference for information located in the docket of DOE's rulemaking to amend the test procedures for central air conditioners and heat pumps. (Docket No.

A. Definitions, Testing, Represented Values, and Compliance of Basic Models of Central Air Conditioners and Heat Pumps

On August 19 and 20, 2014, DOE issued two draft guidance documents regarding the test procedure for central air conditioners and heat pumps. One guidance document dealt with testing and rating split systems with blower coil indoor units (Docket No. EERE-2014-BT-GUID-0033); and the other dealt more generally with selecting units for testing, rating, and certifying split-system combinations, including discussion of basic models and of condensing units and evaporator coils sold separately for replacement installation (Docket No. EERE-2014-BT-GUID-0032). The comments in response to these draft guidance documents were discussed in the November 2015 SNOPR. DOE proposed changes to the substance of the draft guidance that reflects the comments received as well as the recommendations of the Regional Standards Enforcement Working Group (Docket No. EERE-2011-BT-CE-0077-0070, Attachment). DOE makes additional modifications in this final rule in response to comment on the November 2015 SNOPR as well as the recommendations of the CAC/HP ECS Working Group (Docket No. Docket No. EERE-2014-BT-STD-0048, No. 76). The adopted changes supplant the two draft guidance documents; DOE will not finalize the draft guidance documents and has instead provided any necessary clarity through this final rule.

1. Basic Model Definition

In the November 2015 SNOPR, DOE proposed modifying its basic model definition for central air conditioners and heat pumps. 80 FR at 69282-4 (Nov. 9, 2015). Under DOE's proposal, manufacturers could consider each individual model/combination its own basic model, or manufacturers could assign all individual models of the same single-package system or all individual combinations using the same model of outdoor unit (for outdoor unit manufacturers (OUM)) or model of indoor unit (for independent coil manufacturers (ICM)) to the same basic model. DOE proposed to further define (for both single-package units and split systems) the physical characteristics necessary to assign individual models or

EERE-2009-BT-TP-0004, which is maintained at <http://www.regulations.gov/#/docketDetail;D=EERE-2009-BT-TP-0004>. The references are arranged as follows: (commenter name, comment docket ID number, page of that document).

combinations to the same basic model. 80 FR 69278, 69282–83 (Nov. 9, 2015).

DOE proposed that, if a manufacturer chooses to assign each individual model or combination to its own basic model, the manufacturer must test each individual model/combination—and that an AEDM could not be applied. 80 FR 69278, 69283 (Nov. 9, 2015). If manufacturers assign all individual combinations of a model of outdoor unit (for OUMs) or model of indoor unit (for ICMs) to a single basic model, DOE further proposed that each individual combination within a basic model must be certified with a rating determined for that individual combination. However, only one individual combination in each basic model would have to be tested (see section III.A.3.a), while the others may be rated using an AEDM. This option reduces testing burden but increases risk. Specifically, if any one of the combinations within a basic model fails to meet the applicable standard, then all of the combinations within the basic model fail, and the entire basic model must be taken off the market. 80 FR 69278 at 69283 (Nov. 9, 2015).

Comments on these proposals are discussed in the following sections.

a. Basic Model Framework

The Joint Advocates of ACEEE, NRDC and ASAP (“Joint Advocates”) supported the proposed changes to the definition of a basic model and related testing and certification requirements. The Joint Advocates stated that they believe that the clarified testing requirements would reduce testing burden on manufacturers. (ACEEE, NRDC and ASAP, No. 72 at p. 1) Nortek supported DOE’s proposal that manufacturers would have a choice in how to assign individual models or combinations to basic models. (Nortek, No. 58 at p. 3) ADP and Lennox supported the use of the basic model as the basis for any enforcement action as discussed in Section III.A.8 (80 FR 69278, 69297 (Nov. 9, 2015)) and the proposed 10 CFR 429. (ADP, No. 59 at p. 7; Lennox, No. 61 at p. 14)

NEEA and NPCC commented that DOE’s proposed approach that all combinations within the basic model are deemed noncompliant if only one of the combinations within a basic model fails does not align with the other aspects of DOE’s current proposal, in which each and every combination has its own certified rating. (NEEA and NPCC, No. 64 at p. 2–3)

Carrier/UTC expressed the concern that if one combination amongst potentially hundreds of combinations rated with a given outdoor unit fails then the entire basic model will be

removed from the market and claimed that it is excessively punitive. Further, Carrier/UTC recommended a provision for saving the remaining indoor combinations of the basic model such as testing the tested combination and one (or more) other random indoor combinations. Carrier/UTC stated that the de-listing of the product should be limited to the combination that failed, not the entire basic model. (Carrier/UTC, No. 62 at pp. 5–6)

NEEA and NPCC further commented that they presume that DOE’s ratings guidance of August 19 and 20, 2014, would also be impacted by a requirement to rate all outdoor and indoor unit combinations and the proposal with regard to testing-derived versus AEDM-derived ratings. They asserted that the proposal would seem to require the rating of both coil-only and blower coil combinations, with the choice of either using the highest sales volume combination being tested (and all other combinations rated using an AEDM), or testing each combination as its own basic model. (NEEA and NPCC, No. 64 at p. 2–3)

In response to NEEA and NPCC, DOE disagrees that DOE cannot make a determination of compliance on a basic model basis simply because DOE permits the manufacturer to make different representations for combinations within a basic model. In response to NEEA, NPCC, and UTC/Carrier, DOE notes that it developed the proposal for the basic model framework in an effort to balance manufacturer test burden and risk. The determination of compliance with the standard is made at the basic model level, and the manufacturer may choose how to group models into basic models and whether or not to make use of an AEDM for represented values of combinations. DOE expects that the individual combinations grouped into a single basic model would have similarities that would make validation of one of the individual model/combination’s represented values a strong indication of the accuracy of the represented values of the other models/combinations—if the represented values are indeed different. DOE also notes that when manufacturers use an AEDM and DOE finds an invalid rating, manufacturers can conduct re-testing to re-certify the individual model/combination, as described in section 429.70.

DOE also notes that, as stated in the November 2015 SNOPR, this final rule will supplant DOE’s draft ratings guidance documents, which will not be finalized. Finally, DOE notes in response to NEEA and NPCC that the basic model framework itself does not

determine whether both coil-only and blower coil combinations must be rated; this is further discussed in section III.A.3.a. Given the support for the basic model framework voiced by many of the commenters, DOE adopts the framework as proposed in the SNOPR.

b. General Definition Comments

AHRI and several manufacturers including UTC/Carrier, ADP, Lennox, Nortek, and Unico agreed generally with DOE’s proposal to modify its basic model definition. (AHRI, No. 70 at p. 3; UTC/Carrier, No. 62 at p. 5–6; ADP, No. 59 at p. 7; Lennox, No. 61 at p. 14; Nortek, No. 58 at p. 3; Unico, No. 63 at p. 4) Rheem recommended that DOE adopt the industry standard definition for basic model, as defined by AHRI. (Rheem, No. 69 at p. 4) As described below, several commenters requested additional modifications to DOE’s proposed definitions; these comments are discussed below, along with revisions to the proposed definitions.

c. Split Systems Manufactured by OUMs and Single-Package Systems

For split systems manufactured by OUMs and single-package systems, AHRI, Lennox, Ingersoll Rand, Rheem, and Nortek recommended the removal of “the auxiliary refrigeration system components if present (e.g., expansion valve) and controls” from the proposed basic model definition. Lennox and Nortek commented that adding these components to the definition can greatly expand the number of basic models. (AHRI, No. 70 at p. 3; Lennox, No. 61 at p. 4; Ingersoll Rand, No. 65 at p. 11; Rheem, No. 69 at p. 4; Nortek, No. 58 at p. 3) Additionally, Lennox and Nortek suggested that there would not be a benefit to expanding the definition of basic model beyond the currently accepted industry practice as outlined in AHRI’s certification program. (Lennox, No. 61 at p. 4; Nortek, No. 58 at p. 3) DOE understands Lennox and Nortek are referring to the concept of a “basic model group” as the term is described in the AHRI Operations Manual for Unitary Small Air-Conditioners and Air-Source Heat Pumps, in section 1.5, “Basic Model Groups (BMGs).”

After reviewing the comments, DOE acknowledges that while use of different auxiliary refrigeration system components may impact measured performance, it may not do so significantly—for example, measurements made using two different thermostatic expansion valves that both maintain the same superheat should not be different. In an effort to balance manufacturer test burden with the

regulatory needs of the program to establish an appropriate basic model definition, DOE has not included the phrase “auxiliary refrigeration system components if present (e.g., suction accumulator, reversing valve, expansion valve) and controls” in the “basic model” definition for split systems manufactured by OUMs or for single-package systems. DOE notes, however, that each manufacturer is responsible for minor variations in efficiency differences resulting from such changes in design.

For the definition of a basic model for OUMs, Goodman agreed with DOE’s overall direction. However, Goodman commented that DOE’s proposed definition was too rigid and would not provide enough design flexibility to manufacturers. Specifically, Goodman cited the importance of the ability for a manufacturer to vary many aspects of its outdoor coils (e.g., style and fin depth) and to source components, such as compressors, from multiple component manufacturers. Goodman asserted that this flexibility in design would allow manufacturers to provide combinations that optimize their product offering to consumers, while still yielding similar performance and therefore meriting classification under a single basic model. Goodman suggested revised basic model definitions for split systems manufactured by OUMs and single-package systems in which the list of parameters affecting performance (e.g., compressor and outdoor coil properties) that had been proposed to define a distinct model be instead provided as guidance for the OUM to consider when deciding whether two variations of a design should have the same model number. (Goodman, No. 73 at pp. 2–3)

In response to Goodman, DOE recognizes the importance of allowing manufacturers flexibility in design. DOE agrees with Goodman that, for instance, using compressors from different compressor manufacturers in two different models should not require the manufacturer to classify these models as two separate basic models, if the models can still reasonably be described as having “essentially identical characteristics.” However, DOE believes that Goodman’s suggested revised definitions, by providing guidance but no requirements, would allow widely varying characteristics under the same model of outdoor unit or single-package unit. Rather than moving to definitions that provide flexibility limited only by guidance, DOE has instead modified the definitions to allow some design flexibility, while assuring that a large departure from a given design would require that the OUM establish a new

basic model. In the definitions established in this final rule for basic model for split systems manufactured by OUMs and single-package systems, DOE has removed certain requirements proposed in the November 2015 SNOPIR, and added tolerances for the remaining requirements. Specifically, these modifications from the proposal include: (1) Establishing a five percent tolerance for compressor displacement, capacity, and power input; (2) removing requirements for several outdoor coil parameters; (3) adding a five percent tolerance to the face area and total fin surface area of the outdoor coil; (4) adding a ten percent tolerance on outdoor airflow, and (5) for single-package systems, allowing a ten percent tolerance on indoor airflow and a twenty percent tolerance on power input to the indoor fan motor.

In the basic model definition proposed in the November 2015 SNOPIR for split systems manufactured by OUMs and single-package systems, DOE specified that all individual models or combinations in a basic model must have the same or comparably performing compressor(s) with the “same displacement rate (volume per time) and same capacity and power input when tested under the same operating conditions.” 80 FR 69278, 69341 (Nov. 9, 2015). In order to promote design flexibility, DOE is adopting less stringent requirements in the basic model definition amended in this final rule by adding a five percent tolerance to the displacement rate and capacity and power input. DOE’s research suggests that comparable compressors made by different manufacturers vary by less than two percent in displacement rate and capacity and power input when tested under the same conditions. Therefore, DOE believes that a five percent tolerance allows manufacturers the option to use comparably performing compressors from different manufacturers in models without having to classify the models as separate basic models. Additionally, in the definition established in this final rule, DOE explains that the tolerances on compressor parameters refer to the values rated by the compressor manufacturer, not the performance of individual compressors.

In this final rule, DOE is adopting less stringent requirements for classifying as comparably performing outdoor coil(s) in the basic model definition for split systems manufactured by OUMs and single-package systems. To provide more flexibility to manufacturers, DOE is not adopting specifications in the basic model definitions for: Coil depth,

fin style (e.g., wavy, louvered), fin density (fins per inch), tube pattern, tube diameter, tube wall thickness, and tube internal enhancement. However, DOE has added a five percent tolerance to the face area and total fin surface area for outdoor coils. This tolerance on the outdoor coil areas will allow manufacturers to vary their designs while achieving similar performance, such as adding another row perpendicular to the airflow direction to the outdoor coil to compensate for using a more energy-consuming compressor.

Additionally, DOE is adding tolerances to the requirements for classifying as comparably performing outdoor fan(s) in the basic model definition for split systems manufactured by OUMs and single-package systems. DOE is adding a ten percent tolerance on outdoor fan airflow. DOE believes that this tolerance will allow manufacturers to make adjustments to the fans, such as increasing the number, diameter, or design of fan blades, without classifying comparably performing models as separate basic models.

UTC/Carrier agreed with DOE’s proposal to align the basic model definition with that used by AHRI; however, they asserted that the list of additional reporting requirements is excessive and burdensome. Specifically, UTC/Carrier stated that some of these components do not affect the performance of the system, are considered proprietary, and need not be reported. Additionally, they stated that some of these minor components may change due to sourcing availability. UTC/Carrier recommended that DOE align the basic model exactly with AHRI’s basic model group definition: Compressor model, outdoor coil face area, and outdoor airflow, and not require any additional data to be reported. (UTC/Carrier, No. 62 at p. 2)

For split systems manufactured by OUMs, Lennox recommended that the proposed OUM basic model definition be revised to more closely align with industry practices and recommended that the definition of outdoor coil be revised to protect business sensitive information. (Lennox, No. 61 at p. 4) Specifically, Lennox requested that the definition of outdoor coil-only include the words “same face area and depth, style.” Lennox suggested that DOE remove the remaining specification requirements for outdoor coils so that this sensitive business information could not be made available to the public and industry competitors through a FOIA request. (Lennox, No. 61 at pp. 3–4)

DOE acknowledges the importance of avoiding disclosure of proprietary or sensitive business information; however, in the November 2015 SNOPR DOE did not propose any additional certification requirements or supplemental test instruction reporting that would require disclosure of these parameters about which UTC/Carrier and Lennox cited concern. 80 FR 69278, 69338–39 (Nov. 9, 2015). Requirements for reporting are limited to those items listed in section 429.16(e), and mention of a parameter as the basis for distinguishing a model does not by itself imply that the value of that parameter must be reported in certification reports. DOE notes that it is not requiring that manufacturers report the sensitive information such as surface area or coil depth for which their basic model determinations are made.

In response to UTC/Carrier, DOE recognizes that minor components may vary in manufacturer designs based on availability from component manufacturers. However, DOE believes that the tolerances established in this final rule (as previously discussed) around most of the requirements in DOE's definition of basic model allow for variation in component models and manufacturers. DOE also believes that the requirements included in DOE's definition of basic model are necessary to ensure units are similar enough to be classified as the same basic model. DOE also notes that the definition established in this final rule includes tolerances on the compressor model ratings, outdoor coil face area, and outdoor airflow; therefore DOE's definition allows more flexibility for outdoor coil face area and outdoor airflow than does the definition of a split-system model group in the AHRI Operations Manual.⁶

In response to Lennox, as previously discussed, DOE has removed references to fin material, style, or density or tube thickness in the basic model definition established in this final rule, which will provide manufacturers with more flexibility in offering a varied product offering to consumers while limiting the testing burden.

d. Requirements for Independent Coil Manufacturers

Several commenters expressed concern about the impact of the proposed definition of basic model on ICM test burden. Therefore comments

regarding the ICM basic model definition are addressed in the context of testing required to determine represented values in section III.A.3.d.

e. Off-Mode

Revisions to the test procedure as stated in section III.D of this final rule enable the determination of off mode power consumption, which reflects the operation of the contributing components: crankcase heater and low-voltage controls. In the November 2015 SNOPR, DOE proposed that if individual combinations that are otherwise identical are offered with multiple options for off mode related components, manufacturers at a minimum must rate the individual combination with the crankcase heater and controls which are the most consumptive. Under this proposal, if a manufacturer wished to also make representations for less consumptive off mode options for the same individual combination, the manufacturer could provide separate ratings as long as the manufacturer differentiated the individual model numbers for these ratings. These individual combinations would be within the same basic model. 80 FR 69278, 69284 (Nov. 9, 2015).

In their comments, NEEA and NPCC strongly supported DOE's proposal to require manufacturers to either rate and certify all combinations using the most consumptive off-mode power controls and systems, or to differentiate models they wish to certify with different off-mode power controls and/or systems with different model numbers, each with its own certified rating. (NEEA and NPCC, No. 64 at p. 4)

DOE received no other comments on this proposal and adopts it in this final rule.

f. Central Air Conditioner Definition

In the November 2015 SNOPR, DOE proposed to clarify that a central air conditioner or central air conditioning heat pump may consist of: A single-package unit; an outdoor unit and one or more indoor units (e.g., a single-split or multi-split system); an indoor unit only (rated as a combination by an ICM with an OUM's outdoor unit); or an outdoor unit only (with no match, rated by an OUM with the coil specified in this test procedure). DOE proposed adding these specifications to the definition of central air conditioner or central air conditioning heat pump in 10 CFR 430.2. In the certification reports submitted by OUMs for split systems, DOE proposed that manufacturers must report the basic model number as well as the individual model numbers of the indoor unit(s) and the air mover where

applicable. 80 FR 69278, 69284 (Nov. 9, 2015).

Lennox and ADP expressed concern that modifying the CAC/HP definition to include "an indoor unit" only may have significant unintended consequences with additional regulation now applying to indoor units. They stated that the indoor unit has no heating or cooling capability without being installed as a part of the system, that by itself, it is a component, and that the proposed definition is factually incorrect and contradicts the DOE's previous position that they do not have authority to regulate components of air conditioners. Lennox recommended DOE keep the existing definition. (Lennox, No. 61 at p. 10; ADP, No. 59 at p. 4)

DOE notes that the modification of the CAC/HP definition does not change the scope of DOE's product coverage and is in line with the current certification requirements for CAC/HP. Specifically, ICMs are currently responsible for testing and certifying models of indoor units they manufacture as part of a split-system combination. DOE received no other comment on this topic. For these reasons, DOE is adopting the CAC/HP definition as proposed.

2. Additional Definitions

In the November 2015 SNOPR, in order to specify differences in the proposed basic model definition for ICMs and OUMs, DOE proposed definitions for an ICM and an OUM. With respect to any given basic model, a manufacturer could be an ICM or an OUM. 80 FR 69278, 69284 (Nov. 9, 2015).

DOE also proposed to define variable refrigerant flow (VRF) systems that are single-phase and less than 65,000 Btu/h as a kind of multi-split central air conditioner and central air conditioning heat pump system. Id.

Additionally, DOE proposed to clarify several other definitions currently in 10 CFR 430.2 with minor wording changes and move them to 10 CFR 430, Subpart B, Appendix M. DOE also proposed to remove entirely the definitions for "condenser-evaporator coil combination" and "coil family," as those terms no longer appear in the proposed regulations. Id.

DOE did not receive any comments on these definitions and related changes and adopts the proposals in this final rule.

a. Indoor Unit

In the November 2015 SNOPR, DOE proposed modifying the definition of indoor unit to read as follows: "indoor unit transfers heat between the refrigerant and the indoor air, and

⁶ AHRI's Operations Manual for Unitary Small Air-Conditioners and Air-Source Heat Pumps (Includes Mixed-Match Coils) (Rated Below 65,000 Btu/h) Certification Program (AHRI OM 210/240—March 2015). Available at www.ahrinet.org/App_Content/ahri/files/Certification/OM%20pdfs/USE_OM.pdf (Last accessed March 31, 2016.)

consists of an indoor coil and casing and may include a cooling mode expansion device and/or an air moving device.” 80 FR 69278, 69284 (Nov. 9, 2015).

Goodman commented that the definition for indoor unit does not fully account for the range of indoor units sold in the market. Specifically, Goodman stated that including the casing in the proposed indoor unit definition is inconsistent with many industry offerings. Goodman also suggested a new definition for indoor unit. (Goodman, No. 73 at p. 3–5)

AHRI and Nortek proposed a definition for indoor units that does not include casing and/or an expansion device. AHRI and Nortek expressed concern that the uncased coil would no longer be within the scope of regulation, which could open the doors for a loophole in the regulation, or that manufacturers would not be able to list an uncased coil with an outdoor unit, resulting in an illegal installation. AHRI and Nortek proposed definitions for uncased coil, cased coil, and service coil. (AHRI, No. 70 at p. 8; Nortek, No. 58 at p. 3–4). Further, AHRI stated that DOE should make clear that service coils will not be rated in the future. (AHRI, No. 70 at p. 8)

UTC/Carrier commented that the exclusion of uncased coils from DOE certification represents a significant loophole as uncased coils are often installed in various new construction scenarios and should be certified. According to UTC/Carrier, DOE should further define the replacement component service coils that are used only when the current coils fail and are considered service parts and, thus, should not be certified to DOE; the treatment of uncased coils in commerce by manufacturers as service-only is problematic. (UTC/Carrier, No. 62 at p. 3)

JCI commented that, while some manufacturers use uncased service coils, others supply service coils with casings on them. In addition, JCI commented that not all uncased coils are service coils. According to JCI, there are product families of uncased coils very often sold for new construction installations, or installation of new A/C systems in the northern parts of the United States. For example, JCI noted that often in the northern United States, a new home may be constructed with only a furnace for heating and no cooling, and that cooling may be added later by installing an uncased coil into the ductwork itself. JCI commented that the uncased coil market is a vital part of the northern U.S. market, and uncased coils need to be allowed to be

rated as valid matches with a basic outdoor model. (JCI, No. 66 at p. 12–13). JCI also suggested definitions for uncased coil, cased coil, service coil, and indoor unit. (JCI, No. 66 at p. 13)

The California IOUs requested that DOE allow manufacturers to rate uncased coils with outdoor condensing units. They reported that California Building Energy Efficiency Standards (Title 24) define the replacement of any component containing refrigerant to be a system alteration requiring verification of refrigerant charge and airflow through the coil. (see California Code of Regulations, Title 24, Part 1, Article 1, Section 150.2(b)(1)F) The California IOUs stated that the replacement of an indoor coil is an alteration whether the coil is cased or uncased. DOE asserted that DOE’s proposal to define uncased coils as repair parts and to not require them to be part of a rated model would create a compliance problem for contractors in California because without ratings, the energy efficiency of the system with an uncased coil is not known. The California IOUs stated that in applications where the existing coil is removed from the existing case and replaced with a new coil, which is then connected to a new outdoor unit, the efficiency rating is required to meet Title 24. Therefore, the California IOUs requested that DOE allow ratings of combinations having uncased indoor coils so that compliance with Title 24 can be verified. (California IOUs, No. 67 at p. 2)

ADP and Lennox commented that they understand the intent of excluding uncased coils is to differentiate between indoor units used for legacy replacements and new installations, but believe that DOE’s proposal would create a significant loophole. ADP and Lennox commented that uncased coils are used for new installations in a significant number of markets in the upper Midwest of the United States where a long tradition of skilled sheet metal workers exists. Additionally, they asserted that Canada is a predominately uncased coil market and relies on manufacturer ratings that have been certified with DOE and AHRI. Instead, ADP suggests that DOE require replacement coils not subject to certification to carry a different model number than those sold for installation as a part of new, certified systems. (ADP, No. 59 at p. 4–5; Lennox, No. 61 at p. 10)

After consideration of the comments that uncased coils may be used for new installations and that the exclusion of uncased coils from the indoor unit definition could result in a significant loophole, DOE is adopting a revised

definition for an indoor unit such that it “may or may not include . . . (e) external cabinetry”. To distinguish newly installed cased and uncased coils from replacement cased and uncased coils, DOE has added a definition for service coils and explicitly excluded them in the indoor unit definition.

Indoor unit means part of a split-system air conditioner or heat pump that includes (a) an arrangement of refrigerant-to-air heat transfer coil(s) for transfer of heat between the refrigerant and the indoor air and (b) a condensate drain pan, and may or may not include (c) sheet metal or plastic parts not part of external cabinetry to direct/route airflow over the coil(s), (d) a cooling mode expansion device, (e) external cabinetry, and (f) an integrated indoor blower (*i.e.* a device to move air including its associated motor). A separate designated air mover that may be a furnace or a modular blower (as defined in Appendix AA to the subpart) may be considered to be part of the indoor unit. A service coil is not an indoor unit.

Service coil means an arrangement of refrigerant-to-air heat transfer coil(s) and condensate drain pan that may or may not include sheet metal or plastic parts to direct/route airflow over the coil(s), external cabinetry, and/or a cooling mode expansion device, and is sold exclusively to replace an uncased coil or cased coil that has already been placed into service and is labeled accordingly.

DOE also acknowledges the benefit of including definitions for both cased and uncased coils, and adopts the following definitions:

Cased coil means a coil-only indoor unit with external cabinetry.

Uncased coil means a coil-only indoor unit without external cabinetry.

In the November 2015 SNO PR, DOE proposed to specify that if the indoor unit does not ship with a cooling mode expansion device, the system should be tested using the device as specified in the installation instructions provided with the indoor unit, or if no device is specified, using a thermostatic expansion valve (TXV). 80 FR 69278, 69284 (Nov. 9, 2015).

Goodman commented that DOE should not assume the use of TXV if a metering (expansion) device is not specified by the manufacturer. Goodman commented that the majority of systems installed today use fixed orifice rather than TXV expansion devices. (Goodman, No. 73 at p. 3–5)

DOE agrees that many product offerings use fixed orifice or piston expansion devices as standard equipment and that it may be more suitable to use a fixed orifice or piston

device if there are no detailed instructions provided in installation instructions regarding selection of an expansion device. This is because a system installed in the field without such instructions may very well perform poorly if an optimized device is not selected. Because a TXV generally is likely to provide better performance over a range of operating conditions, DOE believes the use of a fixed orifice is more consistent with this potential for poor field performance. Therefore, DOE is modifying its proposal and requiring instead that a fixed orifice or piston expansion device be used if the installation instructions do not specify a metering (expansion) device.

b. Blower Coil and Coil-Only Indoor Units

In the November 2015 SNO PR, DOE proposed definitions for blower coil indoor unit and coil-only indoor unit. The motivation was to simplify the description of the test requirements by referring to blower coil units instead of units “with an indoor fan installed” and to coil-only units instead of units “without an indoor fan installed”.

Blower coil indoor unit means the indoor unit of a split-system central air conditioner or heat pump that includes a refrigerant-to-air heat exchanger coil, may include a cooling-mode expansion device, and includes either an indoor blower housed with the coil or a separate designated air mover such as a furnace or a modular blower (as defined in Appendix AA).

Blower coil system refers to a split system that includes one or more blower coil indoor units.

Coil-only indoor unit means the indoor unit of a split-system central air conditioner or heat pump that includes a refrigerant-to-air heat exchanger coil and may include a cooling-mode expansion device, but does not include an indoor blower housed with the coil, and does not include a separate designated air mover such as a furnace or a modular blower (as defined in Appendix AA). A coil-only indoor unit is designed to use a separately-installed furnace or a modular blower for indoor air movement.

Coil-only system refers to a system that includes one or more coil-only indoor units. 80 FR 69278, 69286 (Nov. 9, 2015).

ADP and UTC/Carrier agreed with the proposed definitions for blower coil and coil-only indoor units. (ADP, No. 59 at p. 6; UTC/Carrier, No. 62 at p. 3) Lennox agreed with the proposed definitions with the exceptions noted in other sections. (Lennox, No. 61 at p. 13) Unico agreed with the coil-only indoor

definition, except recommended removing the word “modular” as there is no definition. Unico commented that the blower can be anywhere in the system. (Unico, No. 63 at p. 2) JCI suggested definitions for air handler, blower coil, and coil-only. (JCI, No. 66 at p. 13)

Rheem commented that the proposed definitions for blower coil and coil-only indoor units exclude the customary practice in the Northwest United States where an uncased coil is installed in a plenum for space-constrained installations. Rheem stated that under DOE’s proposal, a certified rating for this system configuration would no longer be available to consumers. Rheem noted that there are building inspectors who require an AHRI or DOE certified combination including the evaporator coil for replacements. (Rheem, No. 69 at p. 5)

DOE acknowledges that by excluding indoor units without a casing, the customary practice identified by Rheem would not be included. As noted in the previous section, DOE has addressed this by expanding the indoor unit definition to include units which may or may not have external cabinetry. The blower coil and coil-only indoor unit definitions then build on this updated indoor unit definition. Further, DOE has removed, from both the blower coil and coil-only indoor unit definitions, language redundant with the indoor unit definition and is adopting amended definitions:

In response to Unico’s comment regarding “modular”, the definition explicitly refers to the definition of “modular blower” in appendix AA. In response to JCI’s comment requesting a definition for “air handler”, DOE feels that this is not necessary because there are few distinctions in the test procedure between test requirements for blower coil indoor units that are air handlers (as defined by JCI) and blower coil indoor units that are not. In cases where a distinction is needed, the regulatory language adequately provides the distinction, for example in section 3.13.1.d, “blower coil split systems for which a furnace or a modular blower is the dedicated air mover . . .”, which refers to blower coil split systems whose indoor units are not “air handlers”.

3. Determination of Represented Values

In the November 2015 SNO PR, DOE proposed several regulatory changes regarding the relationship between represented values and an effective enforcement plan. The changes are described in the following sections.

a. Single-Split-System Air Conditioners Rated by OUMs

DOE proposed to make changes to 10 CFR 429.16 to revise the testing and rating requirements for single-split system air conditioners. These changes were proposed to occur in two phases. In the first phase, prior to the compliance date of any amended energy conservation standards, DOE proposed only a slight change to the current requirements. Specifically, DOE proposed that for single-split system air conditioners with single speed condensing units, each model of outdoor unit must be tested with the model of coil-only indoor unit that is likely to have the largest volume of retail sales with the particular model of outdoor unit. For split-system air conditioners with other than single speed condensing units, each model of outdoor unit must also be tested with the model of coil-only indoor unit likely to have the largest sales volume unless the model of outdoor unit is sold only with model(s) of blower coil indoor units, in which case it must be tested and rated with the model of blower coil indoor unit likely to have the highest sales volume. However, any other combination may be rated through testing or use of an AEDM. Therefore, both single speed and other than single speed systems may be rated with models of both coil-only or blower coil indoor units, but if the system is sold with a model of coil-only indoor unit, it must, at a minimum, be tested in that combination. 80 FR 69278, 69285–86 (Nov. 9, 2015).

In the second phase, DOE anticipated that any amended energy conservation standards would be based on blower coil ratings. Therefore, DOE proposed that all single-split-system air conditioner basic models be tested and rated with the model of blower coil indoor unit likely to have the largest volume of retail sales with that model of outdoor unit. Manufacturers would be required to also rate all other blower coil and coil-only combinations within the basic model but would be permitted to do so through testing or an AEDM. This proposed change would also be accounted for in the parallel energy conservation standards rulemaking, and would be contingent upon any proposed amended standards being based on blower coil ratings. Id.

DOE noted that these proposed testing requirements, when combined with the proposed definition for basic model, require that each basic model have at least one rating determined through testing; no basic model can be rated solely using an AEDM. Id.

DOE also proposed that in the certification report, manufacturers state whether each rating is for a coil-only or blower coil combination. 80 FR 69278, 69286 (Nov. 9, 2015).

Following publication of the November 2015 SNO PR, DOE held meetings of the CAC/HP ECS Working Group. The CAC/HP ECS Working Group recommended consensus energy conservation standards based on coil-only ratings rather than blower coil ratings, making the second phase of DOE's proposal no longer applicable. Many of the stakeholders who submitted comments on DOE's proposal were also members of the CAC/HP ECS Working Group, and as a result, their positions may have changed over the course of the negotiations. For these reasons, DOE has included the consensus recommendations of the CAC/HP ECS Working Group that pertain to DOE's proposal but has not included the comments of members of the CAC/HP ECS Working Group on the November 2015 SNO PR where the scope of the Working Group recommendation encompassed the scope of the comment.

With respect to the coil-only and blower coil requirements, ADP agreed with the proposed requirements of the first phase approach. (ADP, No. 59 at p. 5–6.)

JCI agreed with the single speed requirements in Appendix M but did not agree with DOE's proposed requirement for two-stage units or multi-stage units to be tested with a coil-only indoor unit, if any coil-only indoor units are listed with that outdoor unit. JCI recommended that there should be no change in the current regulatory text for two-stage or modulating equipment, and asserted that the spirit of the current regulation is met with blower coils remaining as the highest sales volume tested combination, even if there are limited loose coil or coil-only ratings available. (JCI, No. 66 at p. 5)

ADP had concerns that testing the highest sales volume combination (HSVC) with a blower coil in the second phase (in appendix M1) would make it more difficult for ICMs to accurately rate their products because of the added uncertainty of the indoor blower watts and airflow performance. Under the proposed second phase, with a blower coil indoor unit as HSVC, the indoor blower watt value is unknown by the ICM, forcing the ICM to estimate the watts, which introduces additional uncertainty to ICM ratings. Although ADP and Lennox recognized that ICMs could test the HSVC blower coil, they considered this to be an unreasonable testing burden on ICMs. (ADP, No. 59 at

p. 5–6) ADP proposed that DOE require the reporting of indoor watt data, indoor air volume rates, and indoor air mover settings and require that they be made publicly available. (ADP, No. 59 at p. 5–6) Unico stated that it preferred that the HSVC be a coil-only indoor unit so that they would be able to properly account for the fan power when rating their products. (Unico, No. 63 at p. 2)

Lennox; the Joint Advocates of ACEEE, NRDC, and ASAP; UTC/Carrier; Goodman; and Rheem had submitted comments in regard to the two-phase proposal related to coil-only and blower coil requirements. As noted previously, these stakeholders were members of the CAC/HP ECS Working Group, and as such the comments are not included here.

JCI commented that the current language used in Appendix M denoting the HSVC match cannot be determined with exact statistics and that it actually inhibits the adoption of new and promising advancements in product design. (JCI, No. 66 at p. 4) In contrast, Unico commented that, as an indoor coil manufacturer, it believes it to be important that the outdoor unit manufacturer continue to test and rate the HSVC, as this is an integral requirement for their AEDM to maintain accuracy. (Unico, No. 63 at p. 2)

UTC/Carrier also submitted a comment related to removal of the HSVC requirement. As noted previously, UTC/Carrier was a member of the CAC/HP ECS Working Group, and as such the comment is not included here.

In the term sheet, the CAC/HP ECS Working Group recommended that DOE implement the following requirements for single-split system air conditioners and suggested some implementing regulatory text:

- Every combination distributed in commerce must be rated.
 - Every single-stage and two-stage condensing unit distributed in commerce (other than a condensing unit for a 1-to-1 mini split) must have at least 1 coil-only rating that is representative of the least efficient coil distributed in commerce with a particular condensing unit.
 - Every condensing unit distributed in commerce must have at least 1 tested combination.
 - For single-stage and two-stage condensing units (other than condensing units for a 1-to-1 mini split), this must be a coil-only combination.
 - All other combinations distributed in commerce for a given condensing unit may be rated based on the application of an AEDM or testing in

accordance with the applicable sampling plan.

(Docket No. EERE–2014–BT–STD–0048, No. 76, Recommendation #7)

DOE notes that this recommendation is similar to DOE's Phase 1 proposal, as it is based primarily on coil-only values. In particular, single-stage and two-stage condensing units may not ever have only a blower coil represented value. The Working Group recommendation is consistent with ADP and Unico's comments requesting that the tested combination be a coil-only unit but inconsistent with JCI's request that two-stage units be tested with a blower coil. Given the preponderance of stakeholders supporting the recommendation, and the fact that multi-stage units may be tested and rated with a blower coil, DOE believes that adopting the Working Group recommendation best addresses the majority of stakeholder concerns. For these reasons, and given that there is no longer a need for a second-phase, DOE is adopting the recommendation in the term sheet, which will become effective 180 days after publication of this final rule. DOE notes that while 1-to-1 mini-splits are not expected to have a coil-only represented value, this exception does not appear explicitly in the regulatory text. DOE clarifies that since ductless mini-splits are never distributed in commerce as coil-only units, there is no coil-only value that would be representative. Therefore these units only require blower coil represented values. DOE also notes that the Working Group recommendation that every condensing unit distributed in commerce have at least one tested combination was based on the premise that manufacturers would group multiple individual combinations with a single model of outdoor unit into a basic model, as allowed in the adopted basic model definition. If manufacturers instead choose to make every individual combination (using the same model of outdoor unit) a separate basic model, each individual combination would be required to be tested. This aligns with the basic model framework discussed in section III.A.1.a.

DOE also adopts these recommendations for space-constrained split-system air conditioners given that they are subject to the same test procedure provisions and sampling plans as non-space-constrained single-split-system air conditioners.

DOE notes that both the current test procedure and the test procedure proposed in the November 2015 SNO PR requires that the test conditions used for testing coil-only units be the same as

those used for units with single-speed compressors. For example, section 3.2.1 of the current Appendix M indicates that these tests, listed in Table 4 of Appendix M as proposed, are, “. . . for a unit . . . with no indoor blower installed.” Because the regulatory approach finalized in this notice requires that two-stage condensing units have a coil-only test, DOE has removed “coil-only units” from the description of the units that must be tested using the Table 4 tests.

DOE notes that the CAC/HP ECS Working Group recommendation also removes the requirement that the tested combination be the HSVC. DOE believes the Working Group recommendation adequately addresses JCI’s concern about using the highest sales volume as a tested combination, but is inconsistent with Unico’s request that OUMs test and rate the HSVC. DOE will address this aspect of the recommendation in the separate notice and has not adopted it in this final rule.

Goodman commented that DOE has not adequately accounted for the inherent variability and uncertainty existing in the psychrometric test procedures in determining that the proposed change requiring two-stage units to be tested as coil-only would not affect the certified values. Goodman commented that the test methods specified by DOE, AHRI and ASHRAE have an uncertainty for steady state testing of approximately 6–8%.

Goodman also noted that ISO 16491:2012 Annex B lists several factors associated with the indoor air enthalpy method that contribute to uncertainty. Moreover, Table A.3 of ISO 16491:2012 indicates that for typical cooling capacity methods, relative expanded uncertainty might be 6.8%. Goodman commented that even at 0.05 SEER or 0.05 EER below the regional requirements, new test data would therefore either require the OUM to test additional samples or would cause a once-compliant unit to be marked as non-compliant for the regional standards. (Goodman, No. 73 at p. 17)

In response to Goodman’s concern about this change impacting measured energy use, DOE notes that current regulations require testing with the evaporator coil that has the largest volume of retail sales with the particular model of condensing unit. DOE understands that, for two-stage units, this is typically a coil-only combination since many homeowners do not replace the furnace at the same time when they replace their split-system air conditioning system and therefore that manufacturers should represent two-stage units as coil-only combinations. At

the manufacturer’s discretion, the two-stage units could also be represented as blower-coil combinations. Therefore, DOE does not believe the adopted requirements for two-stage units will change the impacted energy use,

b. Split-System Heat Pumps and Space-Constrained Split-System Heat Pumps

The current requirements for split-system heat pumps in 10 CFR 429.16 require testing a condenser-evaporator coil combination with the evaporator coil likely to have the largest volume of retail sales with the particular model of condensing unit.

In the November 2015 SNO PR, DOE proposed to slightly modify the wording explaining the testing requirement for split-system heat pumps to refer to the “evaporator coil” and condensing unit” as the “indoor unit” and “outdoor unit”, as the word “outdoor unit” is more appropriate for heat pumps than “condensing unit”. DOE also proposed to apply this same test requirement to space-constrained split-system heat pumps. 80 FR 69278, 69286–87 (Nov. 9, 2015).

DOE received no comment on this proposal, and in this final rule, DOE adopts the wording modifications. However, in the separate notice regarding Appendix M1, DOE will consider additional modifications based on the recommendations of the CAC/HP ECS Working Group with regard to split-system air conditioners.

c. Multi-Split, Multi-Circuit, and Multi-Head Mini-Split Systems

The current requirements in 10 CFR 429.16(a)(2)(ii) specify that multi-split systems and mini-split systems designed for installation with more than one indoor unit be tested using a “tested combination” as defined in 10 CFR 430.2.

In the November 2015 SNO PR, DOE proposed a slight modification to the testing requirements for single-zone-multiple-coil⁷ and multi-split systems and proposed to add similar requirements for testing multi-circuit systems (see section III.C.2 for more information about these systems). DOE also explained that these requirements apply to VRF systems that are single-phase and less than 65,000 Btu/h. For all multi-split, multi-circuit, and single-zone-multiple-coil split systems, DOE

⁷The November 2015 SNO PR defined a single-zone-multiple-coil split system as representing a split system that has one outdoor unit and that has two or more coil-only or blower coil indoor units connected with a single refrigeration circuit, where the indoor units operate in unison in response to a single indoor thermostat. In this final rule, DOE has adopted the term multi-head mini-split system instead.

proposed that, at a minimum, each model of outdoor unit must be tested as part of a tested combination (as defined in the CFR) composed entirely of non-ducted indoor units. For any models of outdoor units also sold with short-ducted indoor units, DOE proposed a second “tested combination” composed entirely of short-ducted indoor units would be required to be tested. DOE also proposed that a manufacturer may rate a mixed non-ducted/short-ducted combination as the mean of the represented values for the tested non-ducted and short-ducted combinations. 80 FR 69278, 69287 (Nov. 9, 2015).

Under the November 2015 SNO PR proposed definition of basic model, these three combinations (non-ducted, short-ducted, and mixed) would represent a single basic model. When certifying the basic model, manufacturers should report something like “* * *” for the indoor unit model number and report the test sample size as the total of all the units tested for the basic model, not just the units tested for each combination. For example, if the manufacturer tests 2 units of a non-ducted combination and two units of a short-ducted combination, and also rates a mixed combination, the manufacturer should specify “4” as the test sample size for the basic model, while providing the rating for each combination. DOE also proposed that manufacturers be allowed to test and rate specific individual combinations as separate basic models, even if they share the same model of outdoor unit. In this case, the manufacturer would provide the individual model numbers for the indoor units rather than stating a generic model, such as “* * *”.

DOE also proposed adding a requirement that, for any models of outdoor units also sold with models of small-duct, high velocity (SDHV) indoor units, a “tested combination” composed entirely of SDHV indoor units must be used for testing and rating. However, such a system would be certified as a different basic model. 80 FR 69278, 69287 (Nov. 9, 2015).

In the November 2015 SNO PR, DOE noted that multi-split systems consisting of a model of outdoor unit paired with models of non-ducted or short-ducted units should meet the energy conservation standards for split-system air conditioners or heat pumps, while systems consisting of a model of outdoor unit paired with models of SDHV indoor units should meet SDHV standards. DOE also proposed requirements for models of outdoor units that were rated and distributed in combinations that span multiple product classes to be tested and certified

as compliant with the applicable standard for each product class. Even if a manufacturer would sell a combination including models of both SDHV and other non-ducted or short-ducted indoor units, DOE proposed that the manufacturer should not provide a mixed rating for such combinations. 80 FR 69278, 69287–88 (Nov. 9, 2015).

Use of Term “Short-Ducted”

DOE received several comments regarding its use of short-ducted systems as well as requests for low-static and mid-static terminology and comments regarding conventional ducted systems. Many of these systems and ESP requirements were recommended as part of the CAC/HP ECS Working Group term sheet and will be discussed in a separate notice.

In this final rule, DOE has not adopted use of the term short-duct and instead refers only to ducted units.

Mixed Represented Values for SDHV and Other Indoor Units

Several stakeholders commented on whether they supported represented values for mixed multi-split systems including models of both SDHV and non-ducted or ducted indoor units, and if so, how they should be rated and whether the SDHV or split-system standard would be most appropriate.

Nortek commented that some manufacturers publish ratings in the AHRI Directory for SDHV and non-ducted as an average value and that it is appropriate to maintain this practice for this product as it is for the mixed (ducted and non-ducted) indoor multi-split ratings. (Nortek, No. 58 at p. 13)

Unico commented that they publish multi-split ratings for SDHV indoor units, non-ducted indoor units and a mixture of SDHV and non-ducted indoor units. The mixed rating is calculated as an average of the other two, which are based on tests. This is the same procedure used for ducted (“short-ducted”) and non-ducted indoor units. Unico requested the same consideration as all other manufacturers that have mixed (ducted and non-ducted) indoor multi-split ratings. (Unico, No. 63 at p. 3)

UTC/Carrier questioned whether there is any data available on the frequency of application of mixed SDHV and non-ducted, ducted or short duct unit systems to determine the need for a separate system rating. Lacking this data, UTC/Carrier recommended not supporting mixed multi-split system ratings for these systems. (UTC/Carrier, No. 62 at p. 4)

Goodman agreed that SDHV should not be intermixed with non-ducted or

other ducted indoor units, and that SDHV ICMs should be required to rate and certify such systems based upon the external static pressure associated with the SDHV indoor units. (Goodman, No. 73 at p. 13–14)

Unico agreed with DOE that the SDHV test standard is appropriate for testing the multi-split SDHV indoor units. However, Unico asserted that, in doing this, it is not necessary to apply a standard for the mixed indoor combinations since the ratings are based on other ratings that already meet their appropriate standard. (Unico, No. 63 at p. 3)

NEEA and NPCC supported the rating and certification of systems that are distributed in combinations that span more than one product class (such as multi-split and SDHV) and stated that these systems must be tested and rated so as to meet the standards for all product classes represented by the various available combinations. NEEA and NPCC suggested that each class rating be listed separately, in accordance with the testing and rating requirements for that class, and be so identified in the ratings documentation. (NEEA and NPCC, No. 64 at p. 4)

After reviewing the comments, DOE has determined that given that current industry practice includes mixed represented values for SDHV and other non-ducted or ducted indoor units, DOE will explicitly allow these mixed represented values based on an average of the represented values for each of the homogenous indoor systems. DOE has clarified this in 429.16. As noted in the November 2015 SNOPR, SDHV represented values must be a separate basic model. Any represented values for a mixed system including SDHV and another style of unit (non-ducted or ducted) must be in the same basic model as the SDHV model.

Ability To Test Mixed Systems

Several stakeholders commented on whether they supported having the ability to test mixed systems (*i.e.*, systems including both non-ducted and ducted indoor units) using the test procedure rather than using an average of the other tested systems.

UTC/Carrier did not support mixed system ratings nor test averaging due to consumer confusion, proliferation of ratings, and too many permutations. (UTC/Carrier, No. 62 at p. 4) The California IOUs commented that for all types of split systems, it is important to not have averaged ratings and cited as an example that, for the California Building Energy Efficiency Code (Title 24), the rating of the system being installed is needed to demonstrate

compliance. For incentive programs managed by Energy Efficiency Program Administrators such as the California IOUs, calculation and tracking of energy savings require that the installed system be known and its rating is available. (California IOUs, No. 67 at p. 3)

AHRI and Nortek commented that averaging of ducted and non-ducted ratings has been a long-standing industry practice. According to AHRI and Nortek, the kind of indoor ducted unit should be identified as part of the rating so that the mixed ratings could then be based on ratings for the specific kinds of indoor units. (AHRI, No. 70 at p. 16; Nortek, No. 58 at p. 13)

In response to UTC/Carrier, DOE notes that given the test requirements to make representations for individual combinations other than the “tested combination” (as discussed later in this section), and the limited amount of permutations currently listed in the AHRI directory, proliferation of represented values is not expected. In response to the California IOUs, DOE notes that the averaged represented values are based on represented values for kinds of individual systems (*i.e.*, ducted or non-ducted). As a result, an additional averaged represented value does not take away the availability of non-averaged represented values.

AHRI and Nortek also commented that, in industry practice, multi-split ratings with mixed indoor unit types are the numerical average of the ratings for each of the homogeneous indoor systems. They stated that the most common mixture is ducted and non-ducted indoor units. They asserted that there is no test procedure that could adequately test these combinations. (AHRI, No. 70 at p. 16; Nortek, No. 58 at p. 13)

Unico did not support testing mixed multi-split systems and commented that there is no adequate test procedure. Unico commented that using a numerical average of the individual (all ducted or all non-ducted) ratings is the best method to develop a rating for a mixed multi-split system. (Unico, No. 63 at p. 3)

Rheem commented that manufacturers should be permitted to test mixed systems instead of using an average to capture the interaction of the compressor with the multiple styles of indoor units. (Rheem, No. 69 at p. 5)

NEEA and NPCC commented that, given that the rating method for mixed multi-split systems will almost invariably produce a rating that is unrelated to how they actually operate in the field, they see no value in additional testing. However, NEEA and NPCC have no objection to

manufacturers testing such systems if the manufacturers believe the ratings would be better or more reliable with additional testing. (NEEA and NPCC, No. 64 at p. 4)

DOE acknowledges that testing mixed systems could capture interactions not captured in an average; however Rheem did not provide suggestions for how to develop such a test procedure. Given that several other stakeholders believe there is not currently an adequate test procedure to do so, DOE declines to add one at this time.

Options for Averaging

Several stakeholders commented on whether they support determining represented values for mixed systems using other than a straight mean, such as a weighting by the number of non-ducted or short-ducted units.

Unico did not support weighting mixed multi-split systems. Unico commented that indoor units are made in various sizes so the number of indoor units is not indicative of the load split. In addition, Unico stated that indoor units are designed to provide a range of capacities so the load split is dependent mostly on the application rather than the indoor unit size. (Unico, No. 63 at p. 3)

NEEA and NPCC expressed ambivalence regarding the use of weighting by the number of ducted and non-ducted units in the system. They asserted that any alignment of the actual performance of such multi-zone variable capacity systems in the field and their weighted ratings would be purely accidental. (NEEA and NPCC, No. 64 at p. 4)

Given the lack of interest in weighting mixed systems, DOE will continue to allow mixed represented values only as a straight average of two individual systems represented values containing homogenous kinds of indoor units (*i.e.*, non-ducted, ducted, or SDHV) tested with the appropriate method of test in the DOE test procedure.

Determining Represented Values for Specific Individual Combinations

Several stakeholders commented on whether DOE's proposed definition in the June 2010 NOPR for "tested combination" would be appropriate for determining represented values for specific individual combinations, or whether manufacturers prefer more flexibility, such as ability to test more than 5 indoor units. See 75 FR 31223, 31231 (June 2, 2010).

UTC/Carrier commented that rating multi-split systems with more than 5 units is unnecessary, because all manufacturers offer indoor units with a

nominal capacity of up to at least 12,000 BTU/hr. (UTC/Carrier, No. 62 at p. 5)

Mitsubishi commented that the original intent of the proposed "tested combination" definition was to provide variable-speed multi-split (VSMS) system manufacturers with a method to provide efficiency and capacity ratings that would be representative of all the combinations associated with a specific outdoor unit. Mitsubishi stated that DOE based the "tested combination" concept on the fact that the outdoor unit is the primary driver for efficiency and capacity and that DOE recognized that, if a manufacturer had "specific" combinations that had higher efficiencies than the "tested combination," then the manufacturer could test and rate that "specific" combination and enter it into the AHRI VSMS Directory of Certified Products. Mitsubishi recommended that DOE continue this process because it provides the VSMS manufacturer with the best opportunity to highlight top-performing combinations. (Mitsubishi, No. 68 at p. 3)

Unico supported the proposed DOE definition of "tested combination" and stated that there is no need to rate individual combinations unless the manufacturer chooses to rate all possible combinations (for example, if a manufacturer has a limited number of indoor models). Unico commented that single-split systems (one indoor unit) using the same outdoor unit used for multi-split systems should continue to be rated individually. (Unico, No. 63 at p. 4)

NEEA and NPCC acknowledged that combinations that might fall outside the current definition of "tested combination" systems do exist and are installed on a regular basis. The testing burden would be relatively small, as only the largest-capacity systems are capable of operating with more than 5 indoor units. (NEEA and NPCC, No. 64 at p. 4)

AHRI and Nortek commented that they do not believe the tested combination approach is appropriate for rating specific individual models. (AHRI, No. 70 at p. 16; Nortek, No. 58 at p. 13)

Rheem commented that the benefits of mix match ratings for multi-split systems are the same as those provided by mix match ratings for split systems. Rheem stated that consumers expect the ratings provided by DOE to reflect the operation of the system in their home and concluded that outdoor units should be rated to the worst case scenario and manufacturers should use an AEDM to determine the other combinations of indoor and outdoor

units. On the other hand, DOE notes that Rheem also commented that a configuration that represents the highest sales volume should be established for multi-split systems. (Rheem, No. 69 at p. 5)

After reviewing the comments, DOE maintains its proposal to allow manufacturers to rate individual combinations as additional basic models beyond the required tested combinations. DOE agrees with Rheem and Mitsubishi that consumers and utilities often find benefit for having represented values for a wide variety of combinations that are available for installation.

DOE also agrees with Unico that single-split systems (one indoor unit) using the same outdoor unit used for multi-split systems must continue to be rated individually.

Sample Size

Several stakeholders commented on DOE's request for information and data on manufacturing and testing variability associated with multi-split systems that would allow it to understand how a single unit may be representative of the population and what tolerances would need to be applied to represented values based on a single unit sample in order to account for variability.

Lennox commented that multi-split products are subject to the same type of variability as a conventional unit in areas such as compressor variation, coil performance variation, charging, airflow, expansion device, etc. Lennox did not support an allowance for OUM manufacturers of multi-split products to be rated based on a single unit test while OUM manufacturers of conventional products are required to test a minimum of two samples to meet statistical confidence levels. Lennox asserted that all OUM-manufactured products should be required to meet the same minimum test requirements. (Lennox, No. 61 at p. 14)

Mitsubishi and Rheem also recommended that the ratings be established based on the testing of at least two samples. (Mitsubishi, No. 68 at p. 3; Rheem, No. 69 at p. 6)

The California IOUs commented that, in addition to manufacturing variances, controls software creates an additional source of variability in the performance of multi-split systems. The California IOUs asserted that software drives the performance of these variable capacity units based on the input from indoor and outdoor sensors. They stated that, until DOE-vetted data is available for these controls, the use of results from a single unit test for rating is inadvisable. (California IOUs, No. 67 at p. 4)

Unico commented that a single unit test is adequate provided the manufacturer rates a system conservatively. Specifically, Unico said that a manufacturer should not be permitted to rate a product directly using the result of the single test; instead, the manufacturer can generate a rating from a single test through derating the measured performance. Unico gave the example that the rated capacity and efficiency of a system should be at least 95 percent less than the single test result. If two or more tests are conducted, then Unico suggested that the rating could be the mean value or less. (Unico, No. 63 at p. 4)

Goodman suggested that, if DOE mandates that ratings for a single given kind of air conditioner (ducted, non-ducted or mixed) be based on two sample systems, then OUMs should be able to use AEDMs to rate some of the kinds of systems. Goodman stated that, because many multi-split and multi-head mini-split systems use the same indoor products for multiple sizes (e.g., a 2-ton system may use two 1-ton indoor units while a 3-ton system may use three of the exact same 1-ton indoor units), a method to use an AEDM should be developed for rating non-tested

systems. Goodman gave the example that, if one OUM chose to test two sample systems of non-ducted indoor units, it should be able to rate ducted and mixed systems based on an AEDM. Goodman asserted that, if the OUM chose to have a single rating for all combinations of ducted indoor units, then the AEDM would obviously have to be used to rate the combination of ducted indoor units with the lowest efficiency rating. Goodman gave a contrasting example that, if another OUM chose to rate multiple different combinations of ducted indoor units, then each combination would be rated using an AEDM. (Goodman, No. 73 at p. 13)

AHRI and Nortek recommended that DOE maintain consistency with its AEDM approach used in the commercial HVAC equipment such that, at a minimum, manufacturers would test two low static units and apply the AEDM to derive ratings for the high static and mixed ratings. (AHRI, No. 70 at p. 16; Nortek, No. 58 at p. 13)

As previously noted, Rheem stated that outdoor units should be rated to the worst case scenario and manufacturers should use an AEDM to determine the

other combinations of indoor and outdoor units. (Rheem, No. 69 at p. 5)

After reviewing the comments, DOE found that commenters did not provide data on manufacturing and testing variability that would support DOE moving to a single unit sample approach. In response to Goodman, AHRI, Nortek, and Rheem, DOE notes that DOE's current regulations require that represented values for a single kind of system be based on testing a sample of at least two units representative of production units. For these reasons, DOE is not moving to a single unit sample approach and also declines to require only the represented values of a single kind of system to be based on testing while allowing other kinds of systems to be represented using an AEDM, given that the adopted testing requirements do not increase test burden compared to the current regulations. DOE is allowing use of an AEDM for off-mode, as discussed in section III.B.8.

Summary

In summary, Table III.2 provides an example of allowable represented values for multi-split, multi-circuit, and multi-head mini-split systems.

TABLE III.2—EXAMPLE REPRESENTED VALUES FOR MULTI-SPLIT SYSTEMS

Basic model	Individual model (outdoor unit)	Individual model(s) (indoor unit)	Sample size	Ducted rep. value	Non-ducted rep. value	Mix rep. value (D/ND)	SDHV rep. value	Mix rep. Value (SDHV/D)	Mix rep. value (SDHV/ND)
ABC	ABC	***	4	14	15	14.5
ABC-ND1	ABC	2-A123; 3-JH746	2	17
ABC-SDHV	ABC	***	6	11.5	12.75	13.25

d. Basic Models Rated by ICMs

In the November 2015 SNOPR, DOE proposed to require ICMs to test and provide certified ratings for each model of indoor unit (i.e., basic model) with the least-efficient model of outdoor unit with which it will be paired, where the least-efficient model of outdoor unit is the outdoor unit in the lowest-SEER combination as certified by the OUM. If more than one model of outdoor unit (with which the ICM wishes to rate the model of indoor unit) has the same lowest-SEER rating, the ICM may select one for testing purposes. ICMs must rate all other individual combinations of the same model of indoor unit, but may determine those ratings through testing or use of an AEDM. 80 FR 69278, 69288 (Nov. 9, 2015).

AHRI, ADP, Lennox, Mortex, and First Co. commented that DOE's proposed changes to the definition of "basic model" with respect to ICMs, along with the proposed requirement to

test at least one combination within each basic model, presents a significant testing burden to ICMs. (First Co., No. 56 at p. 1; AHRI, No. 70 at p. 3; ADP, No. 59 at p. 1; Lennox, No. 61 at p. 4) In order to avoid this burden, AHRI, ADP, Lennox, and Mortex recommended DOE adopt and define the term "Similarity Group," a group of ICM basic models within a defined range of coil geometries, with performance substantiated by the same validation test, and require testing of a Similar Group rather than testing of each basic model. The range of coil geometries within a Similarity Group would be defined by: face area within ± 1 square feet (e.g. 2-4, 4-6, etc.), fin material (e.g. aluminum, copper), fin style (e.g. wavy, louvered), fin density within ± 1 fin per inch (e.g. 10-12, 13-15, etc.), number of rows, tube pattern (e.g. 1 × 0.625, 1 × 0.75, etc.), tube size (e.g. outer diameter for round tube, channel characteristic size for

microchannel), and tube internal enhancement (e.g. smooth or enhanced). (AHRI, No. 70 at p. 5; ADP, No. 59 at p. 2-3; Mortex, No. 71 at p. 4-6; Lennox, No. 61 at p. 5) AHRI, ADP, Mortex, and Lennox noted that in the proposed framework, Similarity Groups may span AC and HP operations as well as coil-only and blower coil combinations. (AHRI, No. 70 at p. 6; ADP, No. 59 at p. 3; Mortex, No. 71 at p. 6; Lennox, No. 61 at p. 6)

However, the commenters noted that the proposed Similarity Group concept would not replace the concept or definition of an ICM basic model. Instead, a Similarity Group would be a group of basic models for defining AEDM validation test requirements, and the ICM basic model would still be used for other aspects of the certification and enforcement scheme as noted in the SNOPR. (AHRI, No. 70 at p. 7; ADP, No. 59 at p. 4; Mortex, No. 71 at p. 7; Lennox, No. 61 at p. 7)

With regard to DOE's proposed definition of basic model for ICMs, Lennox requested that tube wall thickness not be required as part of a certification report as to protect business sensitive design information. (Lennox, No. 61 at p. 3)

UTC/Carrier, Rheem, and the Joint Advocates of ACEEE, NRDC, and ASAP supported DOE's proposal for ICMs to test each model of indoor unit with the lowest-SEER model of outdoor unit that is certified as a part of a basic model by an OUM. (UTC/Carrier, No. 62 at p. 6; Rheem, No. 69 at p. 6; ACEEE, NRDC, ASAP, No. 72 at p. 2) UTC/Carrier appreciated leveling the playing field closing this loophole advantage for ICMs. (UTC/Carrier, No. 62 at p. 6)

On the other hand, AHRI, ADP, Lennox, and Mortex commented that testing is necessary to validate product performance and each ICM's AEDM, but that the requirement to test every basic model presents an excessive burden on ICMs. (AHRI, No. 70 at p. 3; ADP, No. 59 at p. 1; Mortex, No. 71 at p. 3; Lennox, No. 61 at p. 4) First Co. also commented that the result of DOE's proposal is excessive testing. (First Co., No. 56 at p. 1)

AHRI analyzed data from the AHRI Directory of Certified Product Performance, considering air conditioning, heat pump, coil-only and air handler ratings, but omitting due to time limitations air flow, external static pressure and power input. The results indicated that each ICM has between 287 and 604 basic models for which they would have to bear the cost of testing, which AHRI estimated would increase several-fold if accounting for the additional parameters. AHRI stated that it used an estimate of testing costs for one system at an independent lab of \$7,400 for AC and \$10,000 for HP because many ICMs do not have their own labs. Therefore, by AHRI's calculations, the ICM with the smallest number of basic models from their analysis would be required to perform 574 tests for an estimated \$5,740,000 in testing costs. In addition, a test takes approximately one day, so 574 tests would take approximately two years to complete. (AHRI, No. 70 at p. 4–5)

For these reasons, AHRI, ADP, Mortex, and Lennox recommended that DOE require all ICM ratings to be based on an AEDM, where the ICM would test and rate at least one combination of an outdoor unit with the lowest SEER that complies with standard per Similarity Group. They also recommended that the ICM perform at least one full-system test per Similarity Group, or if the ICM was rating HP combinations, the ICM test one-third of the Similarity Groups with

HP systems in both heating and cooling modes; and certify all combinations before they are distributed in commerce. (AHRI, No. 70 at p. 5–6; ADP, No. 59 at p. 2–3; Mortex, No. 71 at p. 4–6; Lennox, No. 61 at p. 5) AHRI, ADP, Mortex, and Lennox noted that applying this scheme to the AHRI Directory results in between 26 and 64 tests for the same ICM companies analyzed above. AHRI, ADP, Mortex, and Lennox believed that their suggested method provides for an extremely high level of AEDM validation while creating a manageable testing burden on ICMs. (AHRI, No. 70 at p. 6; ADP, No. 59 at p. 3–4; Mortex, No. 71 at p. 6; Lennox, No. 61 at p. 6–7)

First Co. and Unico also supported AHRI's approach. First Co. commented that the use of a Similarity Group would be a more realistic and workable approach that would enable ICMs to reduce testing for comparably performing indoor coils and to validate performance for the group by the same test. (First Co., No. 56 at p. 1) Unico recommended that DOE require the OUM to have at least two tests for each basic model (the outdoor unit) and the ICM to have at least one test from each Similarity Group in order to validate the AEDM. Unico also noted that the ICM testing requirements would increase significantly compared to what they are today even under AHRI's suggestion. (Unico, No. 63 at p. 4–5)

After reviewing the comments, DOE agrees with the manufacturers that its proposed definition of basic model with respect to ICMs, combined with the proposed testing requirements, may result in a significant test burden for ICMs. In order to balance the burden of testing with the risk of enforcement action, DOE is adopting aspects of the suggested "Similarity Group" as a replacement to its proposed definition of basic model. Hence, the basic model definition for ICMs established in this final rule includes all individual combinations having comparably performing indoor coil(s) [plus or minus one square foot face area, plus or minus one fin per inch fin density, and the same fin material, tube material, number of tube rows, tube pattern, and tube size].

DOE also agrees that manufacturers should test one combination per what the AHRI and manufacturer calls "Similarity Group", and what DOE will call a basic model for ICMs. However, DOE does not agree that testing should only serve to validate AEDMs. In order to accurately rate these non-engineered-to-order products by capturing the variability in the manufacturing processes, all combinations required to

be tested must be tested according to the sampling plan in 429.16, which generally requires a sample of at least two units of the basic model. DOE notes that AHRI's calculation of burden assumes that ICMs have not been testing under current regulations, which is not consistent with existing DOE regulations. In addition, by changing the proposed definition of basic model to align with the similarity group proposal, DOE has significantly reduced the proposed test burden on ICMs.

DOE notes that because basic models do not span product classes, unlike in the stakeholders' proposal, each Similarity Group is limited to either air conditioners or heat pumps; however, in response to the stakeholders' request that only one-third of Similarity Groups need be tested in both cooling and heating mode, DOE is not requiring testing for basic models of heat pumps as long as an equivalent basic model of air conditioner has been tested.

DOE also notes that while off-mode power consumption requirements apply to ICMs, the represented values for off-mode may be based on the results of testing by the OUM according to the requirements in 429.16.

In response to Lennox's request to remove tube wall thickness from the definition of basic model, DOE notes that the Similarity Group requirements DOE is adopting in its basic model definition for ICMs do not include tube wall thickness; in addition, as noted in section III.A.1.c, DOE did not propose that manufacturers report this information regardless of its inclusion in this definition.

e. Single-Package Systems

In the current regulations, 10 CFR 429.16(a)(2)(i) states that each single-package system must have a sample of sufficient size tested in accordance with the applicable provisions of Subpart B. In the November 2015 SNO PR, DOE proposed that the lowest SEER individual model within each basic model must be tested. DOE expected that in most cases, each single-package system would represent its own basic model. However, based on the definition of basic model in section III.A.1, this may not always be the case. DOE noted that regardless, AEDMs do not apply to single-package systems—manufacturers may either test and rate each individual single-package system or, if multiple individual models are assigned to the same basic model per the proposed requirements in the basic model definition, test only the lowest SEER individual model within the basic model and use that to determine the

rating for the basic model. 80 FR 69278, 69288 (Nov. 9, 2015).

DOE also proposed to specify this same requirement for space-constrained single-package air conditioners and heat pumps. 80 FR 69278, 69288 (Nov. 9, 2015).

DOE requested comment on the likelihood of multiple individual models of single-package units meeting the requirements proposed in the basic model definition to be assigned to the same basic model. DOE also requested comment on whether, if manufacturers are able to assign multiple individual models to a single basic model, manufacturers would want to use an AEDM to rate other individual models within the same basic model other than the lowest SEER individual model.

In response, Lennox commented that the use of basic models that meet the defined requirements should not be restricted to split-system products because allowing groupings in a basic model may allow the use of AEDMs for single-package products to reduce testing burden. (Lennox, No. 61 at p. 14) UTC/Carrier supported that different options would be assigned to [individual models within] the same basic model and supported the ability to have unique ratings for units with different options without additional testing. (UTC/Carrier, No. 62 at p. 6–7)

JCI stated that it, in general, would prefer to test single-package units, especially the single-phase models. For 3-phase (commercial) products, JCI would opt to utilize an AEDM. (JCI, No. 66 at p. 15)

Rheem disagreed that manufacturers should not be allowed to use AEDM to rate packaged units; Rheem would want to use an AEDM to rate other individual models within the basic model for packaged units. (Rheem, No. 69 at p. 3, 6–7)

In response to these comments, DOE is modifying the regulations to permit the use of AEDMs for models of single-package units in cases where multiple individual models are assigned to the same basic model. The lowest SEER individual model in the basic model still will be required to be tested. DOE believes that the lowest SEER model will typically be similar to the highest sales volume model.

f. Replacement Coils

In the November 2015 SNOPR, DOE noted that its proposed definition of “indoor unit” refers to the box rather than just a coil. Accordingly, legacy indoor coil replacements and uncased coils would not meet the definition of indoor unit of a central air conditioner or heat pump. Hence, they would not

need to be tested or certified as meeting the standard. 80 FR 69278, 69289 (Nov. 9, 2015).

DOE received several comments in response to this proposal. These comments have been addressed as part of DOE’s definition of “indoor unit,” discussed in section III.A.2.

g. Outdoor Units With No Match

For split-system central air conditioners and heat pumps, current DOE regulations require that manufacturers test the condensing unit and “the evaporator coil that is likely to have the largest volume of retail sales with the particular model of condensing unit” (commonly referred to as the highest sales volume combination or HSVC). 10 CFR 4429.16(a)(2)(ii). Effective January 1, 2010, the U.S. Environmental Protection Agency (EPA) banned the sale and distribution of those central air conditioning systems and heat pump systems that are designed to use HCFC–22 refrigerant. 74 FR 66450 (Dec. 15, 2009). EPA’s rulemaking included an exception for the manufacture and importation of replacement components, as long as those components are not pre-charged with HCFC–22. *Id.* at 66459–60.

Because complete HCFC–22 systems can no longer be distributed, manufacturers inquired how to test and rate individual components. Because the EPA prohibits distribution of new HCFC–22 condensing unit and coil combinations (*i.e.*, complete systems), there is no such thing as a HSVC, and hence, testing and determination of represented values of new HCFC–22 combinations cannot be conducted using the existing test procedure.

Accordingly, DOE proposed a test procedure that may be used for determining represented values and certifying the compliance of these outdoor units. DOE proposed to specify coil characteristics to be used when testing models of outdoor units that do not have a HSVC. Specifically, these requirements included limitations on indoor coil tube geometries and dimensions and coil fin surface area. In the November 2015 SNOPR, DOE proposed to require the normalized gross indoor fin surface (NGIFS) calculated for the indoor unit used for the test to be no more than 1.15. 80 FR 69278, 69289 (Nov. 9, 2015). NGIFS is the fin surface area divided by the unit’s capacity. By imposing a limit on this value, the size of the indoor coil would be consistent with older model designs that would likely be installed in the field and that do not include a common design approach for improving efficiency, *i.e.* use of larger coils.

Attaining a given efficiency level when testing a combination having a lower-NGIFS indoor unit requires use of a more efficient outdoor unit to compensate. These outdoor unit models must meet applicable Federal standards when tested with the specified indoor units.

General Comments

AHRI, URI, Nortek, HARDI, Goodman, UTC/Carrier, Rheem, and JCI submitted comments against adding the test procedure provisions for outdoor units with no match. (AHRI, No. 70 at p. 2; United Refrigeration, Inc., No. 60 at p. 3–4; Nortek, No. 58 at p. 2; HARDI, No. 57 at p. 2; Goodman, No. 73 at p. 17–18; UTC/Carrier, No. 62 at p. 22–23; Rheem, No. 69 at p. 3; JCI, No. 66 at p. 5)

Nortek and UTC/Carrier expressed concern that offering a test procedure for units with no match could potentially open up a larger loophole than what DOE is attempting to fix with this proposal. (Nortek, No. 58 at p. 2; UTC/Carrier, No. 62 at p. 23) Similarly, Nortek and HARDI noted that there have been no instances of a company trying to sell an outdoor unit without match that failed to meet existing standards. (Nortek, No. 58 at p. 2; HARDI No. 57 at p.1)

Conversely, Lennox, NEEA, NPCC, and the Joint Advocates of ACEEE, NRDC and ASAP concurred with DOE’s proposal to require testing and rating of dry-ship units. (Lennox, No. 61 at p. 2; NEEA and NPCC, No. 64 at p. 3; ACEEE, NRDC and ASAP, No. 72 at p. 2)

DOE acknowledges these comments and responds to particular concerns about its proposal in subsequent sections.

URI commented that the Department’s proposal not only would ban the manufacture of new replacement units, it also would impose significant cost burdens on manufacturers and distributors of replacement HCFC–22 components. URI suggested that under DOE’s proposal, replacement unit manufacturers that tested and certified HCFC–22 products in good faith reliance of the various test procedure guidance documents issued by the Department would be unable to advertise or sell these units. URI requested that DOE evaluate the impacts of replacing rather than repairing and maintaining an HCFC–22 unit, particularly on those consumers who live on a fixed income, and that DOE assess whether, as a practical matter, this test procedure amendment would adversely impact the availability of replacement components for the installed base of HCFC–22 units.

(United Refrigeration, Inc., No. 60 at p. 8–9)

In response to URI, DOE's approach in developing the test procedure requirements for outdoor units with no match is based on the concept that the test should produce results that measure energy efficiency during a representative average use cycle. (42 U.S.C. 6293 (b)(3)) Further, the test procedure addresses the fact that these units have no match. Unmatched outdoor units are primarily used as a low-cost alternative to replacement of an entire legacy system when the outdoor unit is no longer operational. Specifically, in such installations, only the outdoor unit would be replaced, rather than both the outdoor unit and indoor unit. In addition, such units would be installed using HCFC-22, which is no longer legal for use in new systems.

DOE developed this amended test procedure with the goal of ensuring that the unmatched outdoor unit should be compliant when tested with an indoor unit that is representative of indoor units in the field with which the outdoor unit could be paired. DOE's goal was to provide a method of test, consistent with the current standards, that meets the statutory requirement of measuring a representative average use cycle. Hence, the indoor unit specifications are intended to represent among the lesser-efficient units that could be paired with a given outdoor unit with no match. DOE believes this approach is consistent with the requirement that the represented value for a basic model reflect the performance of the poorest-performing model that is part of the basic model.

In response to URI's comments regarding evaluation of cost burdens and impacts of the test procedure change, DOE notes that its energy conservation standard rulemakings have already evaluated the costs and benefits of specific efficiency levels for central air conditioners and heat pumps. This test procedure provides a mechanism of assessing the performance of unmatched outdoor units, which can then be used to provide a reasonable level of assurance that all field-match combinations of the new, unmatched outdoor units will achieve the established efficiency levels. DOE is now adopting the November 2015 SNOPIR approach for testing and determining represented values for unmatched outdoor units based on stakeholder comment.

Goodman had concerns about unforeseen and unintended consequences when moving forward with alternate refrigerants at some date

in the future, especially as the requirements for applying air conditioners and heat pumps with these likely A2L refrigerants is unknown. Goodman stated that it expects that, with currently known alternate refrigerants, there may be a need for certain low-income and elderly consumers to have cost-effective replacement air conditioners. Goodman also noted that it has apprehensions that providing a test procedure provides a path for HCFC-22 "dry ship" products to continue in the marketplace. (Goodman, No. 73 at p. 18)

DOE responds that it cannot set test procedure requirements based on speculation about the potential cost impact of future refrigerant changes on air-conditioning product costs. In response to the second comment, DOE points out the suggestion of commenters that DOE's proposal will limit sales of these units—URI for example indicated that the test procedure will effectively end the manufacturer of such components (URI, No. 60 at p. 2). While DOE does not agree with this assessment, DOE also does not believe that the approach will increase manufacturer of such units.

DOE Authority

In its comments, JCI stated that it was not certain that DOE has the authority under EPCA to create a test procedure to allow for units with no match. (JCI, No. 66 at p. 6)

URI commented that the DOE's November 2015 SNOPIR test procedure, if finalized, would violate EPCA, as amended, as well as the Administrative Procedure Act. URI asserted that DOE had proposed a restriction on representations for already manufactured and certified units and that the proposal would invalidate the expectation-backed investments of manufacturers and distributors, constituting a violation of the Fifth Amendment to the U.S. Constitution. URI characterized DOE's proposal as an effective ban on condensing units using HCFC-22 that also would impose significant cost burdens on consumers. (United Refrigeration, Inc., No. 60 at p. 2, 3–5)

URI also commented that a test procedure change for replacement HCFC-22 systems is not needed, and that DOE has not articulated a valid basis for its proposal, as required by EPCA. URI argued that DOE's proposed test procedure change for replacement HCFC-22 systems would violate the Administrative Procedure Act, which requires an agency to "examine the relevant data and articulate a satisfactory explanation for its action

including a 'rational connection between the facts found and the choice made.'" 5 U.S.C. 553, *Motor Vehicle Manufacturers Ass'n v. State Farm Mutual Automobile Insurance Co.*, 463 U.S. 29 (1983)). URI said that the DOE did not only fail to explain why the change to the test procedure for replacement units is necessary, but also failed to acknowledge the de facto ban it is proposing for such units. URI argued that DOE does not have the authority to impose a ban on replacement units and asserted that, even assuming that DOE has the authority to impose such a ban, that EPCA prohibits the Department from implementing such an action through a test procedure amendment. (United Refrigeration, Inc., No. 60 at p. 5)

URI also argued that DOE could not circumvent the prohibition against retroactive effect by belatedly "clarifying" that HCFC-22 condensing components are basic models in and of themselves, even assuming that the EPCA would allow such a comprehensive revision of the "basic model" via test procedure rulemaking. (United Refrigeration, Inc., No. 60 at p. 9)

Contrary to URI's assertions, DOE is not, in this rule, imposing a de facto ban on condensing units using HCFC-22. DOE is amending a test procedure and, in accordance with the applicable provisions of EPCA, is ensuring that the test procedure is reasonably designed to measure the energy efficiency and energy use of unmatched outdoor units in a manner that is comparable to that of other complete systems. DOE clearly articulated the basis for its proposal and has explained again here the need for a test procedure applicable to unmatched outdoor units. Regarding the amended definition of basic model in today's rule, DOE is not proposing that the definition, as amended, be applied retroactively.

Test Procedure Details Including Specification of Indoor Unit

Stakeholders provided a range of comments regarding whether the proposed details of the test for outdoor units with no match are suitable.

Nortek, Ingersoll Rand, and Goodman questioned how DOE determined the proposed value for NGIFS and that the default coefficient of cyclic degradation should be used for these units, and requested that DOE provide supporting evidence. (Nortek, No. 58 at p. 2; Ingersoll Rand, No. 65 at p. 12; Goodman, No. 73 at p. 18)

URI commented that it is simply impossible for any HCFC-22 replacement component to meet the 13

SEER standard using the amended test procedure, stating that the proposed coil size limitation makes no sense as such coils were used in HCFC-22 units rated to 10 SEER. URI also asserted that the proposed coefficient of cyclic degradation improperly excludes units that use thermostatic expansion valves, rather than orifice tubes, to control the flow of refrigerants, thus penalizing the efficiency rating approximately 6% (for example, a 13 SEER unit with a thermostatic expansion valve would instead rate at 12.2 SEER). (United Refrigeration, Inc., No. 60 at p. 2, 7)

Goodman noted that by specifically choosing the 1.15 maximum NGIFS (especially without deference to the type of fin used), DOE is choosing indoor coils that are smaller, but not smallest, in size. Goodman commented that based on the information it has, the value of 1.15 would favor one manufacturer, which has all of its "no-match" units rated with indoor coils having less than 1.15 NGIFS, while at least two manufacturers have zero "no-match" units rated with indoor coils having less than 1.15 NGIFS. Goodman commented that DOE should not ignore fin surface type in the NGIFS calculation, and that if DOE's intent is to specify an indoor coil size such that it is virtually impossible for an OUM to have an outdoor unit with no match that can achieve 13 or 14 SEER as a system, then DOE should choose an NGIFS in the range of 0.90 or less using the proposed NGIFS formula. (Goodman, No. 73 at p. 18-19)

JCI commented for a 10 SEER product, the value of NGIFS of 1.15 is too small. The NGIFS of 10 SEER products made by JCI was 1.25, and these products will have been out of production for 10 years by the time this SNPOR is effective. JCI said that, at this point, when an outdoor unit fails, approximately 40% to 50% would be 13 SEER plus equipment. A reasonable NGIFS for 13 SEER equipment would be 1.30, which is the average for JCI's 13 SEER HCFC-22 product when the EPA ban on new produced equipment shipped with HCFC-22 took effect in 2010: averaging the 10 SEER and 13 SEER values leaves a value of 1.28. JCI believes this value to be a more representative value for NGIFS and recommends DOE adopt it. (JCI, No. 66 at p. 5-6)

Ingersoll Rand provided data on the 61 HCFC-22 systems that they had on the market before HCFC-22 was phased out. For the HVCs of these 61 models, the NGIFS ranged from 0.9784 to 1.9082 with a mean of 1.2692 and a standard deviation of 0.2215. Ingersoll Rand recommended a value of 1.75 for the

final rule. (Ingersoll Rand, No. 65 at p. 12)

JCI commented that modern heat exchanger technology such as that found in microchannel heat exchangers significantly reduces the refrigerant charge and thus reduces the cycling losses, resulting consistently in degradation coefficient values under 0.10 with piston metering (expansion) devices, or non-bleed TXVs. JCI recommended that rather than requiring use of the default degradation coefficient value, DOE should specify the type of expansion device it believes would be used in the legacy indoor units, which in most instances would be a piston or fixed orifice construction. (JCI, No. 66 at p. 6)

As mentioned above, DOE's approach in developing the test procedure requirements for outdoor units with no match is based on the concept that the test should produce results which measure energy efficiency during a representative average use cycle (see 42 U.S.C. 6293(b)(3)) while also ensuring that they will generally meet the standard. By their nature, however, neither the manufacturer nor DOE knows exactly what the paired system will be. DOE evaluated indoor unit specifications representing units across the spectrum that would likely be paired with the "no match" units. To ensure compliance, DOE proposed indoor unit specifications that it believed to be representative of a less efficient unit that could be paired with the given outdoor unit with no match.

In developing its proposal, DOE developed the indoor unit specifications (1.15 NGIFS and coefficient of cyclic degradation equal to the default) through reverse engineering 13 SEER split-system blower coil air conditioners designed to use HCFC-22. The 1.15 value is representative of the indoor units associated with the evaluated systems. All of these units had single-capacity compressors, and the indoor units had PSC fan motors. Although the NGIFS for these units ranged from 1.0 to 1.7, almost identical to the range of the data provided by Ingersoll Rand, DOE does not feel that establishing an NGIFS range is a valid approach, since this would be equivalent to setting the limit equal to the highest end of the range. In any case, both of these datasets are at odds with URI's claim that the 1.15 NGIFS makes attaining 13 SEER impossible. Regarding JCI's claim that the value is too small, the selected value is for an indoor unit that was part of an HCFC-22 unit rated at 13 SEER, hence it is certainly representative of the indoor units that may be installed in the field. In fact, DOE's selection of 1.15 did

not consider the 10 SEER units whose indoor units are still in the field as well. In addition, the actual performance of the non-replaced legacy indoor units, represented in terms of NGIFS, generally will be significantly degraded. Degradation of indoor unit performance can be caused by numerous factors, including foulants coating external coil surfaces, caustic environments attacking fin material and/or fin/tube contact, inadequate air flow, and degraded oil fouling the internal tube surfaces. Consistent with the use of unmatched outdoor units for such system repairs as a low-cost alternative, it is questionable whether installation consistently addresses optimization of the system for operation at the diminished efficiency potential of the degraded legacy indoor unit. Consequently it is expected that laboratory testing of new models of unmatched outdoor units significantly overestimates the efficiency of these units when paired with old legacy indoor units in the field. The proposed maximum NGIFS of the indoor unit to be used in such a test is in the range of the values for legacy indoor units, but, because of the non-optimum field conditions, choosing a value that is an average or median for such legacy indoor units is not representative. Based on all of these considerations, DOE has decided to lower the required NGIFS for the test to 1.0. This level acknowledges degradation of indoor unit performance over time, questions regarding optimization of the indoor/outdoor unit match and of the installation, and that the range of indoor units in the field would also include 10 SEER units. This value is representative of the 13 SEER systems of both DOE's and Ingersoll Rand's datasets. DOE notes that the comments have not shown that this value is unrepresentative of the potential indoor unit pairings of no-match outdoor units. Furthermore, given that DOE believes this value is representative and that an NGIFS range is not a valid approach, DOE does not believe there is a need for AEDM for these units.

DOE understands that the type of fin surface has an impact on coil performance, as Goodman pointed out in its comment. Most of the fins of the evaporator coils of DOE's dataset were enhanced, having lanced or louvered surfaces, so DOE's assessment has considered the possibility that the fin surfaces would be enhanced. DOE believes that selecting the NGIFS limit based on enhanced-fin information is appropriate because any manufacturer conducting such a test would do so using an indoor unit that has enhanced

fins, which would provide an advantage to the manufacturers.

DOE notes JCI's comment that when an outdoor unit fails, 40% to 50% of the indoor units would have been rated 13 SEER or higher. This suggests that at least half would have been rated lower than 13 SEER. JCI also suggested that NGIFS might be 0.05 lower for a 10 SEER indoor unit than for 13 SEER. The Ingersoll Rand comment indicates that the NGIFS of their HCFC-22 models on the market prior to the refrigerant's phase-out was as low as 0.9784. Since the 13 SEER standard took effect in 2006, DOE presumes that these units all had a SEER value no lower than 13.

DOE agrees with JCI that advanced heat exchanger technology might improve system efficiency. In particular, microchannel heat exchangers may reduce refrigerant charge sufficiently to reduce degradation of performance associated with unit cycling. However, DOE is not convinced that the expansion devices, be they thermostatic expansion valves, pistons, or fixed-orifice devices, of all legacy indoor units are replaced with orifices optimized for the new paired combination using the intended refrigerant. DOE agrees that a degradation coefficient less than the default value may be achievable in a laboratory test while using a fixed orifice device, but is not convinced that this will consistently be achieved with field-paired combinations. JCI did not comment on the consistency of the replacement of the expansion devices in unmatched outdoor unit installations, so DOE cannot determine how many such installations include expansion devices that are optimized for the outdoor/indoor unit combination. It is reasonable to expect that numerous such installations do not involve installation of an optimized expansion device, since unmatched outdoor units are sold as a low-cost alternative to purchase of an entirely new system, and use of the existing expansion device would also reduce cost. Further, DOE notes that reduction of the cyclic degradation coefficient, as proposed in the November 2015 SNOPR, was based on the observation that most modern systems achieve degradation coefficients well below 0.2. DOE did not intend to assign this same value as the default for outdoor units without a match. Based on the same arguments regarding lack of optimization of the expansion devices, DOE does not believe it is appropriate to adopt the new-test default of 0.2 for these units and therefore is retaining the current degradation coefficient for them at 0.25.

Waiver Process and Change in the Measurement

Nortek, Goodman, and HARDI commented that manufacturers who would like to sell a condensing unit with no match should request a waiver from DOE. (Nortek, No. 58 at p. 2; Goodman, No. 73 at p. 18; HARDI, No. 57 at p. 2)

URI commented that the notice is silent on how the proposed coil limitation or NGIFS will improve the measured energy efficiency of replacement HCFC-22 condensing units and that DOE's view that these units should have been tested pursuant to a waiver doesn't make sense in light of guidance DOE issued in 2010, 2012, and 2014. URI separately indicated that DOE has not clarified whether the test procedure change will alter the measurement and/or whether the standard would have to be adjusted as required by EPCA. (United Refrigeration, Inc., No. 60 at p. 6)

In response to Nortek, Goodman, and HARDI, DOE notes that the waiver process is a step towards establishing new procedure provisions in the CFR that address the test procedure issues raised by the waiver. In this case, as mentioned by some commenters, at the time of publication of the November 2015 SNOPR, there had been no petitions for waivers for outdoor units with no match. Test procedure waivers are not a long-term solution, however. DOE's regulations require DOE to amend its test procedure to address an issue raised through the waiver process. Therefore, even though DOE has not received any petitions for waivers for outdoor units with no match, DOE has long recognized the difficulty of reconciling the current test procedure language with the reality that manufacturers have no highest sales volume combination due to EPA regulations and proposed a test method to eliminate the regulatory incongruity between EPA's and DOE's regulations. DOE is finalizing a test procedure to eliminate the issue.

In response to URI, DOE acknowledges that its guidance document indicated that an individual condensing unit must meet the current Federal standard when paired with the appropriate other new part to make a system when tested in accordance with the DOE test procedure and sampling plan. However, as noted in the November 2015 SNOPR, generally when a model cannot be tested in accordance with the DOE test procedure, manufacturers must submit a petition for a test procedure waiver for DOE to assign an alternative test method.

Nothing in the guidance documents indicated that this would not have been the case for these units.

In response to URI's comment suggesting that measured energy use must improve under a waiver procedure, DOE notes that a test procedure waiver is not intended to impact measured energy efficiency. Instead, a test procedure waiver provides a manufacturer with an alternative method of test that will yield results comparable to the test procedure in the DOE regulations. Test procedures are not a mechanism to impact the efficiency of a product, which is why DOE has carefully evaluated the characteristics of a paired system so as to avoid impacting measured efficiency relative to the current test procedure.

Transition From Coverage Under the Guidance Documents

URI commented that the test procedure would effectively end the manufacture of such components six months after the revised test procedure goes into effect. URI contended that it also would be prohibited from selling or distributing its existing inventory of properly certified and rated HCFC-22 replacement condensing units six months after the effective date because the notice makes clear that "any representations, including compliance certifications," about the energy cost and efficiency of replacement condensing units must be based on the revised test procedure. (United Refrigeration, Inc., No. 60 at p. 2)

URI submitted that DOE should clarify in the preamble and regulatory text of a final test procedure that the restriction on representations does not apply to HCFC-22 condensing units that were manufactured and certified pursuant to the preceding DOE guidance. (United Refrigeration, Inc., No. 60 at p. 2)

In a letter to the Secretary of Energy, Lennox requested DOE to promptly issue guidance to prevent the entry of newly designed 14 SEER HCFC-22 dry-charge products into the southern and southwestern regions that do not meet the requirements of the DOE test procedure. Lennox commented that DOE action on these issues is particularly critical by early 2016, as manufacturers ramp up production for the 2016 summer air-conditioning sales season in that timeframe. (Lennox, No. 61 at p. 2)

Lennox requested DOE include mechanisms in the final rule to facilitate a quick and orderly market transition from legacy dry-shipped outdoor split-system central air conditioners and heat pumps certified to DOE as compliant

that are not rated in accordance with the test procedure final rule by requiring manufacturers to discontinue all non-compliant ratings 180 days after the final rule's publication. (Lennox, No. 61 at p. 2–3)

JCI recommended that no later than February 1, 2016, DOE should issue enforcement guidance stating that DOE will not seek civil penalties or injunctive relief for the distribution in commerce of a dry charged HCFC–22 unit (unit with no match), or for the labeling requirements of that unit, if the unit is manufactured prior to a date that is 30 days after the date of publication of the enforcement guidance. (JCI, No. 66 at p. 7)

On December 16, 2015, DOE issued an enforcement policy stating that it would begin investigating the methods manufacturers were using to rate split-system central air conditioners that do not have a highest sales volume combination. Those investigations are ongoing. DOE also stated that it would seek civil penalties for violations related to units manufactured on or after February 1, 2016, that had not been tested and properly certified as compliant with the applicable

standards. As DOE indicated in the policy statement, DOE will continue to use its discretion in determining whether or to what extent penalties are appropriate, including an evaluation of a manufacturer's good faith efforts to comply with the regulations. DOE notes that this test procedure final rule does not have retroactive application; however, the units at issue have been subject to the energy conservation standards and certification requirements since 2006.

DOE also notes that following the close of the comment period for the November 2015 SNOPR, on December 1, 2015, an ex parte meeting occurred between AHRI, manufacturers, and DOE regarding outdoor units with no match. Representatives from Nortek, Mitsubishi, Carrier, Lennox, Trane, Rheem, JCI, ADM, Goodman, and Allied Air attended. During this meeting, the attendees requested that DOE require that ratings of existing dry R–22 units must be discontinued 180 days after the date of the publication of the amended test procedure in the **Federal Register**. (Docket No. EERE–2009–BT–TP–0004–0074) This recommendation indicates that existing ratings for outdoor units

with no match are invalid and supports the need for a test procedure as finalized in this notice. DOE is implementing this recommendation consistent with EPCA, as discussed in section III.H.1.

4. Compliance With Federal (National or Regional) Standards

In the November 2015 SNOPR, DOE proposed to add requirements to the relevant provisions of section 430.32 that the least-efficient combination within each basic model must comply with the regional SEER and EER standards. 80 FR 69278, 69290 (Nov. 9, 2015). In addition, as noted in section III.A.1, DOE proposed that if any individual combination within a basic model fails to meet the standard, the entire basic model (*i.e.*, model of outdoor unit) must be removed from the market. In order to clarify the limitations on sales of models of outdoor units across regions with different standards, DOE proposed to add a limitation in section 429.16 that any model of outdoor unit that is certified in a combination that does not meet all regional standards cannot also be certified in a combination that meets the regional standard(s). Further,

Basic model	Individual model # (outdoor unit)	Individual model # (indoor unit)	Certified rep. value (SEER/EER)	Permitted?
AB12	ABC***-***	SO123	14.5/12.0	NO.
AB12	ABC***-***	SW123	15.0/12.8	
AB12	ABC***-***	N123	13.9/11.7	
CD13	CDESO**-*#*	SO123	14.5/12.0	YES.
CD13	CDESW**-*#*	SW123	15.0/12.8	
CD13	CDEN***-*#*	N123	13.9/11.7	
EF12	EFCS***-***	SO123	14.5/12.2	YES.
EF12	EFCS***-***	SW123	14.6/12.4	
EF12	EFCN***-***	N123	13.9/11.7	

DOE proposed to require that outdoor unit model numbers cannot span regions unless the model of outdoor unit is compliant with all standards in all possible combinations. If a model of outdoor unit is certified below a regional standard, then, under DOE's proposal, it must have a unique individual model number for distribution in each region. 80 FR at 69290 (Nov. 9, 2015).

For example:

The Joint Advocates of ACEEE, NRDC and ASAP commented that the approach proposed by DOE is workable and provides clear requirements for OUM rating systems. The Joint Advocates also commented that requiring a specific model number for outdoor units that are certified only in combinations that meet regional standard(s), and therefore permitted to

be installed in those regions, will aid enforcement. The Joint Advocates also commented that DOE should clarify the requirements for ICMs, specifically how DOE would treat an ICM that attempts to certify a combination with a rating below 14 SEER using an outdoor unit model that otherwise meets 14 SEER in all combinations certified by the OUM. (ACEEE, NRDC and ASAP, No. 72 at p. 3)

Based on this comment, DOE adopts the limitation as proposed, with wording modifications for clarity. DOE has not added a limitation on ICMs certifying a combination below an OUM represented value, given that such a value would reflect the performance the consumer would experience. DOE has not modified 430.32 in this rulemaking and will instead do so in the regional standards enforcement rulemaking.

5. Certification Reports

To maximize test repeatability and reproducibility for assessment and enforcement testing, DOE proposed a number of amendments to the certification reporting requirements. 80 FR 69278, 69290 (Nov. 9, 2015).

Among these requirements, DOE proposed to clarify what basic model number and individual model numbers must be reported for central air conditioners and heat pumps. 80 FR 69278, 69290–91 (Nov. 9, 2015). DOE proposed to require the reporting of the sensible heat ratio (SHR) value calculated based on full-load cooling test conditions at the outdoor ambient conditions: 82 °F dry bulb and 65 °F wet bulb. 80 FR at 69326 (Nov. 9, 2015). Finally, DOE also proposed to require certain product-specific information at 10 CFR 429.16(c)(4) that would not be

displayed in DOE's public database. 80 FR at 69291 (Nov. 9, 2015).

NEEA and NPCC supported DOE's proposals for certification reports, specifically noting the importance that all combinations of individual model numbers within a basic model group can be identified and to identify the outdoor and indoor mini-split and multi-split system units that are rated as combinations. (NEEA and NPCC, No. 64 at p. 3) DOE adopts this provision in the final rule.

Regarding the basic model provision, AHRI commented that ICMs should be required to identify in the certification report the Similarity Group to which each indoor unit belongs. (AHRI, No. 70 at p. 5–6) DOE notes that it has adopted the Similarity Group structure recommended by AHRI as the basis for the basic model for ICMs. Hence, identification of the Similarity Group is not necessary.

The California IOUs commented that the proposal to require reporting of SHR is a good precedent for providing other data from tests and requested that results also be reported for all the tests that are the inputs to calculation of SEER and HSPF, as well as the results of the AHRI maximum operational conditions test.⁸ (California IOUs, No. 67 at p. 4) On the other hand, AHRI, Lennox, ADP, UTC/Carrier, JCI, Goodman, and Nortek believe that SHR should not be reported as part of a certification report. (AHRI, No. 70 at p. 10; Lennox, No. 61 at p. 9; ADP, No. 59 at p. 7; UTC/Carrier, No. 62 at p. 8; JCI, No. 66 at p. 15–16; Goodman, No. 73 at p. 14; Nortek, No. 58 at p. 7) JCI noted that the publication of SHR should be left to the manufacturer as part of their technical literature, and UTC/Carrier noted that that information is already provided in the manufacturer's product data. (JCI, No. 66 at p. 12; UTC/Carrier, No. 62 at p. 7) AHRI, Lennox, ADP, Goodman, Nortek, and Rheem commented that the requirement to add reporting of SHR adds an excessive burden. (AHRI, No. 70 at p. 10; Lennox, No. 61 at p. 9; ADP, No. 59 at p. 7; Goodman, No. 73 at p. 14; Nortek, No. 58 at p. 7; Rheem, No. 69 at p. 8) ADP further commented that adding a requirement for SHR is significant for those OUM and ICM ratings developed by AEDMs, as manufacturers may not have this capability in their current AEDM. (ADP, No. 59 at p. 7) JCI further commented that the agreement made between AHRI members and advocates (presumably referring to the agreement in advance of the 2011 Direct Final

Rule) was intended to encourage manufacturers to list SHR in manufacturer technical literature, not to make it a certified value. (JCI, No. 66 at p. 15–16)

After reviewing these comments, DOE agrees that the joint proposal from stakeholders that served as the basis for the 2011 Direct Final Rule regarding central air conditioners stated that manufacturers would make the SHR at 82 °F (at the rated airflow) available in in manufacturer technical literature and Web sites but that the SHR would not be verified or certified by AHRI. The parties agreed that DOE did not need to take regulatory action to implement this information sharing. (Docket No. EERE–2011–BT–STD–0011, No. 16 at p. 7) DOE did not account for this agreement in the November 2015 SNOPR, and in response to stakeholder comment within this docket, proposed to require reporting of SHR. However, given the existing stakeholder agreement that underlay the 2011 Direct Final Rule, DOE is not adopting the proposed requirement to certify SHR.

AHRI, ADP, Lennox, UTC/Carrier, Ingersoll Rand, JCI, Nortek, Rheem, Goodman, and Mitsubishi did not support the additional reporting requirements proposed by DOE and commented that they are a significant burden on manufacturers. (AHRI, No. 70 at p. 13–15; ADP, No. 59 at p. 7; Lennox, No. 61 at p. 14–15; UTC/Carrier, No. 62 at p. 7; Ingersoll Rand, No. 65 at p. 12; JCI, No. 66 at p. 15; Nortek, No. 58 at p. 11; Rheem, No. 69 at p. 7; Goodman, No. 73 at p. 14, 19; Mitsubishi, No. 68 at p. 2–3) AHRI, Lennox, UTC/Carrier, Nortek, JCI, Rheem, Goodman, and Mitsubishi also commented that some of the required data is proprietary and puts the manufacturer at risk. (AHRI, No. 70 at p. 13–15; Lennox, No. 61 at p. 14–15; UTC/Carrier, No. 62 at p. 7; Nortek, No. 58 at p. 11; JCI, No. 66 at p. 12; Rheem, No. 69 at p. 7; Goodman, No. 73 at p. 14, 19; Mitsubishi, No. 68 at p. 2) JCI and Mitsubishi expressed concern that confidential information could be revealed in a FOIA request. (JCI, No. 66 at p. 12; Mitsubishi, No. 68 at p. 2)

AHRI and Lennox each provided a list of information that they support DOE requiring. (AHRI, No. 70 at p. 13–14; Lennox, No. 61 at p. 14–15) Unico agreed in its comments with AHRI's position on the reporting burden associated with the certification reporting requirements. (Unico, No. 63 at p. 6) Nortek commented that it supports DOE requiring information that is already being submitted to AHRI for purposes of certification. (Nortek, No. 58 at p. 10–11) Mitsubishi commented that manufacturers should not be

required to provide any physical information that is not needed to test the system. (Mitsubishi, No. 68 at p. 3) JCI commented that the only additional reporting information that should be added to the certification report is the off mode standby metric, and that no other unregulated items should be added. (JCI, No. 66 at p. 12)

Some stakeholders listed specific information that DOE should not require manufacturers to report. AHRI, Rheem, and JCI commented that DOE should not require manufacturers to report the orientation of a product's indoor coils and that, rather than reporting the process for manually entering the defrost cycle to DOE, manufacturers should describe that process in the product instructions. (AHRI, No. 70 at p. 13; Rheem, No. 69 at p. 7–8; JCI, No. 66 at p. 12) AHRI commented that for variable speed products, compressor frequency set points are proprietary to the manufacturer and therefore should not be reported to DOE. (AHRI, No. 70 at p. 15) Rheem commented that variable speed heat pump minimum and maximum speed blocks are proprietary and therefore should not be reported. (Rheem, No. 69 at p. 7–8) Goodman commented that their product nameplates do not explicitly state nominal capacity, nor do the majority of their competitors' products. Goodman recommended that the manufacturer provide the specific model numbers of the indoor unit tested rather than nominal capacity of each indoor unit. (Goodman, No. 73 at p. 6) Goodman also suggested that, instead of requiring manufacturers to solely report the general type of expansion device, DOE should require that manufacturers submit the same information (for fixed orifices, the orifice inside dimension (I.D.) and length; or, for expansion valves, the part number or model number) manufacturers currently submit to AHRI for each individual combination of a split-system air conditioner or split-system heat pump. (Goodman, No. 73 at p. 3–5)

Rheem commented that the addition of the requirement to certify airflow and C_D is a significant certification burden on manufacturers. Rheem noted that the documentation of the values measured during the test of a single sample cannot be applied to a second test, and that the averages of multiple measured values are even less applicable. Rheem stated that the certification of C_D requires that manufacturers provide a conservative value that would be applied to multiple test samples. Rheem suggested that the certification of a product should be based on actual product performance, as the use of a certified value of C_D would

⁸ This test is conducted with 115 °F air entering the outdoor coil, see AHRI 210/240–2008, Table 13.

increase the variability of the test procedure and require more conservative ratings and redesign of minimum efficiency equipment. (Rheem, No. 69 at p. 7)

After reviewing the stakeholders' comments, DOE maintains that the certification reporting requirements proposed in the November 2015 SNO PR, except for SHR as previously discussed, are necessary for DOE to be able to conduct testing. None of the commenters indicated how DOE could properly conduct testing without the requested information. In the November 2015 NOPR, DOE proposed that this information would not be made available on the DOE public Web site. While the information may be subject to Freedom of Information Act (FOIA), DOE will seek to protect this information to the extent legally permissible.

For these reasons, DOE has adopted these requirements in the final rule, with minor modifications as discussed in relevant sections. In response to Goodman, DOE notes that the model numbers of indoor units are required in addition to nominal capacity, which is needed to verify appropriate unit selection used for certification testing. DOE also declines to require additional information beyond the type of expansion device, as DOE does not need this information to conduct testing. In response to Rheem, as noted in section III.A.7, DOE is only requiring manufacturers to report whether they used a default value for C_D or whether they conducted the optional test; manufacturers do not have to report the C_D value used.

In their comments, the California IOUs requested that DOE require the reporting of all test results that are inputs to the calculation of SEER and HSPF. In addition, they requested that DOE collect the results of the AHRI Maximum Operational Conditions tests, which they acknowledge would require adding these tests to Appendix M/M1. As in the case of SHR, they argued that this would not add to the test burden; it would only add the additional reporting of results, because all the measurements required to calculate SHR (e.g., indoor air flow and indoor entering and leaving air conditions) are required as part of the current test. The California IOUs argued that consumers, incentive programs, and energy efficiency building codes need to have SEER and HSPF values that are calculated for specific climatic regions to enhance the value of the published SEER and HSPF that are calculated for climatic region 4. They said this would support the fair comparison of system

performance and annual energy use costs. (California IOUs, No. 67 at p. 3–4)

In this final rule, DOE declines to add the additional reporting requirements recommended by the California IOUs as these are not necessary for DOE testing, and existing programs currently operate without the additional detail requested.

6. Represented Values

In the November 2015 SNO PR, DOE proposed to make several additions to the represented value requirements in 10 CFR 429.16. First, DOE proposed adding a requirement that the represented values of cooling capacity, heating capacity, and sensible heat ratio (SHR) must be the mean of the values measured for the sample. Second, DOE proposed to move the provisions currently in 10 CFR 430.23 regarding calculations of various measures of energy efficiency and consumption for central air conditioners to 10 CFR 429.16. DOE proposed minor changes to the calculations of annual operating cost to address other changes proposed in Appendix M. 80 FR 69278, 69291 (Nov. 9, 2015).

Lennox, ADP, and UTC/Carrier commented that SHR is currently published by manufacturers and that there is no benefit to adding a single point SHR as a represented value potentially subject to enforcement. (Lennox, No. 61 at p. 9; ADP, No. 59 at p. 7; UTC/Carrier, No. 62 at p. 8) On the other hand, Unico supported the requirement to submit SHR but only for reporting purposes, not for testing and enforcement. (Unico, No. 63 at p. 6)

Although DOE has determined that manufacturers should not be required to report SHR (see section III.A.5), DOE is adopting requirements on the represented values for SHR as proposed, in order to generate consistency in any representations of SHR made by industry.

AHRI, Lennox, JCI, Ingersoll Rand, Goodman, UTC/Carrier, and Nortek disagreed with the requirement that the represented capacity values must be the mean of the tested values, and recommended that DOE allow manufacturers to rate capacity conservatively. (AHRI, No. 70 at p. 10; Lennox, No. 61 at p. 8, 15; JCI, No. 66 at p. 15–16; Ingersoll Rand, No. 65 at p. 5; Goodman, No. 73 at p. 15; UTC/Carrier, No. 62 at p. 8; Nortek, No. 58 at p. 6) Rheem similarly commented that the addition of the requirement to certify cooling capacity and heating capacity is a significant certification burden and does not allow for manufacturers to rate capacity conservatively. (Rheem, No. 69 at p. 8)

Nortek commented that DOE's proposal adds significant and unnecessary increased risk to a manufacturer due to increased exposure from enforcement testing. (Nortek, No. 58 at p. 6)

In its comments, Goodman noted that there is variability from sample to sample in any population of units. (Goodman, No. 73 at p. 15) Lennox commented that DOE's proposed use of mean values adds unnecessary risk and complexity in associated voluntary industry certification programs (VICP), such as AHRI. Lennox commented that manufacturers face stringent penalties through the AHRI VCIP program in the event of failure, and that manufacturers manage their financial and market risk through conservative ratings. Although DOE and VICPs may have different parameters for capacity metrics, Lennox believed DOE's proposal adds unnecessary complexity, which may confuse the consumer and bring into question the validity of different represented capacity values in the VICP program versus the DOE CCMS value. (Lennox, No. 61 at p. 8–9)

AHRI, Lennox, and JCI disagreed with DOE's proposal, stating that eliminating the conservative rating capacity would impact current ratings, which would require re-rating products. They contended that this requirement represents a significant and unnecessary burden that has no value to the consumer. (AHRI, No. 70 at p. 10; Lennox, No. 61 at p. 8; JCI, No. 66 at p. 7)

Several commenters recommended alternatives to DOE's proposal. Ingersoll Rand recommended that the average capacity on which to base the appropriate standard be determined using the same statistical method as used for determining SEER, but that the manufacturers be allowed to claim up to 5 percent lower in their rating. (Ingersoll Rand, No. 65 at p. 5) UTC/Carrier commented that the current procedure of using the mean or the statistically adjusted mean should be used and manufacturers should be able to de-rate the certified values as necessary to account for testing uncertainties in the audit facility as well as the manufacturer's test facility. (UTC/Carrier, No. 62 at p. 8) AHRI and Nortek commented that instead of implementing the mean of measured values for capacity, any represented value of the energy efficiency or other measure of energy consumption for which consumers would favor higher values should be less than or equal to the lower of: (1) The mean of the sample, or (2) the lower 90 percent confidence limit (LCL) of the true mean divided by 0.95. (AHRI, No. 70 at p. 10;

Nortek, No. 58 at p. 6–7) DOE understands that AHRI and Nortek supported DOE applying this approach to capacity as well.

After reviewing the comments, DOE is updating its proposal from the November 2015 SNOPR, which required represented values of cooling and heating capacity to be the mean of the sample. In this Final Rule, DOE is requiring the represented value of cooling (or heating) capacity to be a self-declared value that is no less than 95 percent of the mean of the cooling (or heating) capacities measured for the units in the sample selected for testing. This will allow manufacturers the flexibility to derate capacity with conservative values as requested by multiple commenters, while still providing consumers with information that is reasonably close to the performance they may expect when purchasing a system.

Goodman commented that DOE provided no guidance on how to treat systems rated by AEDM and that it is unreasonable to expect manufacturers to always rate at the exact value developed by a computer program. (Goodman, No. 73 at p. 15)

DOE agrees with Goodman. DOE's intent had been for represented values for systems rated by testing or AEDM to be determined similarly but had inadvertently left this requirement out of the AEDM portion of the regulatory text. To parallel the provision adopted for tested combinations, DOE is adopting a provision that the represented value of cooling (or heating) capacity must be no less than 95% of the cooling (or heating) capacity output simulated by the AEDM. DOE notes that, if a manufacturer believes the capacity predicted by the AEDM is more than 5% off of what the manufacturer would otherwise expect, then the manufacturer should be evaluating the validity of the AEDM in other respects.

Finally, DOE notes that Annual Performance Factor (APF) is not used for any regulatory program, and therefore DOE has removed all calculations and represented value requirements for APF in this final rule.

7. Product-Specific Enforcement Provisions

In the November 2015 SNOPR, DOE proposed to verify certified cooling capacity during assessment or enforcement testing. DOE proposed to measure the cooling capacity of each tested unit pursuant to the test requirements of 10 CFR part 430. If the measurement is within five percent of the certified cooling capacity, DOE would use the certified cooling capacity

as the basis for determining SEER. Otherwise, DOE would use the measured cooling capacity as the basis for determining SEER. 80 FR 69278, 69292 (Nov. 9, 2015).

DOE also proposed to require manufacturers to report the cyclic degradation coefficient (C_D) value used to determine efficiency ratings. DOE proposed to run C_D testing as part of any assessment or verification testing, except when testing an outdoor unit with no match. If the measurement is 0.02 or more greater than the certified value, DOE would use the measurement as the basis for calculation of SEER or HSPF. Otherwise, DOE would use the certified value. For models of outdoor units with no match, DOE would always use the default value. 80 FR 69278, 69292 (Nov. 9, 2015).

Lennox, UTC/Carrier, Rheem, and JCI disagreed with DOE's proposal to use rated values in cooling capacity and in C_D testing. The commenters proposed that tested capacity and cyclic test values should be used in all determinations of efficiency and compliance. (Lennox, No. 61 at p. 9; UTC/Carrier, No. 62 at p. 8; Rheem, No. 69 at p. 2; JCI, No. 66 at p. 8) Rheem commented that the proposal to enforce SEER using certified values of cooling capacity and C_D has not been justified or shown to provide representative and repeatable results. (Rheem, No. 69 at p. 8) Unico supported the requirement to submit cooling capacity and heating capacity but only for reporting purposes, not for testing and enforcement. (Unico, No. 63 at p. 6)

In its comments, Lennox explained that, given the variability in component and manufacturing processes, product capacity and power can vary slightly from unit to unit. According to Lennox, if products are manufactured within the acceptable limits, the variations in capacity and power tend to be linear. Lennox added that DOE's proposal to fix capacity to the rated value in determining efficiency if measured within five percent of rating while allowing power to be a variable from the tested value can result in both false pass and fail results. (Lennox, No. 61 at p. 9–10) Lennox also commented that cyclic C_D testing is prone to variation from test to test on the same unit within the same facility—let alone lab to lab, and that the industry has spent a tremendous amount of resources studying variability issues and has developed recommendations for lab improvement. In particular, Lennox commented, the industry has developed a method for compensating for differences in thermal mass of the test facility used for testing. (Lennox, No. 61 at p. 10)

Nortek and JCI commented that the proposal to use a tolerance to determine if measured capacity is within 5 percent of rated capacity and from there, determining efficiency, would make it necessary for manufacturers to report capacity at all points necessary to determine SEER and HSPF. (Nortek, No. 58 at p. 7; JCI, No. 66 at p. 7–8) JCI commented that this is an increased burden of reporting without additional value. (JCI, No. 66 at p. 7–8) In addition to this burden, Nortek expressed concern that this could lead to overrating capacity. As efficiency is not tied to capacity, Nortek stated it is unsure of the purpose of this proposal and would like DOE to clarify the purpose. (Nortek, No. 58 at p. 7)

Goodman commented that DOE's proposal to use certified rather than tested values conflicts with DOE's acknowledgement that individual unit performance varies from sample to sample due to both individual unit production differences as well as testing differences. Goodman noted that compressor suppliers would only certify the performance of their product to manufacturers to a $\pm 5\%$ tolerance. Goodman commented that from a statistics perspective, it is not correct to suggest that in order to determine the true mean of a population that modified values would be used from actual measurements. Goodman strongly opposed DOE's proposed regulatory language in reference to the assessment and enforcement testing of HVAC products as it pertains to assumed average performance values in the determination of the performance of an individual unit. Goodman strongly suggested that DOE omit the proposed 10 CFR 429.134(g) in its entirety. (Goodman, No. 73 at p. 21)

After reviewing the comments, DOE is adopting modifications from its proposal. For cooling capacity, DOE will use the mean of any DOE test measurements to determine SEER. DOE notes that this adopted modification, by eliminating the comparison to the manufacturer's represented value, addresses JCI's concern about additional reporting burden and Goodman's concern about using modified (certified) values rather than actual measurements. In addition, DOE's modification related to the represented value for capacity, in section III.A.6, addresses Nortek's concern about overrating.

In addition, DOE wishes to clarify that when calculating SEER values, manufacturers must use the tested capacity value, not the certified capacity value.

For the C_D value, in section III.E.11, based on stakeholder comments, DOE

has decided to allow manufacturers to use the default value without testing. The default value is conservative, and DOE believes that manufacturers will only opt to test if it will improve upon the default value for that model. DOE will follow the lead of the manufacturer in determining whether to use the default value or to test a given unit. Therefore, instead of reporting the C_D value used, the manufacturer must report whether the optional tests were conducted to determine the C_D value or whether the default value was used. If manufacturers report using the default value, DOE will also use the default value. If manufacturers conduct optional testing, DOE will also conduct testing to determine C_D . The result for each unit tested (either the tested value or the default value, as selected according to the criteria for the cyclic test in 10 CFR part 430, subpart B, Appendix M, section 3.5e) will be used to determine the applicable standards for purposes of compliance.

B. Alternative Efficiency Determination Methods

1. General Background

For certain consumer products and commercial equipment, DOE's existing regulations allow the use of an alternative efficiency determination method (AEDM) or alternative rating method (ARM), in lieu of actual testing, to estimate the ratings of energy consumption or efficiency of basic models by simulating their energy consumption or efficiency at the test conditions required by the applicable DOE test procedure. The simulation method permitted by DOE for use in rating split-system central air conditioners and heat pumps, in accordance with 10 CFR 429.70(e), is referred to as an ARM. In contrast to an AEDM, an ARM must be approved by DOE prior to its use.

DOE published a Notice of Proposed Rulemaking (AEDM NOPR) in the **Federal Register** on May 31, 2012. 77 FR 32038. In the AEDM NOPR, DOE proposed the elimination of ARMs, and the expansion of AEDM applicability to those products for which DOE allowed the use of an ARM (*i.e.*, split-system central air conditioners and heat pumps). 77 FR at 32055. Furthermore, DOE proposed a number of requirements that manufacturers must meet in order to use an AEDM, as well as a method that DOE would employ to determine if an AEDM was used appropriately along with specific consequences for misuse of an AEDM. 77 FR at 32055–56. DOE subsequently published a final rule, related to

commercial HVAC equipment only, on December 31, 2013 (78 FR 79579).

In the November 2015 SNO PR, DOE proposed modifications to the central air conditioner and heat pump AEDM requirements that were proposed in the AEDM NOPR. 80 FR 69278, 69292 (Nov. 9, 2015). In response to DOE's proposal, AHRI, Nortek, and Ingersoll Rand recommended that DOE align the CAC/HP AEDM proposal with commercial equipment AEDM provisions because the commercial and residential technologies, testing methods, and simulation approaches were nearly identical. (AHRI, No. 70 at p. 9; Nortek, No. 58 at p. 5; Ingersoll Rand, No. 65 at p. 11)

In response to that comment, DOE notes that its proposal was based off the commercial equipment AEDM provisions with slight modifications appropriate to the residential product, and as such declines to make the AEDM provisions identical to those for commercial equipment. However, revisions to specific aspects of the proposal based on stakeholder comments are discussed in subsequent sections.

First Co. commented that the DOE's proposed modifications in the November 2015 SNO PR require manufacturers to develop an AEDM for heat pumps. First Co. noted that any AEDMs used by an ICM to rate systems would require coefficient data from the OUM, which is not required to be publicly disclosed and which is not currently available to ICMs. First Co. commented that this issue must be addressed in the rule. (First Co., No. 56 at p. 1)

In response to First Co.'s comment, DOE notes that its proposal in the November 2015 SNO PR did not require use of an AEDM. 80 FR 69278, 69292 (Nov. 9, 2015). Manufacturers may choose to test all individual combinations within a basic model rather than applying an AEDM. Therefore, DOE has not made any changes to its proposal in response to First Co.'s concerns.

AHRI, ADP, Mortex, and Lennox commented that, for ICMs, certified ratings must be less than or equal to AEDM output. (AHRI, No. 70 at p. 5–6; ADP, No. 59 at p. 2–3; Mortex, No. 71 at p. 4–6; Lennox, No. 61 at p. 5)

In response, DOE notes that in 10 CFR 429.16, DOE adopted the requirement that represented values of efficiency must be less than or equal to the output of the AEDM, while represented values of power must be greater than or equal to the output of the AEDM. In addition, under 10 CFR 429.70(a), represented values must never be "better" (overrate

efficiency or underrate consumption) than the output of the AEDM. These requirements apply to all manufacturers, not just ICMs.

2. Terminology

In the AEDM NOPR, DOE proposed to eliminate the term "alternate rating method" (ARM) and instead use the term "alternative efficiency determination method" (AEDM) to refer to any modeling technique used to rate and certify covered products. 77 FR 32038, 32040 (May 31, 2012). In the November 2015 SNO PR, DOE continued to propose the use of one term, AEDM, to refer to all modeling techniques used to develop certified ratings of covered products. 80 FR 69278, 69293 (Nov. 9, 2015).

Lennox, Goodman, Ingersoll Rand, and AHRI supported DOE's proposal to eliminate the term "ARM" and instead use the term "AEDM." (Lennox, No. 61 at p. 7; Goodman, No. 73 at p. 7; Ingersoll Rand, No. 65 at p. 11; AHRI, No. 70 at p. 9) There, DOE has eliminated the term "ARM" in this final rule, using only "AEDM."

3. Elimination of the Pre-Approval Requirement

In the November 2015 SNO PR, DOE proposed to eliminate the pre-approval process for ARMs for split-system central air conditioners and heat pumps. In lieu of this, DOE also proposed that manufacturers may only apply an AEDM if it (1) is derived from a mathematical model that estimates performance as measured by the applicable DOE test procedure; and (2) has been validated with individual combinations that meet current Federal energy conservation standards (as discussed in the next section). Furthermore, DOE proposed records retention requirements and additional manufacturer requirements to permit DOE to audit AEDMs through simulations, review of data and analyses, and/or certification testing. 80 FR 69278, 69294 (Nov. 9, 2015).

Lennox agreed that elimination of the pre-approval for AEDMs could reduce time to market, facilitate innovation, and eliminate the time required to complete the approval process. (Lennox, No. 61 at p. 7) In this final rule, DOE has eliminated the pre-approval requirement as proposed in the November 2015 SNO PR.

4. AEDM Validation

a. Outdoor Unit Manufacturers

In the November 2015 SNO PR, DOE noted that in its proposed revisions to the determination of certified ratings for central air conditioners and heat pumps,

manufacturers must test each basic model. Specifically for split-system air conditioners and heat pumps, OUMs must test each model of outdoor unit with at least one model of indoor unit (highest sales volume). Manufacturers would only be able to use AEDMs for other individual combinations within the same basic model—in other words, other combinations of models of indoor units with the same model of outdoor unit. In the November 2015 SNOPI, DOE did not seek to require additional testing to validate an AEDM beyond what is proposed under 10 CFR 429.16(a)(1)(ii). 80 FR 69278, 69294 (Nov. 9, 2015).

DOE also proposed in the November 2015 SNOPI to adopt test requirements similar to those used for AEDM validation for commercial HVAC and water heating equipment, as published in the AEDM final rule 78 FR 79579, 79584 (Dec. 31, 2013). Specifically, DOE proposed that (1) for energy-efficiency metrics, the predicted efficiency using the AEDM may not be more than 3 percent greater than that determined through testing; (2) for energy consumption metrics, the predicted efficiency using the AEDM may not be more than 3 percent less than that determined through testing; and (3) the predicted efficiency or consumption for each individual combination calculated using the AEDM must comply with the applicable Federal energy conservation standard. Furthermore, the test results used to validate the AEDM must meet or exceed the applicable Federal standards, and the test must have been performed in accordance with the applicable DOE test procedure. If DOE has ordered the use of an alternative test method for a particular basic model through the issuance of a waiver, that alternative test method should apply in lieu of the DOE test procedure. 80 FR 69278, 69296 (Nov. 9, 2015).

In the November 2015 SNOPI, DOE proposed a validation tolerance of 3 percent for AEDMs because the variability in a manufacturer's lab and within a basic model should be more limited than lab-to-lab variability. DOE proposed tolerances for verification testing of 5 percent to account for added lab-to-lab variability. 80 FR 69278, 69296 (Nov. 9, 2015).

ADP, Lennox, UTC/Carrier, Rheem, and Unico agreed with DOE's proposal to not require additional testing to validate an AEDM beyond the testing required under 429.16(a)(2)(ii) for split-system air conditioners and heat pumps where manufacturers must test each basic model—that is, each model of outdoor unit with at least one model of HSV indoor unit. (ADP, No. 59 at p. 7;

Lennox, No. 61 at p. 15; UTC/Carrier, No. 62 at p. 8; Rheem, No. 69 at p. 8; Unico, No. 63 at p. 6)

Unico commented that single-split systems manufactured and rated by an OUM should continue to validate their AEDM using the HSVC measured results. (Unico, No. 63 at p. 6) The California IOUs commented that it is critical that an AEDM be validated fully and in a manner that allows DOE to use lab-testing data to disallow an AEDM if it is inaccurate. (California IOUs, No. 67 at p. 4)

Lennox, JCI, AHRI, First Co., Ingersoll Rand, UTC/Carrier, Rheem, and Nortek recommended that DOE align the CAC/HP AEDM validation tolerance proposal with commercial equipment AEDM provisions of 5 percent. (Lennox, No. 61 at p. 8; JCI, No. 66 at pp. 3–4; AHRI, No. 70 at p. 9; First Co., No. 56 at p. 2; Ingersoll Rand, No. 65 at p. 11; UTC/Carrier, No. 62 at p. 8; Rheem, No. 69 at p. 2; Nortek, No. 58 at p. 5) AHRI, Lennox, JCI, and Nortek further commented that lab variability is an inherent part of the testing process regardless of whether all testing is conducted in a manufacturer's lab or lab-to-lab. They asserted that the fundamental issue is that HVAC equipment relies on accurate air property measurements (wet bulb/dew point) and the variability of the test alone is greater than five percent. (AHRI, No. 70 at p. 9; Nortek, No. 58 at p. 5; JCI, No. 66 at pp. 3–4; Lennox, No. 61 at p. 8) AHRI and Nortek also commented that it is crucial that manufacturers be permitted to apply the AEDM across basic models in order to align the CAC/HP AEDM validation tolerance with the commercial equipment AEDM provisions. (AHRI, No. 70 at p. 9; Nortek, No. 58 at p. 5)

Given the support in the comments related to AEDM validation for OUMs, DOE maintains its proposal to not require any additional testing to validate an AEDM beyond that required for certification. DOE notes that while the proposal applied to split systems only, in this final rule, it applies to single-package systems as well. After reviewing the comments, DOE has adopted a validation tolerance of 4% rather than the proposed 3%. DOE notes that manufacturers did not provide evidence of the comparison of within-lab variability to lab-to-lab variability nor did they request a higher verification tolerance, indicating that a 5% tolerance appropriately captures lab-to-lab variability. In addition, DOE notes that in its own enforcement testing, it obtains results within 3%. For these reasons, DOE believes that a validation tolerance of 4% balances the

manufacturers' concerns regarding within-lab variability with the understanding that such variability is by nature less than lab-to-lab variability and with DOE's own experience with such testing variability. In response to AHRI and Nortek's additional comment, while at least one individual model or combination within each basic model must be tested, DOE did not propose that AEDMs be specific to basic models; they can be applied across basic models.

b. Independent Coil Manufacturers

In the November 2015 SNOPI, DOE noted that in its proposed revisions to the determination of certified ratings for central air conditioners and heat pumps, ICMs must test each model of indoor unit with at least one model of outdoor unit (lowest SEER). Manufacturers would only be able to use AEDMs for other individual combinations within the same basic model. Additionally, DOE did not require additional testing to validate an AEDM beyond that proposed to be required to determine the certified ratings. 80 FR 69278, 69294 (Nov. 9, 2015). DOE also proposed the same additional test requirements for ICMs as for OUMs, as discussed in the previous section. 80 FR 69278, 69296 (Nov. 9, 2015).

Rheem commented that ICMs should validate their AEDMs in the same manner as an OUM. Rheem agreed that ICM ratings would improve when indoor units are tested with outdoor units. Rheem further commented that ICM ratings would also improve when a particular indoor coil is tested with multiple outdoor units of different capacities and that the process should properly consider what effects refrigerant mass flow variations across tonnages have on the performance of a single indoor unit. (Rheem, No. 69 at p. 8) UTC/Carrier also supported DOE's proposal and appreciates DOE for closing what it perceived as a loophole in the current regulations and requiring ICMs to test in a similar fashion to OUMs. (UTC/Carrier, No. 62 at p. 9)

On the other hand, Unico commented that DOE should replace the term "basic model" with "Similarity Group," essentially requiring AEDM validation based on the testing requirements for a Similarity Group. (Unico, No. 63 at p. 6) As discussed in section III.A.3.d, AHRI, ADP, Mortex, and Lennox recommended that, to validate an AEDM, an ICM (1) test and rate at least one combination per Similarity Group with an outdoor unit with the lowest SEER that complies with standard; (2) perform at least one full-system test per Similarity Group; (3) if rating HP combinations, test one-third of

Similarity Groups with HP systems in both heating and cooling modes; and (4) if an ICM has only one Similarity Group, the manufacturer must test a minimum of two combinations to validate the AEDM. (AHRI, No. 70 at p. 5–6; ADP, No. 59 at p. 2–3; Mortex, No. 71 at p. 4–6; Lennox, No. 61 at p. 5)

AHRI, ADP, Mortex, and Lennox suggested that for ICMs to validate an AEDM, test results should be required to be more than five percent below output from the AEDM. The commenters noted that DOE has proposed three percent on the supposition that a manufacturer's lab will have less variation, but that many ICMs do not have labs and will rely on external labs for testing and that there is no basis to suggest that the testing variation will be significantly different between testing commercial and consumer products. (AHRI, No. 70 at p. 5–6; ADP, No. 59 at p. 2–3; Mortex, No. 71 at p. 4–6; Lennox, No. 61 at p. 5)

AHRI, ADP, Mortex, and Lennox also suggested that ICMs only be permitted to rate basic models within Similarity Groups validated by a tested combination. (AHRI, No. 70 at p. 5–6; ADP, No. 59 at p. 2–3; Mortex, No. 71 at p. 4–6; Lennox, No. 61 at p. 5)

As discussed in section III.A.3.d, DOE is adopting the suggested Similarity Group requirements as the basic model definition for ICMs and is requiring testing of one combination per basic model (with the exception of heat pumps) according to the sampling plan in 429.16. With these changes, DOE believes that the testing requirements for certification remain sufficient for validating an AEDM. In addition, DOE believes that the additional requirements on test data used for validation address AHRI's concern regarding a need for additional testing for ICMs with only a single Similarity Group. Therefore DOE is not requiring ICMs to conduct any additional testing for AEDM validation beyond that required for certification.

Furthermore, after reviewing these comments, DOE has adopted a validation tolerance of four percent rather than the proposed 3 percent, for ICMs as well as OUMs.

In response to AHRI, ADP, Mortex, and Lennox, DOE notes that the request that ICMs only be permitted to rate basic models within Similarity Groups validated by a tested combination is consistent with its adopted requirements regarding use and validation of AEDMs, although in the adopted framework, manufacturers may only use AEDMs to rate individual combinations within basic models validated by a tested combination.

5. AEDM Verification Testing

DOE may randomly select and test a single unit of a basic model pursuant to 10 CFR 429.104. This authority extends to all DOE covered products, including those certified using an AEDM. In conducting enforcement testing, DOE tests a retail unit or a unit provided by the manufacturer if a retail unit is not available. 10 CFR 429.110(c). A selected unit is tested using the applicable DOE test procedure at an independent, third-party laboratory accredited to the International Organization for Standardization (ISO)/International Electrotechnical Commission (IEC), "General requirements for the competence of testing and calibration laboratories," ISO/IEC 17025:2005E. 10 CFR 429.110(a). DOE may conduct testing at an independent, third-party testing facility or a manufacturer's facility upon DOE's request if the former is not capable of testing such a unit. 10 CFR 429.110(a).

In the November 2015 SNO PR DOE explained that verification testing conducted by DOE is conducted with no communication between the lab and the manufacturer without DOE authorization. 80 FR 69278, 69296 (Nov. 9, 2015). Thus, DOE proposed a method for determining that a combination rated using an AEDM does not meet its certified rating. Specifically, DOE proposed that an individual combination would be considered as having not met its certified rating if, even after applying the five percent tolerance between the test results and the rating as specified in the proposed 10 CFR 429.70(e)(5)(vi), the test results indicate the individual combination being tested is less efficient or consumes more energy than indicated by its certified rating. DOE noted that this approach will not penalize manufacturers for applying conservative ratings to their products. That is, if the test results indicate that the individual combination being tested is *more* efficient or consumes *less* energy than indicated by its certified rating, DOE would consider that individual combination to meet its certified rating. 80 FR 69278, 69296 (Nov. 9, 2015).

In the November 2015 SNO PR, DOE also proposed providing manufacturers with a test report that includes a description of test set-up, test conditions, and test results when an individual combination rated using an AEDM fails to meet the certified rating. Under this proposal, DOE would also provide the manufacturer with an opportunity to respond to the lab report by presenting all claims regarding testing validity, and if the manufacturer

was not on-site for initial set-up, to purchase an additional unit from retail to test following the requirements in 429.110(a)(3). Under the proposed procedure, DOE would consider any response offered by the manufacturer within a designated time frame before deciding upon the validity of the test results. Only after considering the manufacturer's response and determining it to be unsatisfactory would DOE declare the manufacturer's rating for the basic model invalid and require the manufacturer to take subsequent action, as described in section III.B.6. 80 FR 69278, 69297 (Nov. 9, 2015).

AHRI and Nortek commented that DOE's proposal was unclear regarding the difference between AEDM validation testing and verification testing. (AHRI, No. 70 at p. 9; Nortek, No. 58 at p. 5) In response, DOE notes that manufacturers must conduct validation testing in order to use an AEDM to determine represented values and to certify compliance to DOE. DOE may conduct AEDM verification testing to verify the validity of an AEDM.

ADP, Lennox, UTC/Carrier, and Unico agreed with DOE's proposal that manufacturers should not be penalized for being conservative in their ratings for any of the metrics. They stated that, given the testing uncertainties, manufacturing variation, etc., manufacturers need to be conservative to ensure their product performs at the rated level. (ADP, No. 59 at p. 8; Lennox, No. 61 at p. 15; UTC/Carrier, No. 62 at p. 9; Unico, No. 63 at p. 7) Rheem also agreed with the proposal to allow conservative ratings. (Rheem, No. 69 at p. 9)

JCI and Lennox commented that there appears to be a typographical error on (5) AEDM Verification Testing. (v) Tolerance. The text shows "For efficiency metrics, the result from a DOE verification test must be greater than or equal to 1.05 multiplied by the certified rating." JCI and Lennox believe the language should read: "must be greater than or equal to 0.95 multiplied by the certified rating". (JCI, No. 66 at p. 3; Lennox, No. 61 at p. 15)

Given the agreement of the commenters, DOE finalizes its proposed five percent tolerance in verifying an AEDM's performance and allowance for manufacturers to make conservative representations in this final rule. In response to JCI and Lennox's comments, DOE acknowledges that the November 2015 SNO PR included a typographical error in the tolerances, which has been corrected in this final rule. DOE did not receive comments on other aspects of its

AEDM verification testing proposals and adopts them as proposed in the SNOPR.

6. Failure To Meet Certified Represented Values

In the November 2015 SNOPR DOE proposed that manufacturers need not re-validate the AEDM in response to the first determination of an invalid rating for models certified with that AEDM. In such cases, the manufacturer must conduct additional testing and re-rate and re-certify the individual combinations within the basic model that were improperly rated using the AEDM. 80 FR 69278, 69297 (Nov. 9, 2015).

DOE also proposed that if DOE has determined that a manufacturer made invalid ratings on individual combinations within two or more basic models rated using the manufacturer's AEDM within a 24 month period, the manufacturer must test the least efficient and most efficient combination within each basic model in addition to the combination specified in 429.16(a)(1)(ii). The twenty-four month period begins with a DOE determination that a rating is invalid through the process outlined above. If DOE has determined that a manufacturer made invalid ratings on more than four basic models rated using the manufacturer's AEDM within a 24-month period, the manufacturer may no longer use an AEDM. 80 FR 69278, 69297 (Nov. 9, 2015).

DOE also proposed additional requirements for manufacturers to regain the privilege of using an AEDM, including identifying the cause(s) for failure, taking corrective action, performing six new tests per basic model, and obtaining DOE authorization. 80 FR 69278, 69297 (Nov. 9, 2015).

DOE created its proposal under the expectation that each manufacturer will use only a single AEDM for all central air conditioner and central air conditioning heat pumps. Several stakeholders responded to DOE's question on whether manufacturers typically apply more than one AEDM, and if they do, then what the differences are between such AEDMs.

ADP commented that they use one AEDM. (ADP, No. 59 at p. 8) Unico commented that a single AEDM may incorporate several calculation methods, but that the AEDM should be designed to choose the most accurate calculation method and is still one AEDM. (Unico, No. 63 at p. 7)

Lennox commented that while the concept of an AEDM's function is the same, different AEDMs may be optimized for application, ease of use,

outputs or integration into other business processes. Lennox recommended that AEDMs not be restricted to a singular application. (Lennox, No. 61 at p. 15) UTC/Carrier suggested that multiple AEDMs could be applied for different products, such as packaged systems versus splits and variable speed versus single-stage. UTC/Carrier argued that a dedicated AEDM would more accurately reflect product performance for consumer benefit (UTC/Carrier No. 62 at p. 9) JCI commented that they would likely utilize one AEDM for split AC units, one for split HP units, and possibly one for single-package units, with a possible additional one a two stage product and another for multistage product. JCI stated the primary differences are the additional simulation conditions and required additional input. (JCI, No. 66 at p. 16) Rheem commented that manufacturers may choose to have multiple AEDMs based on design technologies to ensure rating accuracy for each technology, *i.e.*, micro-channel vs. fin and tube performance modeling. (Rheem, No. 69 at p. 9)

After reviewing the comments, DOE acknowledges that some manufacturers may have more than one AEDM but will likely have fewer than five. DOE believes that its proposal is still valid under these circumstances and has adopted it as proposed. DOE has adopted a requirement for manufacturers to provide a "name" for the AEDM used to rate each individual model or combination, although for some manufacturers it may be the same for all. If DOE finds that there is a proliferation of AEDMs and that DOE's requirements for re-validation, re-determination of represented values, and/or re-certification following the failure of a model to meet its certified represented value are no longer sufficient to ensure that represented values generated with AEDMs are reliable, DOE may revisit these requirements.

AHRI and Nortek disagreed with the proposal to invalidate an AEDM after four failures within 24 months and recommended that DOE implement an option to "save" the HSVC and remaining basic model ratings, similar to the provisions within the AHRI Certification Program. (AHRI, No. 70 at p. 9; Nortek, No. 58 at p. 6) Ingersoll Rand recommended that DOE adopt the AHRI proposal for additional testing should there be "excessive" failures of AEDM rated products. (Ingersoll Rand, No. 65 at p. 11) JCI commented that it appears that if a basic model is deemed invalid that all mix match ratings associated with that basic outdoor

model would be made invalid and be required to be recertified. JCI believes this is very punitive and does not take into account that the invalid ratings may be due to other factors. JCI also agreed with other commenters that there should be a method to "save" all of the other mix match ratings associated with that basic outdoor model. (JCI, No. 66 at p. 4)

UTC/Carrier recommended that the number of failures in 24 month period before the AEDM is invalidated should scale to the number of basic models for that particular manufacturer. (UTC/Carrier, No. 62 at p. 8)

Goodman expressed concern over the result of an initial assessment test in which the basic model being tested failed to achieve its ratings. Goodman commented that if the manufacturer is permitted to review the setup of test arrangement before the test is finished, the cause of failure could be eliminated. (Goodman, No. 73 at p. 7)

In response to AHRI, Nortek, and JCI, DOE's proposal does permit a manufacturer to "save" all represented values with minimal effort at the first failure and with additional testing at the second, third and fourth failures. If, after all of that additional testing, the AEDM is still not accurate, DOE is unsure what would be "saved". DOE notes that the tested combination of each basic model would not have been rated using the AEDM and thus would be unaffected by a failure of the AEDM. In response to Ingersoll Rand, DOE views five failures in two years as excessive, as DOE has already provided a 5% tolerance. In response to UTC/Carrier, DOE disagrees that the number of failures should scale to the number of basic models. DOE believes that if a manufacturer has five basic models that test outside of the 5% tolerance, especially following feedback from the four previous failures, that there must be a significant problem with the AEDM. In response to Goodman, DOE notes that although it has not provided an allowance for a manufacturer to review the test set up prior to testing, DOE will provide the manufacturer with documentation related to the test set up and allows the manufacturer to present claims regarding the validity. DOE believes this accomplishes the same result.

Unico commented that for ICM ratings, if a rating is invalid, if the same basic model was tested and passed, only the system tested that failed is re-rated. For an ICM, the same failure is not considered a failure of the AEDM unless the outdoor unit has been tested and shown to meet the OUM rating. Unico argued that, from an engineering view,

the calculation method should only be changed if the measured data is [in]consistent with the AEDM input. Unico also expressed the view that, since the ICM does not manufacture the outdoor unit, the ICM should not be held responsible for the OUM information. According to Unico, ICM ratings are likely to be doubly conservative if one considers that the OUM ratings are conservative and this is added to the conservative ICM rating. Unico also urged DOE to consider that the ratings are based on tests of the outdoor unit (OUM basic model testing) and of the indoor unit (ICM Similarity Group testing), asserting that this is more testing than the OUM product alone. (Unico, No. 63 at p. 4)

In response to Unico, DOE does not agree that ICMs should have different consequences for failures than OUMs. All manufacturers use AEDMs at their own risk and are responsible for ensuring the accuracy of the AEDM, including the accuracy of the testing used to validate the AEDM.

7. Action Following a Determination of Noncompliance

If an individual model or combination is determined to be noncompliant, then all other individual models or combinations within that basic model are considered noncompliant. DOE's proposal in the November 2015 SNO PR with respect to AEDMs did not include a provision that other basic models rated with the AEDM would be considered noncompliant. However, DOE noted that an AEDM must be validated using test data for individual combinations that meet the current Federal energy conservation standards. Therefore, if a noncompliant model was used for validation of an AEDM, a manufacturer must re-validate the AEDM with test data for a compliant basic model in order to continue using the AEDM. The requirements for additional testing based on invalid ratings, as discussed in the previous sections, may also apply. 80 FR 69278, 69298 (Nov. 9, 2015).

DOE notes that it did not receive comments related to this discussion in the November 2015 SNO PR.

8. AEDM for Off Mode

In the November 2015 SNO PR, DOE listed several requirements a manufacturer must meet to use an AEDM in certifying ratings, including P_{w,OFF}. 80 FR 69278, 69339 (Nov. 9, 2015).

AHRI, Ingersoll Rand, Nortek, Lennox, and JCI recommended that use of an AEDM be permitted to generate ratings for off mode power across units of similar construction. (AHRI, No. 70 at p. 9; Ingersoll Rand, No. 65 at p. 4; Nortek, No. 58 at p. 5; Lennox, No. 61 at p. 7; JCI, No. 66 at p. 9) Additionally, Lennox recommended that use of an AEDM be permitted to generate ratings for off mode power for units that use the same off mode components (Lennox, No. 61 at p. 7), while AHRI and Nortek recommended that an AEDM be permitted to be used to generate ratings across tonnages. (AHRI, No. 70 at p. 9; Nortek, No. 58 at p. 5) Rheem recommended that manufacturers be permitted to use an AEDM to generate ratings for off mode power across similar control systems that would consume the same off-mode power. Rheem also expressed the view that the AEDM should be validated based on testing of a single model with the same control system. Rheem further commented that manufacturers should be able to rate the off mode power consumption of both single-package and split systems with varying compressors, coils, and auxiliary refrigeration system components if the models are in the same basic model or have common control and motor types. (Rheem, No. 69 at p. 3, 7)

DOE agrees with stakeholders that, for units with a similar pairing of compressor, crankcase heater and common control, an AEDM is capable of providing an off mode represented value without the manufacturer needing to test each basic model. In response to the commenters' request, DOE has eliminated the requirement to test each basic model for off-mode power. Instead, at a minimum, among models with similar off-mode construction (even spanning different basic models, a manufacturer must test at least one individual model or combination for off-

mode power, and may use an AEDM for the rest. DOE notes that in all cases, the AEDM-generated represented value may be subject to verification testing, and thus the responsibility is on the manufacturer to determine which model(s) or combination(s) should be tested for off-mode as part of AEDM validation. DOE also notes that an AEDM may be used for off-mode power for multi-split, multi-circuit, and multi-head mini-split systems, even though an AEDM may not be used for the efficiency metrics.

C. Waiver Procedures

In the November 2015 SNO PR, DOE stated that a total of four waivers (and one interim waiver) for central air conditioner and heat pump products would terminate 180 days after the publication of this final rule notice in the **Federal Register**. 80 FR 69278, 69298–300 (Nov. 9, 2015). The waivers to be terminated are listed in Table III.4.

In the June 2010 NOPR, DOE proposed a test method for testing Triple-Capacity Northern Heat Pumps which would replace the waiver test procedure granted to Hallowell International (see 75 FR 6013 (Feb. 5, 2010)) for testing its line of boosted compression heat pumps. 75 FR at 31238 (June 2, 2010). The November 2015 SNO PR re-proposed the same procedure initially proposed in the June 2010 NOPR. 80 FR 69278, 69298 (Nov. 9, 2015). DOE did not receive comments regarding this test procedure and is therefore finalizing it in this final rule. The Hallowell waiver will terminate on December 5, 2016.

DOE received comments on the proposed test procedure revisions related to waivers for Multi-Zone Unitary Small Air Conditioners and Heat Pumps from ECR International (ECR) and Multi-blower Air-Conditioning and Heating Equipment from Cascade Group. Additionally, DOE has further reviewed the proposed approach for the waivers for air-to-water heat pumps granted to Daikin for their Altherma heat pumps. These waivers and associated comments are discussed in the following sub-sections.

TABLE III.4—WAIVERS TO BE TERMINATED

Scope	Decision & Order
ECR International, Inc., Multi-zone Unitary Small Air Conditioners and Heat Pumps	(Petition & Interim Waiver, 78 FR 47681, 8/6/2013).
Daikin AC (Americas), Inc., Heat Pump & Water Heater Combination	76 FR 11438, 3/2/2011.
Daikin AC (Americas), Inc., Heat Pump & Water Heater Combination	75 FR 34731, 6/18/2010.
Hallowell International, Triple-Capacity Northern Heat Pumps	75 FR 6013, 2/5/2010.
Cascade Group, LLC, Multi-blower Air-Conditioning and Heating Equipment	73 FR 50787, 8/28/2008.

1. Air-to-Water Heat Pumps and Air Conditioners

In the November 2015 SNOPR, DOE had determined that the Daikin Altherma air-to-water heat pumps with integrated domestic water heating rely exclusively on refrigerant-to-water heat exchange on the indoor side, and thus would not be required to be tested and rated for the purpose of compliance with DOE standards for central air conditioners or heat pumps. 80 FR 69278, 69298 (Nov. 9, 2015). DOE received no comment on these waivers.

DOE further considered the regulatory status of air-to-water heat pumps and notes that EPCA defines Central Air Conditioner as “a product, other than a packaged terminal air conditioner, which—(A) is powered by single phase electric current; (B) is air-cooled; (C) is rated below 65,000 Btu per hour; (D) is not contained within the same cabinet as a furnace the rated capacity of which is above 225,000 Btu per hour; and (E) is a heat pump or a cooling only unit.” (42 U.S.C. 6291(21)) The definition does not exclude products that transfer cooling or heating to a water loop on the indoor side. Hence, DOE concludes that these products are covered under regulations for CAC/HP. DOE does agree that the existing test procedures for CAC/HP do not fully address test methods for air-to-water systems. Specifically, they do not provide instructions regarding how to set up the water loop in the test, nor whether any power input associated with the water-based thermal distribution system should be incorporated into the efficiency metrics.

The Daikin waivers called for testing of the Altherma air-to-water heat pumps using European standard EN 14511 to determine EER and COP, and that these measurements are the only allowed representations of the performance of these products. (See for example 75 FR 34731, 34733 (June 18, 2010).) DOE now considers these waivers to be invalid, because they did not provide a method to determine SEER and HSPF, the metrics that must be reported to DOE to certify compliance with the applicable efficiency standards. Hence, these waivers are considered to be terminated, effective immediately. DOE will work with manufacturers of air-to-water heat pumps and air-to-water air conditioners as needed to help develop test procedures for providing SEER, HSPF, and average off-mode power represented values that may become the basis of replacement waivers.

2. Clarification of the Test Procedure Pertaining to Multi-Circuit Products

The ECR waiver for Multi-zone Unitary Small Air Conditioners and Heat Pumps concerns a split system that has one outdoor unit with multiple circuits. In the November 2015 SNOPR, DOE proposed to define such a product as a multiple-circuit (or multi-circuit) system (see Section 1.2 in Appendix M). The November 2015 SNOPR also proposed to provide a test procedure for multi-circuit products using a common duct approach for the indoor air flow measurement, similar to the approach used for multi-split units (see Section 2.4.1.b in Appendix M), thus allowing a single test for each operating condition. 80 FR 69278, 69299 (Nov. 9, 2015).

In their comments, AHRI and Nortek stated that multi-circuit products are different than multi-split systems. According to AHRI and Nortek, the outdoor unit has multiple separate circuits, each serving a separate indoor unit. They commented that multi-circuit products should be considered as multiple units whose outdoor portions are all contained within one outdoor unit cabinet. (AHRI, No. 70 at p. 18; Nortek, No. 58 at p. 14–15). AHRI and Nortek also commented that utilizing a common duct at zero static pressure with indoor sections of differing airflows will load the indoor sections unequally and may not yield the same air flows as when individually ducted. AHRI and Nortek commented that without each circuit having individual performance data collected, the test would not reflect the true performance of the system. *Id.*

Rheem stated that each circuit should be tested individually and the efficiency certified separately but did not elaborate on this comment. (Rheem, No. 69 at p. 9)

Lennox supported DOE's proposal of the common duct approach for multi-circuit products. (Lennox, No. 61 at p. 16)

DOE believes that a multi-circuit system is a single unit rather than multiple units, one for each circuit, as suggested by Rheem. All of the individual circuits within the multi-circuit system share the same outdoor coil and fan(s) and therefore are affected by the operation of the other circuits. The outdoor unit containing the multiple circuits is shipped as a single unit, not as separate units. Therefore, DOE adopts its November 2015 SNOPR proposal to require manufacturers to certify the multi-circuit system as a single system, which is consistent with the existing ECR waiver.

DOE noted in the November 2015 SNOPR that the common duct testing approach has been adopted by industry standards and is an accepted method for testing systems, such as multi-split systems, having multiple indoor units. 80 FR 69299 (Nov. 9, 2015). In fact, the indoor units of multi-split systems do not all have the same capacity or air flow rate. Hence, it is not clear why the common-duct approach is suitable for multi-split systems but would not be suitable for multi-circuit systems. In this final rule, DOE adopts the common-duct testing approach proposed in the November 2015 SNOPR for multi-circuit systems. However, considering that there might be manufacturers and/or test laboratories that wish to use the approach of the waiver, in which individual measurements are made for each indoor section, DOE has modified the provisions in section 2.4.1.b for multi-circuit systems to allow use of either the common-duct approach or separate air flow measurement for each indoor unit of the multi-circuit system. Both approaches should yield the same performance since all the indoor sections are subject to the same external static pressure.

Because DOE has adopted test procedure amendments that allow multi-circuit systems to be tested without a waiver, testing in accordance with the ECR waiver may not be used for representations after 180 days following publication of this final rule.

3. Clarification of the Test Procedure Pertaining to Multi-Blower Products

The Cascade Group waiver concerns multi-blower products. The test procedure amendments, as proposed in the June 2010 NOPR enable testing of multi-blower products. 75 FR 31237 (June 2, 2010). In the November 2015 SNOPR, DOE proposed amending Appendix M to Subpart B of 10 CFR part 430 with language in sections 3.1.4.1.1d and 3.1.4.2e to provide detailed instructions on obtaining the Cooling full-load air volume rate and cooling minimum air volume rate. 80 FR 69278, 69300 (Nov. 9, 2015).

In response to DOE's November 2015 SNOPR, Rheem stated that, if there are options for obtaining the maximum or minimum airflow configuration, the option for each with the highest energy consumption should be tested. (Rheem, No. 69 at p. 9)

DOE notes that in tests for products other than multi-blower systems, the test procedures do not require use of the most energy-consuming control setting options to achieve the specified air flow rates. Hence, DOE declines to require this approach for multi-blower

products. Therefore, DOE adopts the test approach initially proposed in the June 2010 NOPR and modified in the November 2015 SNO PR.

Because DOE has adopted test procedure amendments that allow multi-blower systems to be tested without a waiver, testing in accordance with the Cascade Group waiver may not be used for representations after 180 days following publication of this final rule.

D. Measurement of Off Mode Power Consumption

In the June 2010 NOPR, DOE proposed a first draft of testing procedures and calculations for off mode power consumption. 75 FR 31223, 31238 (June 2, 2010). In the following April 2011 SNO PR, DOE proposed a second draft, revising said testing procedures and calculations based on stakeholder-identified issues and changes to the test procedure proposals in the 2010 June NOPR and on DOE-conducted laboratory testing. 76 FR 18105, 18111 (April 1, 2011). In the October 2011 SNO PR, DOE proposed a third draft, further revising the testing procedures and calculations for off mode power consumption based primarily on stakeholder comments received during the April 2011 SNO PR comment period regarding testing burden on manufacturers. 76 FR 65616, 65618–22 (Oct. 24, 2011). In the November 2015 SNO PR, DOE proposed a fourth draft discussing and revising test settings and the calculation method in response to stakeholders' comments. 76 FR 69278, 69300–05 (Nov. 9, 2015). Based on further comments DOE received in the November 2015 SNO PR comment period, DOE is modifying its approach and is adopting the off mode test procedure.

1. Test Temperatures

In the November 2015 SNO PR, DOE proposed to require manufacturers to include the temperatures at which the crankcase heater is designed to turn on and turn off, if applicable, in their certification reports. 80 FR 69278, 69301 (Nov. 9, 2015). DOE proposed to replace the "shoulder season" off mode test (P1) at 82 °F with a test at 72±2 °F and replace the "heating season" off mode test (P2) at 57 °F with a test at a temperature which is 5±2 °F below a manufacturer-specified turn-on temperature. *Id.*

In response to the October 2011 SNO PR, the California IOUs recommended that P1 be measured at a temperature that is 3–5 °F above the manufacturer's reported "off" set point. (California IOUs, No. 33 at p. 2) DOE

requested comment on this recommendation in the December 2011 extension notice. 76 FR 79135 (Dec. 21, 2011). AHRI responded to the California IOUs' recommendation, indicating that the first test should instead be conducted at 72 °F to verify whether the crankcase heater is on, and suggesting that 72 °F is more appropriate than 82 °F because 72 °F is "the top of the shoulder season." (AHRI, No. 41 at p. 2) In response to the November 2015 SNO PR, Rheem expressed its preference for the shoulder season off mode test to be at 82±2 °F instead of 72±2 °F in order to reduce the test condition transitioning time after the B test. (Rheem, No. 69 at p. 9)

Although DOE acknowledges that there may be added test burden to reduce the temperature in the test room, DOE agrees with AHRI that 72 °F is more representative of conditions during actual use. Accordingly, today's final rule adopts the requirement that this test be conducted at 72±2 °F. There were no comments against the proposal to replace the "heating season" off mode test (P2) at 57 °F with a test at a temperature which is 5±2 °F below a manufacturer-specified turn-on temperature. Hence, DOE adopts the proposal in this final rule.

Ingersoll Rand requested an option that off mode tests be allowed to take place in a climate controlled enclosure rather than a psychrometric room. (Ingersoll Rand, No. 65 at p. 4) In considering this suggestion, DOE noticed that, although the proposed test procedure does not specify that off mode tests should be conducted in psychrometric rooms, the proposed procedure requires off mode tests be done after the B, B₁, or B₂ test, thus implying that it be conducted in a psychrometric room. DOE agrees that the off mode test results will not be affected by humidity levels. The proposal of the November 2015 SNO PR involves conducting the off mode test after the B, B₁, or B₂ test, and approaching the target 72 °F test temperature at a rate of change of no more than 20 °F per hour. 80 FR 69278, 69374 (Nov. 9, 2015). The test procedure in this final rule modifies this procedure by allowing the off mode test to be conducted in a temperature-controlled room, but to otherwise maintain the proposed requirements with regard to ambient temperature, *i.e.* starting the test when the ambient temperature is 82 °F (as required for the B, B₁, or B₂ test) and subsequently ramping down the ambient temperature as required by the proposed procedure. The final test procedure also acknowledges the initial intent to conduct the test after the B, B₁,

or B₂ test by requiring that the compressor shell temperature be at least 81 °F before starting the ambient-temperature rampdown. This requirement prevents a test lab from moving a test sample from a storage room that might be much colder than 82 °F into the test room and starting the test with a cold compressor.

Lennox suggested that DOE allow manufacturers to simply energizing the crankcase heater for non-variable type heaters to reduce the test burden, so that such units could be tested with no temperature control requirement. (Lennox, No. 61 at p. 16) In considering Lennox's comment, DOE agrees that this option could be adopted for many fixed-power-input crankcase heaters, including those without controls and those controlled by thermostats that measure ambient temperature whose sensing elements are not affected by the heater. However, DOE understands that, if the thermostat's action is affected by the crankcase heater's heat output (*i.e.* if the sensing element is close enough to the heater to be affected by the heat), the unit should be tested with a controlled ambient temperature because in such cases the ambient temperatures at which the thermostat switches the heater on and off would differ from its rated cut-in and cut-out temperatures, due to the warming effect of the heater.

Several comments recommended a third off-mode test at low temperatures. JCI recommended for air conditioners whose crankcase heaters are turned off during winter a third test at 5 °F below the winter cut-off temperature. (JCI, No. 66 at p. 16) The joint NEEA/NPCC comment requested a third test below freezing to establish the slope of a variable power crankcase heating system and to capture the energy use of electric resistance drain pan heaters which could consume considerable energy in off mode for conditions below freezing. (NEEA and NPCC, No. 64 at p. 4) The joint ACEEE/NRDC/ASAP comment made a similar recommendation (ACEEE, NRDC, ASAP, No. 72 at p. 3) As mentioned in the November 2015 SNO PR, the intent of the off mode power consumption value ($P_{w,OFF}$) is that it be a representation of the off mode power consumption for the shoulder and heating seasons, and DOE has not found that the additional accuracy gained from the additional test point merits the additional test burden, as discussed in the November 2015 SNO PR. 80 FR 69278, 69301 (Nov. 9, 2015). As DOE is required to consider test burden in its development of test procedures, DOE is not adopting a third test in this final rule.

2. Calculation and Weighting of P1 and P2

DOE proposed to give equal weighting to *P1* and *P2* for the calculation of the off mode power rating ($P_{W,OFF}$). 76 FR 65616, 65620 (Oct. 24, 2011). (See also 80 FR 69278, 69301 (Nov. 9, 2015)).

The Joint Efficiency Advocates (NEEA and NPCC) strongly urged DOE to adopt a temperature bin-weighting methodology that would include the energy contribution of drain pan heaters and suggested considering the AHRI-proposed bin method. (NEEA and NPCC, No. 64 at p. 5) The Joint Advocates of ACEEE, NRDC and ASAP also recommended the bin method due to their concern that the current averaging method would underestimate the off mode power consumed for units with variable output crankcase heaters. (ACEEE, NRDC and ASAP, No. 72 at p. 3) NEEA and NPCC also commented that with manufacturers providing turn-on and turn-off temperatures for crankcase heaters, it would be easy to construct a bin method calculation. Further, they indicated that DOE has not shown data to justify the selection of a 50–50 weighting of *P1* and *P2*. (NEEA and NPCC, No. 64 at p. 5)

DOE is aware that drain pan heaters may be used in heat pumps that have drain pans to collect defrost melt water. However, heat pumps are not considered to have off-mode hours in sub-freezing winter conditions when drain pan heaters might be required. Their energy use is captured as part of the active-mode heating tests in 17 °F ambient conditions (e.g. the H3, H3₁, and H3₂ tests) that are part of the HSPF determination. To clarify, DOE has added a new section 2.2.f to Appendix M that indicates that such heaters are energized for active-mode testing.

DOE initially proposed to adopt the 50–50 weighting of the off mode in the October 2011 SNO PR 75 FR at 65620 (Oct. 24, 2011). This decision was made in light of disagreement regarding what represents an appropriate shoulder season, concern about regional variation in shoulder season characteristics, and the fact that EPCA did not grant DOE authority to set regional off-mode standards. A 50–50 weighting of *P1* and *P2* provides a representative national estimate of off mode power input. Depending on the assumptions made regarding the shoulder season, the climate region examined, whether the product is an air conditioner or a heat pump, and the details of the crankcase heater control, the relative representativeness of *P1* and *P2* may change. In light of this variability and uncertainty, it is not clear that a bin

calculation would have more meaning than the 50–50 averaging. Therefore, DOE is adopting the 50–50 weighting as proposed.

There were additional comments concerning the calculation of *P1* and *P2* for products with variable speed compressors. Nortek, Unico, JCI, Rheem, Goodman and AHRI each provided an estimate of 70 Watts for variable speed products' crankcase heaters and commented that 70 Watts is an accurate average value. They argued that, considering that the standard single-capacity products' crankcase heaters require no more than 40 Watts, the ratio of 70 to 40, which is 1.75, should be a reasonable multiplier. (Nortek, No. 58 at p. 8; Unico, No. 63 at p. 9; JCI, No. 66 at p. 9; Rheem, No. 69 at p. 10; AHRI, No. 70 at p. 11; Goodman, No. 73 at p. 8) Lennox recommended that DOE adopt the same requirement for modulating or variable speed systems as adopted for multiple compressor systems, with a multiplier factor of 2. (Lennox, No. 61 at p. 16)

In contrast, a joint comment from NEEA and NPCC and a comment from the California IOUs disagreed with DOE's proposal to adjust the off-mode measurements for large-capacity, multiple or modulated compressors. NEEA and NPCC argued that appropriately-designed crankcase heaters for large-capacity compressors should pass the off-mode standard and that it is unnecessary to have a multiplier. (NEEA and NPCC, No. 64 at p. 5) The California IOUs commented that off mode power consumption should be on a per-system basis rather than per-compressor. (California IOUs, No. 67 at p. 2–4)

Based on these comments, DOE is adopting 1.75 as the multiplier for modulated compressors (including variable-speed compressors). DOE adopts as the effective multiplier for a compressor system consisting of multiple single-stage compressors a value equal to the number of single-stage compressors. As addressed in the November 2015 SNO PR, DOE believes that large-capacity and multiple-compressor systems require higher wattage crankcase heaters because they are likely to have larger surface area and more thermal mass, including more lubricant. Also, manufacturers have been using higher-wattage crankcase heaters for modulating compressors to address the higher perceived risk associated with oil frothing on restart for these compressors, due to their higher controls complexity. DOE does not have sufficient evidence that larger-capacity, multiple-, or modulating compressor systems can operate safely

with the same levels of crankcase heating and hence retains the multiplier for these compressors in the off-mode test. DOE agrees that modulated compressors (including variable speed products) require more crankcase heater power, and selected the 1.75 factor on this basis (this is equal to the typical 70W mentioned above for variable-speed compressors divided by the typical 40W power draw for typical single-stage compressor crankcase heaters).

Although not indicated clearly in the comments, DOE understands “modulated” in the comments to refer to any compressor that is not single-capacity. DOE clarifies in this final rule that the 1.75 multiplier applies to the number of compressors that are not single-stage, including two-stage compressors and variable speed compressors. This is less than a factor of 2, which would be the effective adjustment for a two-compressor system, but there is insufficient data showing variable speed products should have the same requirement as multiple compressor systems.

3. Time Delay Credit and Removal of Calculations for Off Mode Energy Consumption and Annual Performance Factor

In the November 2015 SNO PR, DOE proposed to adopt, for crankcase heaters that incorporate a time delay before turning on, a credit that would be proportional to the duration of the delay, as implemented in the calculation of the off mode energy consumption. (The original proposed calculation method for $P_{W,OFF}$ did not include any adjustment associated with the time delay). DOE also proposed, for products in which a time delay relay is installed but the duration of the delay is not specified in the manufacturer's installation instructions shipped with the product or in the certification report, a default period of non-operation of 15 minutes out of every hour, resulting in a 25% savings in shoulder-season off mode energy consumption. DOE notes that the impact on crankcase heater energy use was extended in the proposal to the entire off-mode energy consumption because, for an air conditioner or heat pump with a crankcase heater, most of the off mode energy use is associated with the heater. To reduce potential instances of the misuse of this incentive, DOE also proposed requiring manufacturers to include in certification reports the duration of the crankcase heater time delay for both the shoulder and heating seasons. 80 FR 69278, 69303–04 (Nov. 9, 2015).

DOE received a joint comment from NEEA and NPCC that stated, among other things, that the impact of a time delay in a system is difficult to measure accurately. NEEA and NPCC also expressed the opinion that sometimes the time delay behavior is an artifact of temperature control, because it takes a certain time for the compressor to cool after a run cycle. (NEEA and NPCC, No. 64 at p. 6) The California IOUs recommended care be taken in adopting such a credit, and requested that it be vetted appropriately before being implemented. (California IOUs, No. 67 at p. 5)

Upon further review of the function of the time delay relay and its potential impact on off mode power consumption, DOE concludes that the proposed credit is not consistent with the intent of its off mode definition. A definition for off mode was initially proposed in the July 2010 NOPR. For air conditioners, it was proposed to include, "all times during the non-cooling season of an air conditioner. This mode includes the 'shoulder seasons' between the cooling and heating seasons when the unit provides no cooling to the building and the entire heating season, when the unit is idle." 75 FR at 31249 (June 2, 2010). The definition for off mode season in today's notice is not identical but has essentially the same meaning, for example for an air conditioner, referring to both the shoulder season and the heating season. The shoulder season is defined as the period between the months of the year that require heating or cooling. The off mode season lasts months. Hence, the impact of a crankcase heater time delay of a fraction of an hour, as is typical for such relays, would insignificantly reduce average crankcase heater on-time or energy use.

The time delay credit was proposed in the November 2015 SNOPR to apply only to the off mode energy use calculation, and to the annual performance factor, APF, but not to the off-mode metric $P_{W,OFF}$. DOE does not currently have, and has not proposed to establish, standards or reporting requirements for off mode energy use or annual performance factor, nor are these parameters needed for representations, such as for product labeling. Hence, DOE is not adopting in Appendix M the proposed provisions for calculating off mode energy use, as well as the proposed time delay credit, and has removed the provisions for calculating annual performance factor.

4. Impacts on Product Reliability

Addressing concerns from stakeholders, in the November 2015

SNOPR, DOE stated that it expected that the proposed off mode test method would allow manufacturers to meet the June 2011 off mode standards without compromising the reliability of central air conditioners and heat pumps. DOE requested comments on the issue of compressor reliability as it relates to crankcase heater operation. 80 FR 69278, 69304 (Nov. 9, 2015).

Lennox, JCI, and Rheem expressed concerns that regulating crankcase heater power will have a negative impact on products. (Lennox, No. 61 at p. 17; JCI, No. 66 at p. 17; Rheem, No. 69 at p. 11) NEEA/NPCC strongly agreed with DOE that manufacturers will be able to meet off mode power consumption standards without adverse impact on product reliability. (NEEA/NPCC, No. 64 at p. 7) UTC/Carrier and the California IOUs suggested that DOE should seek comments or obtain information on research conducted by compressor manufacturers or independent entities. (UTC/Carrier, No. 62 at p. 12; California IOUs, No. 67 at p. 5) However, no party provided any data indicating that the proposal would have such an impact. Also, DOE has modified many of the details of the test procedure as requested by stakeholders to address concerns, for example, adjusting the measurement of $P_{W,OFF}$ for modulating- or multiple-compressor systems for consistency with their typically higher crankcase heater wattages. In this final rule, DOE has modified the proposed off mode test procedure consistent with information, provided by stakeholders, that might affect crankcase heater performance as measured by the test procedure such that application of the off mode standard using the final test procedure should have minimal impact on the reliability of CAC/HP systems.

5. Off Mode Power Consumption for Intelligent Compressor Heat Control

In a general response to the off mode test procedure proposed in the November 2015 SNOPR, Ingersoll Rand commented that the proposed off mode test procedure cannot accurately reflect off mode energy consumption for their intelligent crankcase heater control, which cycles the heater to provide the appropriate average heat input. They requested that they be allowed to use an alternative test method for measurement of the heating season off-mode power consumption, P2, for products with this feature. The requested alternative test suggested by Ingersoll Rand would consist of a test period for measurement of input power that includes three complete crankcase heater cycles, or 18 hours, whichever is shorter, rather than

the 5-minute test period of the proposed test. Ingersoll Rand provided test data showing typical operation of the crankcase heater. (Ingersoll Rand, No. 65 at p. 14–23) DOE carefully reviewed Ingersoll Rand's data and agrees that longer tests are needed for heaters whose controls cycle or vary crankcase heater power over time. Rather than authorizing an alternative method specific to Ingersoll Rand, the final rule adopts an additional provision in the measurement of heating season off mode power consumption (P2), using the approach suggested by Ingersoll Rand for such controls: three complete heater cycles or 18 hours, whichever is shorter. The final rule also requires that this approach be used for measuring the shoulder season off-mode power consumption, P1, if the heater is energized and cycles or varies input power for that measurement.

6. Off Mode Test Voltage for Dual-Voltage Units

In its comments on the off mode test procedure proposal of the November 2015 SNOPR, Ingersoll Rand stated that the proposal did not specify how to test units with a dual voltage rating. They further recommended that for such systems, the higher voltage should be the test voltage for off mode tests. (Ingersoll Rand, No. 65 at p. 4). They also commented that the same tolerances be adopted as are used for performance testing. DOE notes that the current test procedure incorporates by reference section 6.1.3.2 of AHRI 210/240–2008, which provides requirements for setting voltage for testing products with dual nameplate voltages. The standard requires that 230 V be used for 208–230 V dual-voltage units and that testing for all other dual nameplate voltage units be conducted at either the lower of the two voltages or at both voltages. Ingersoll Rand did not provide explanations supporting their suggestion to instead use the higher voltage (Ingersoll Rand, No. 65 at p. 4), and DOE sees no reason to depart from these established requirements for off-mode testing. DOE agrees with the need to specify tolerances, which are discussed in the next section.

7. Off Mode Test Tolerance

DOE recognized that the November 2015 SNOPR did not address all relevant test tolerances for the off mode power consumption test. DOE proposed tolerances for outdoor temperatures in the November 2015 SNOPR, but did not clarify whether test tolerances for power supply voltage for off mode testing should be different than for active mode testing. DOE adopts in this final rule the

same test tolerances used for active mode testing (see, for example, Table 7 in section 3.3 of Appendix M). These tolerances are 2.0 percent as the test operating tolerance and 1.5 percent as the test condition tolerance, both as a percentage of measured voltage.

8. Organization of Off Mode Test Procedure

In addition to revising the proposed off-mode test procedure in response to stakeholder comments, as discussed in previous sections, DOE also modifies the proposed off mode test procedure in this final rule. These modifications do not affect the measurement but should help to ensure consistency between tests conducted in different labs.

First, DOE has provided greater detail regarding test sample set-up and connection of power measurement devices for off-mode testing. This includes provisions for providing power to the control circuit for all kinds of units and specifically addresses the options when testing coil-only units for which a furnace or a modular blower is the designated air mover. (See section 3.13.1.a of Appendix M as finalized in this notice.)

Second, the test procedure now provides greater specification regarding which power inputs are to be included as part of the low voltage power P_x . (See, for example, section 3.13.1.d of Appendix M as finalized.)

Third, the test procedure indicates that for units with time delay relays, the measurement is to be made after the time delay has elapsed.

In addition, DOE notes that in the calculation of off-mode seasonal power consumption in section 4.3, P_2 should never equal to zero. As described in the November 2015 SNOPR, DOE intended that the off mode power rating $P_{W,OFF}$ be equal to the arithmetic mean of P_1 and P_2 , without discussion of any special cases in which P_2 is equal to zero. 80 FR at 69301 (Nov. 9, 2015). The provisions for calculating $P_{W,OFF}$ for cases in which P_2 is equal to zero should not have appeared in the Appendix M regulatory language presented in the notice. Hence this notice shows the intended calculation, that $P_{W,OFF}$ be equal to the average of P_1 and P_2 .

9. Certification

In the November 2015 SNOPR, DOE proposed that manufacturers report off-mode power in their certification reports. 80 FR 69278, 69291 (Nov. 9, 2015). In response, AHRI and Rheem suggested that the off mode ratings should be reported as pass/fail with a 5% tolerance. AHRI did not explicitly

clarify what they meant by a 5% tolerance, but DOE assumes this means that the model would rate as “pass” even if the measured value (or the average of the values measured for the sample of units) is as much as 5% greater than the standard. AHRI stated that first, it is difficult to accurately measure the power consumption because of the inaccuracies in common measurement devices, and second, because consumers do not compare products using this metric, manufacturers have no incentive to report it. (AHRI No. 70 at p. 11; Rheem No. 69 at p. 3)

DOE requires that manufacturers report the value of all regulated efficiency metrics rather than simply an indication of whether units pass or fail the energy conservation standard. If a manufacturer does not wish to reveal how much lower than the off-mode power consumption standard a model performs, it has the option to rate at the standard level as long as the represented value is consistent with the measurements, sampling plan and represented value requirements in 10 CFR 429. Accordingly, DOE maintains the requirement to report the actual value for off-mode power.

DOE also proposed to require manufacturers to include in the certification reports the temperatures at which the crankcase heater is designed to turn on and turn off for the heating season, if applicable. 80 FR 69278, 69301 (Nov. 9, 2015).

After finalization of the off mode test procedure based on stakeholder comments, DOE recognized that the only product-specific temperature needed to be known to properly conduct the test is the turn-on temperature (*i.e.* the cut-in temperature). This is the temperature below which the thermostat would energize the heater. The heating season off-mode power is measured at an ambient temperature 5 +/- 2 °F below this turn-on temperature. The temperature at which the crankcase heater of an air conditioner is designed to turn off for the heating season (*i.e.* below which the heater would no longer be energized) will not be needed to conduct the tests. This is because the test procedure as finalized does not call for a test at a temperature near this lower turn off temperature. Hence DOE is requiring reporting only of the temperature at which the crankcase heater is designed to turn on.

10. Compliance Dates

Rheem, Nortek, Goodman and JCI expressed concern with complying with the off mode power rating within 180 days of publication of the final test

procedure. (Rheem, No. 69 at p. 3; Nortek, No. 58 at p. 7; Goodman, No. 73 at p. 20; JCI, No. 66 at p. 9) JCI commented that at least one test year is needed to complete the work to comply. (JCI, No. 66 at p. 9) JCI further suggested that they would agree with requiring the off mode test for any new basic model starting 180 days after the publication of final rule, but that all existing basic models should be granted an extended period of 5 years for compliance. (JCI, No. 66 at p. 9) Nortek commented that manufacturers should have at least two years to comply with this change, otherwise DOE must explicitly permit all existing products to be grandfathered in until the new energy conservation standard goes into effect. (Nortek, No. 58 at p. 7) Goodman commented that manufacturers are statutorily provided with five years to comply with energy conservation standards, which DOE has reduced to less than six months. Goodman requested that DOE provide at least half of the required statutory time (two-and-a-half years) to comply with the off-mode standard compliance and certification requirements. Goodman noted that DOE could not presently assert civil penalties for off-mode because there is no final method of test. (Goodman, No. 73 at p. 20–21)

DOE understands that the stakeholders' concern with the compliance date is due to the test burden related to measuring off mode power consumption. In this final rule, DOE has considerably reduced the test burden in the following aspects: (a) manufacturers do not need to test each basic model for off mode power consumption and instead are allowed to use an AEDM for off mode with certain requirements (discussed in section III.B.8); (b) all units are allowed to be tested for off mode power consumption in a temperature-controlled room rather than a psychrometric room; and (c) for units having a compressor crankcase heater whose power consumption can be determined without ambient condition requirements (*e.g.* the heater's wattage when energized does not vary with ambient temperature), manufacturers do not need to use temperature-controlled test facilities.

With the test procedure allowances stated above, DOE believes that the off mode test burden has been reduced significantly and manufacturers should be able to provide the off mode power represented values within 180 days as required by statute.

E. Test Repeatability Improvement and Test Burden Reduction

42 U.S.C. 6293(b)(3) states that any test procedure prescribed or amended

shall be reasonably designed to produce test results which measure energy efficiency and energy use of a covered product during a representative average period of use and shall not be unduly burdensome to conduct. This section discusses clarifications to improve test procedure repeatability and to reduce test burden. None of the clarifications listed in this section would alter the average measured energy consumption of a representative set of models.

1. Indoor Fan Speed Settings for Blower Coil or Single-Package Systems

Indoor unit fan speed is typically adjustable to assure that the required air volume rate is provided for the range of field-installed ductwork systems that the unit might use for air distribution. The DOE test procedure has specific requirements for fan speed adjustment, external static pressure, and air volume rate during the test. For a ducted blower coil system, DOE's test procedure requires that (a) external static pressure be no less than a minimum value that depends on cooling capacity⁹ and product class, ranging from 1.10 to 1.20 inches of water column (in. wc.) for small-duct, high-velocity systems and from 0.10 to 0.20 in. wc. for all other systems except non-ducted (see 10 CFR part 430, subpart B, Appendix M, Table 2); and that (b) the air volume rate divided by the total cooling capacity not exceed a maximum value of 37.5 cubic feet per minute of standard air (scfm) per 1000 Btu/h of cooling capacity¹⁰ (see 10 CFR part 430, subpart B, Appendix M, Section 3.1.4.1.1). In the November 2015 SNOPR, DOE proposed that blower coil products be tested using the lowest speed setting that satisfies the minimum static pressure and the maximum air volume rate requirements, if applicable, if more than one of these settings satisfies both requirements. This clarification was proposed to be added to section 2.3.1.a of Appendix M. 80 FR 69278, 69305 (Nov. 9, 2015).

Rheem agreed that the most logical and energy efficient method to set up an indoor fan on a central air conditioner or heat pump system is to set the indoor blower to the lowest fan setting that meets all of the air volume rate requirements. Rheem also agreed that lab to lab repeatability will improve with this requirement. (Rheem, No. 69 at p. 11)

JCI expressed concern that testing above the rated airflow would be permitted (JCI, No. 66 at p. 11).

However, JCI expressed agreement with the proposal provided DOE establishes a tolerance relative to the rated airflow before adjusting speed settings (JCI, No. 66 at p. 17). In response to JCI, DOE did not intend to imply that the tested airflow is allowed to exceed the rated airflow. In this final rule, DOE has clarified this in sections 2.3.1.a and 2.3.2.a of the regulatory text by referencing section 3.1.4 for information on air volume rate control settings. Section 3.1.4 outlines a procedure in which the air volume rate is always set to the rated value or reduced to meet the static pressure requirement.

Further, DOE notes that in the current test procedure (section 3.1.4 of Appendix M) the air flow may be adjusted downwards from the rated air flow by up to 5 percent to meet the static pressure requirement before adjusting speed settings (*i.e.*, if the ESP is lower than required when running at the rated air flow, the code tester fan can be adjusted to increase ESP and decrease airflow, without increasing the fan speed setting, until airflow is 95 percent of rated airflow). The June 2010 NOPR proposed increasing this tolerance such that switching to a higher speed setting would be required when the air volume rate drops below 90 percent of the rated air volume rate without meeting the external static pressure requirement—a 10 percent tolerance below rated. 75 FR at 31234 (June 2, 2010).

NEEA commented that they do not support widening the gap between rated performance in the lab and actual performance in the field. NEEA requested that DOE research the adequacy of the 5 percent tolerance with an ESP testing minimum of 0.5 in. w.c. (NEEA, No. 7 at pp. 3–4). DOE does not believe that the air volume rate measurement in the field is very precise, if it is measured directly at all when systems are installed. This is because the apparatus used to measure air flow with this precision in the laboratory is very bulky and is not used for field installations. Hence, the increase from 5 to 10 percent tolerance would not increase the gap between field and laboratory operation. DOE adopts the tolerance as proposed.

DOE identified potential sources of confusion in section 3.1.4 and has improved the language for setting the air volume rate of ducted blower coil systems that use blower motors other than constant-air-volume-rate indoor blower motors. These changes do not alter the test method but rather provide clearer instructions for adjusting the indoor fan and the test apparatus

settings to set the air volume rate in accordance with the test procedure.

Improper fan speeds implemented during testing may have a marked impact on product performance, and inconsistent implementation of speed settings and adjustments may be detrimental to test repeatability. DOE therefore proposed that manufacturers could include in their certification report a certified air volume rate and certified instructions for setting fan speed or controls to achieve that air volume rate. 80 FR 69278, 69305 (Nov. 9, 2015). The requirement has been adopted by DOE in the final rule. As part of the section 3.1.4 changes, DOE added instructions for testing if there is no certified air volume rate. Additionally, absent fan speed instructions for installation, DOE added instructions to use the as-shipped settings.

DOE also adds specificity on which test conditions to use for determining air volume rates. For instance, the A (for single-stage units) or A₂ test is specified for determining the cooling full-load air volume rate. Another modification places the 37.5 cubic feet per minute of standard air (scfm) per 1,000 Btu/h of capacity check as a last step in the process, after both the air volume rate and external static pressure requirements are met.

AHRI asked DOE to provide information on how the airflow 450 scfm per ton ceiling was derived and why it is still relevant. (AHRI, No. 70 at p. 13) DOE notes that the 450 scfm/ton ceiling is identical to the 37.5 scfm per 1,000 Btu/h maximum air flow requirement that is in the CAC/HP test procedure. This requirement has been in the DOE test procedure since it was initially established. On January 11, 2001, DOE published a NOPR in which it discussed whether this upper limit on air flow should remain in the test procedure, expressed interest in further discussion to resolve the question, but proposed not to change the limit. 66 FR 6774. The final rule completing that rulemaking did not again discuss the issue. 70 FR 59122 (Oct. 11, 2005).

DOE agrees with AHRI that the limit is not needed for blower coil systems. Increased air flow can improve heat transfer from the indoor coil. However, higher air flow for blower coil systems is at the expense of considerable fan power, which both reduces cooling capacity and increases system power. There is an optimum air flow for which efficiency would be maximized, typically near 400 scfm per ton, but it is different for each system. In a blower coil system test, the added fan power required to move additional air is

⁹ Or heating capacity for heating-only heat pumps.

¹⁰ Such a requirement does not exist for heating-only heat pumps.

incorporated in the measurement. Hence, a manufacturer would not have incentive to increase rated airflow unreasonably. On the other hand, not setting an upper bound on air flow in the test procedure gives manufacturers more design flexibility. For these reasons, DOE has removed the 450 scfm per ton requirement for blower coil systems in this final rule notice. DOE does, however, expect that certified airflow rates will be consistent with installation instructions, since ultimately the test procedure is intended to reflect field performance.

For consistency with the furnace fan test procedure, DOE proposed to add to Appendix M the definition for “airflow-control setting” that has been adopted in Appendix AA to refer to control settings used to obtain fan motor operation for specific functions. 80 FR 69278, 69305 (Nov. 9, 2015). DOE did not receive comments on this proposal and is retaining it as proposed.

2. Air Volume Rate Adjustment for Coil-Only Systems

In the current DOE test procedure, for a coil-only system, the pressure drop across the indoor unit must not exceed 0.3 inches of water for the A test (or A₂ test for two-capacity or variable-capacity systems), and the maximum air volume rate per capacity must not exceed 37.5 cubic feet per minute of standard air (scfm) per 1000 Btu/h. (10 CFR part 430, subpart B, Appendix M, Section 3.1.4.1.1) For such systems, higher air volume rates enhance the heat transfer rate of the indoor coil, and therefore may maximize the measured system capacity and efficiency. In addition, the energy use and heat input attributed to the fan energy for such products is a fixed default value in the test procedure, and is set at 365 W per 1,000 scfm (see, for example, 10 CFR part 430, subpart B, Appendix M, Section 3.3(d)). Thus, the impact from fan power on the efficiency measurement if air volume rate is increased may be more modest than for a blower coil unit, for which fan input power would increase more rapidly due to the increase of internal pressure drop as well as air volume rate. To prevent rating based on excessive air volume rates, a maximum pressure drop of 0.3 in. wc. is specified for the indoor coil assembly. To minimize potential testing variability due to the use of different air volume rates, in the November 2015 SNOPR, DOE proposed to require for coil-only systems for which the maximum air flow (37.5 scfm/1,000 Btu/h) or maximum pressure drop (0.3 in wc) are exceeded when using the specified air flow rate, that the air flow rate must be reduced so that

both are satisfied. This is specified in section 3.1.4.1.1.c of Appendix M as proposed. 80 FR 69278, 69305 (Nov. 9, 2015). DOE did not receive comments on this proposal other than the AHRI comment regarding the 450 scfm per ton upper limit on air flow discussed above. DOE believes that the 0.3 in wc coil pressure drop maximum provides a limit on airflow that is comparable, *i.e.* exceeding the 450 scfm per ton limit would generally involve also exceeding the 0.3 in wc limit. Hence, DOE sees little need to maintain the 450 scfm per ton limit only for coil-only systems and, consistent with the approach discussed above for blower coil systems, has removed this limit for coil-only systems.

3. Requirements for the Refrigerant Lines and Mass Flow Meter

Section 2.2(a) of 10 CFR part 430, subpart B, Appendix M provides instructions for insulating the “low-pressure” line(s) of a split system. In the cooling mode, the vapor refrigerant line connecting the indoor and outdoor units operates at low refrigerant pressure. However, in the heating mode, it operates at high pressure. To improve clarity and ensure that the language of the test procedure refers specifically to the actual functions of the refrigerant lines, DOE proposed in the November 2015 SNOPR to refer to the lines as “vapor refrigerant line” and “liquid refrigerant line”. 80 FR 69278, 69306 (Nov. 9, 2015).

Because DOE seeks to minimize test variability associated with the use of insulation, the November 2015 SNOPR included a proposal for determining the insulation requirement for the test based on the materials and information shipped with the test unit. Under this proposal, test laboratories would install the insulation shipped with the unit. If the unit is not shipped with insulation, the test laboratory would install the insulation specified in the installation manuals shipped with the unit. If instructions for refrigerant line insulation are not provided, liquid line insulation would be used only for heating-only heat pumps. These proposed requirements were intended to reduce test burden and improve test repeatability. 80 FR 69278, 69306 (Nov. 9, 2015).

Additionally, DOE proposed to add requirements to Appendix M, section 2.10.3 to require use of a thermal barrier to prevent thermal transfers between the flow meter and the test chamber floor if the meter is not mounted on a pedestal or other support elevating it at least two feet from the floor. 80 FR 69278, 69306 (Nov. 9, 2015).

DOE requested comment on these proposals. Many stakeholders agreed with the proposals. (NEEA and NPCC, No. 64 at p.8; ADP, No. 59 at p.9; UTC/Carrier, No. 62 at p. 13; Rheem, No. 69 at p. 11) DOE did not receive any comments opposing these proposals. Therefore, in this final rule, DOE adopts these proposals and adds a specification that insulation should remain the same for heating mode and cooling mode.

4. Outdoor Room Temperature Variation

The current DOE test procedure requires that a portion of the air approaching the outdoor unit’s coil is sampled using an air sampling device, often called an air sampling tree. (See Appendix M, section 2.5). To ensure that the measured temperature accurately represents the average temperature approaching the coil even if there might be variation in the outdoor room conditions, the November 2015 SNOPR proposed to require demonstration of air temperature uniformity over all of the air-inlet surfaces of the outdoor unit using thermocouples, if sampling tree air collection is not performed on all inlet-air faces of the outdoor unit. Specifically, DOE proposed requiring that the thermocouples be evenly distributed over the inlet air surfaces such that there is one thermocouple measurement representing each square foot of air-inlet area. The maximum temperature spread to demonstrate uniformity, *i.e.*, the maximum allowable difference in temperature between the measurements at the warmest location and at the coolest location, would be 1.5 °F. If this value is exceeded, DOE proposed that sampling tree collection of air would be required from all air-inlet surfaces of the outdoor unit. DOE proposed in the November 2015 SNOPR to add these requirements to Appendix M, section 2.11.b. 80 FR 69278, 69306–07 (Nov. 9, 2015).

In its comments on the November 2015 SNOPR, Rheem agreed with DOE’s proposal. (Rheem, No. 69 at p. 12) UTC/Carrier also supported this proposal, indicating that although it will be challenging for testing facilities, it should reduce testing uncertainty. (UTC/Carrier, No. 62 at p. 14). DOE recognizes that some of these proposed requirements could represent challenges, since they involve both addition of instrumentation and could require adjustment of outdoor room air circulation patterns in order to assure that the maximum temperature difference is not exceeded.

Some stakeholders indicated that aspects of the proposal were not clear. JCI and AHRI commented that the

proposal did not specify if the 1.5 °F maximum range for the observed temperatures measured by the thermocouples applies to time averages or instantaneous measurements made at any time during the test period, with AHRI adding that the tolerance should apply to the time-average measurements. (JCI, No. 66 at p.18; AHRI, No. 70 at p. 13; ADP, No. 59 at p. 10; Lennox, No. 61 at p. 17). JCI, AHRI, ADP, and Lennox commented that the regulatory text portion of the notice requires that the thermocouple grid be used to verify temperature uniformity whether or not air samplers are used on all air inlet faces of the outdoor unit, while the preamble discussion (section III.E.3 of the notice) indicates that the thermocouple grid is not needed if air samplers are used on all air inlet faces—the commenters questioned the requirement for use of the thermocouple grid if air samplers are used on all faces. (JCI, No. 66 at p.18; AHRI, No. 70 at p. 13; ADP, No. 59 at p. 10; Lennox, No. 61 at p. 17). In response, DOE notes that DOE intended that the tolerance apply to the average temperatures measured during the test period and that the thermocouple grid be waived if the air samplers are used on all air inlet faces. DOE revised Appendix M for consistency with the intent of the proposal. DOE notes that time variation of the air inlet temperature is already addressed by the test operating tolerance requirement of ANSI/ASHRAE 37–2009.

JCI and Ingersoll Rand suggested increasing the allowed variation between thermocouples on the thermocouple grid or sampler to 2.5F. (JCI, No. 66 at p.11; Ingersoll Rand, No. 65 at p. 5) In response, DOE notes that the proposal was somewhat lenient in allowing only one inlet air face to be measured with an air sampler if the temperature uniformity requirement is met. If, for example, the outdoor unit has four air inlet faces and the face with an air sampler is measuring high just within the allowed tolerance, while all the others are reading low, the actual average outdoor air condition would be up to 1.9 °F lower than measured by the air sampler if the maximum allowed tolerance were 2.5 °F.¹¹ Hence DOE is reluctant to allow significant departure from the proposed 1.5 °F tolerance. However, DOE has increased the tolerance to 2.0 °F, noting that the accuracy of thermocouples is at best

nearly +/- 1 °F without careful calibration, thus making imposition of a 1.5 °F maximum range impractical.

JCI commented that they have had excellent experience with regard to the balance of entering air when using a 3-sided air sampler for products with 4 inlet air surfaces. (JCI, No. 66 at p.17) However, the comment did not provide DOE details to clarify what this means in terms of air temperature uniformity and how they determined that the 3-sided approach is sufficient. For example, if testing using four air samplers with separate measurements has always shown that any three of the air samplers provides an average temperature that is negligibly different than the full four-air-sampler average, such results would indicate strongly that the fourth air sampler was not necessary. DOE may consider such information and potential revision of the temperature uniformity requirements in a future rulemaking if such data can be provided.

AHRI and JCI commented that the requirement to provide thermocouples for every square foot of outdoor coil surface would increase test burden, potentially requiring use of up to 40 thermocouples for larger units. (AHRI, No. 70 at pp. 12–13; JCI, No. 66 at p.11). DOE notes that the thermocouples are not required if all air-inlet faces of the outdoor unit are measured using air samplers. DOE also notes that the 2015 draft version of AHRI Standard 210/240 calls for use of 16 thermocouples per air sampler. If using four air samplers, this adds up to 64 thermocouples. DOE has modified the requirement so that the thermocouple density would be 16 per face or one per square foot of inlet area, whichever is less. However, as noted before, the thermocouples are not required if air samplers are used on all air inlet faces.

Ingersoll Rand commented that DOE should specify the location of the thermocouples, indicating that poor choice of location could, contrary to ASHRAE 37 requirements, lead to the thermocouple grid blocking the natural recirculation of condenser discharge air to the air inlet that may be inherent to the product design. The comment recommended that the thermocouples be mounted on an air sampler. Ingersoll Rand also recommended adding a specification to correlate the average thermocouple reading to the dry bulb temperature measurement of the sampled air, similar to the requirements of the thermopile used on the indoor side. (Ingersoll Rand, No. 65 at p. 5) In response, DOE notes that thermocouple requirement applies only if all air inlet faces of the outdoor unit are not

measured using air samplers. DOE has modified the test procedure language to indicate that natural recirculation of discharge air back to the air inlet should be avoided when mounting the thermocouples, and that they should be located 6 to 24 inches from the air inlet face. Certainly any thermocouple that blocks discharge air flow will register a high measurement that is outside of the specified tolerance. Regarding the correlation of thermocouple measurements with the air sampler dry bulb temperature measurement, DOE has not adopted this recommendation because it is not clear what its purpose would be. For the indoor side, such correlation helps to calibrate the thermocouple grid measurement for the cyclic test, but the outdoor air inlet temperature measurements are not used in a similar way for any of part of the tests. DOE adopts the amendments as proposed except for the changes discussed in this section, including (a) adopting 16 as the maximum number of thermocouples per inlet face, (b) increasing the maximum temperature range from 1.5 °F to 2.0 °F, (c) clarifying that the maximum range applies to the average measurements for the test period, and (d) clarifying that the thermocouples should not interfere with condenser discharge air flow.

5. Method of Measuring Inlet Air Temperature on the Outdoor Side

The average dry bulb temperature of air approaching the air inlet faces of the outdoor unit can be measured using air samplers or using thermocouple grids. To improve test repeatability, in the November 2015 SNO PR, DOE sought to ensure that temperature measurements taken during the test are as accurate as possible. DOE proposed that the air sampler dry bulb measurement (rather than the thermocouple grids) be the basis of comparison with the outdoor air dry bulb temperature requirement for the test. 80 FR 69278, 69307 (Nov. 9, 2015).

Rheem and ADP agreed with DOE's proposal in the November 2015 SNO PR. (Rheem, No. 69 at p. 12; ADP, No. 59 at p. 10) There were no comments against the proposal. Hence, DOE adopts the proposal in this final test rule.

6. Requirements for the Air Sampling Device

In the November 2015 SNO PR, DOE proposed to require that no part of the room air sampling device or the means of air conveyance to the dry bulb temperature sensor be within two inches of the test chamber floor. DOE also proposed to require those surfaces of the air sampling device and the

¹¹ For example, if the air approaching the air-sampled face were 95 °F while the air approaching the other faces were 92.5 °F, the actual average inlet air temperature would be 93.1 °F, nearly 2 °F lower than the temperature measured by the air sampler.

means of air conveyance that are not in contact with the indoor and outdoor room air be insulated. 80 FR 69278, 69307 (Nov. 9, 2015).

DOE also proposed to require that humidity measurements and dry bulb temperature measurements used to determine the moisture content of air be made at the same location in the air sampling device. As discussed in section III.E.14, DOE also proposed several amendments to air sampling procedures that are included in a draft revision of AHRI 210/240. 80 FR 69278, 69307 (Nov. 9, 2015).

Many stakeholders supported these proposals. (JCI, No. 66 at p.18; ADP, No. 59 at p. 10; UTC/Carrier, No. 62 at p. 14; Unico, No. 63 at p. 9; Rheem, No. 69 at p. 12). There were no comments against the proposals. Therefore, DOE adopts the proposals.

7. Variation in Maximum Compressor Speed With Outdoor Temperature

In the November 2015 SNOPR, DOE proposed that the maximum compressor speed be defined for the test procedure as the absolute maximum speed at which the compressor operates, allowing for a different maximum for heating mode as opposed to cooling mode. One implication of this proposal is that the maximum speed cannot be different for different cooling mode test conditions, and likewise it cannot be different for different heating mode test conditions. 80 FR 69278, 69307 (Nov. 9, 2015).

Some stakeholders supported this proposal and others did not. In its comments, Rheem tentatively agreed with the proposal but indicated it would support DOE conducting further studies. (Rheem, No. 69 at p. 12) AHRI also proposed further study on the issue without further specificity. (AHRI, No. 70 at p. 17) UTC/Carrier requested clarification, although commented that the proposal seemed to be current industry practice. (UTC/Carrier, No. 62 at p. 14) JCI and Goodman also agreed that the maximum speed should be held constant. (JCI, No. 66 at p. 18; Goodman, No. 73 at pp. 8–9)

In contrast, Ingersoll Rand and Lennox commented that they do not support the proposal to fix the maximum compressor speed because it limits the potential performance benefits of heat pumps. (Ingersoll Rand, No. 65 at p. 11; Lennox, No. 61 at p. 11) Ingersoll Rand commented that this proposal will become a bigger problem when the heating load line of Appendix M1 is implemented. (Ingersoll Rand, No. 65 at p. 11) Lennox conducted testing on a three ton system and determined that operation at the 17 degree test point

could be enhanced by 40 percent capacity and 10 percent HSPF by allowing the speed of the compressor to change with outdoor air temperature. (Lennox, No. 61 at p. 11) Mitsubishi recommended that the current testing process remain the same and that the optional testing method for HSPF should allow manufacturers to obtain ratings that incorporate the varying of the maximum compressor speed with outdoor temperatures. (Mitsubishi, No. 68 at p. 4)

DOE agrees with JCI and Goodman that the maximum speed should be the same for the different test conditions. DOE notes that a unit's performance is calculated based on test results using extrapolation and interpolation assuming that capacity and power vary linearly with outdoor temperature (*i.e.*, the capacity and power vary a fixed amount in Btu/h for each additional degree that the outdoor temperature rises). For example, equations 4.2.2–3 and 4.2.2–4 in Appendix M of the current test procedure are used with k set equal to 2 to calculate heat pump capacity and power input when operating at maximum speed. The performance for temperatures below 17 °F and above 45 °F ambient temperatures is calculated based on tests conducted at 17 °F and 47 °F. Specifically, an equation for capacity as a function of ambient temperature is determined based on the measured capacities at 17 °F and 47 °F. This equation is then used to calculate capacity for all ambient conditions cooler than 17 °F and warmer than 45 °F. The same is done to determine heat pump power input for these temperature ranges. In a similar fashion, performance for temperatures between 17 °F and 45 °F are calculated based on tests conducted at 17 °F and 35 °F. The following example shows how allowing different compressor speeds for the pairs of tests used to determine performance can lead to non-representative results.

The heat pump in question varies its maximum compressor speed in heating mode—its performance is shown in Figure 2 of the Oak Ridge National Laboratory review of variable-speed heat pump test procedures. (Review of Test Procedure For Determining HSPF's of Residential Variable-Speed Heat Pumps, Docket No. EERE–2009–BT–TP–0004, No. 49 at p. 5) The maximum-speed capacity of this heat pump clearly does not vary linearly between outdoor temperatures of 17 °F and 47 °F. Use of the test procedure's equation to represent this heat pump's performance below 17 °F would indicate that its capacity increases as temperature drops

below 17 °F, which clearly is not true. This example shows that allowing different maximum compressor speeds can lead to nonsensical results. Hence, DOE is maintaining its proposal, consistent with its understanding of the test procedure's original intent, that maximum speed be the same speed for all test conditions of the particular operating (heating or cooling) mode that uses maximum speed. DOE has, however, modified the test procedure in this notice such that the maximum speed for a given operating mode (heating or cooling) used for the test conditions required to rate the product does not have to be the absolute maximum used by the product for that operating mode. Hence, a heat pump could use a higher maximum compressor speed when operating in a 5 °F ambient condition than used for the required tests in 17 °F, 35 °F, and 47 °F conditions. This provision assures that cold-climate variable speed heat pumps, those that boost compressor speed in very low ambient temperatures to reduce the amount of heat provided by resistance heating, can be tested using appropriate compressor speeds for the tested operating conditions. DOE has implemented the requirements discussed in this section differently than proposed. Instead of adding the proposed clarifications for maximum and minimum compressor speed in the definition of “variable-speed compressor system”, DOE has provided clarification regarding compressor speed requirements in sections 3.2 and 3.6, which describe the tests that are required to be conducted for cooling and heating modes.

DOE does agree that variable-speed heat pumps that have the capability to increase speed and thus heating capacity in lower ambient temperatures should have a test method that accurately reflects the performance of this potentially energy-saving feature (*e.g.*, see Lennox, No. 61 at p. 11). However, it is DOE's belief that accurately accounting for such a feature requires more careful consideration of test procedure changes beyond simply allowing the compressor speed to vary for the test conditions required by the current procedure. DOE will consider such revisions in a future rulemaking. In the meantime, if a manufacturer feels that more accurate representation of a unit's performance would be obtained with an alternative test procedure, the manufacturer has the option of petitioning for a test procedure waiver.

JCI and Goodman recommended using a different term than “maximum compressor speed”. (JCI, No. 66 at p. 18; Goodman, No. 73 at pp. 8–9) Goodman

recommended adopting the term “full”, as was proposed in the AHRI 210/240 Draft. DOE agrees and has modified the terminology accordingly, renaming the term “maximum compressor speed” to “full speed” to be consistent with AHRI 210/240 Draft.

The California IOUs commented that DOE should require the OUM to provide testing controls that allow fixed minimum, intermediate, and maximum speed/capacity controls settings. (California IOUs, No. 67 at p. 5) Rather than requiring provision of a test controller, DOE is requiring the provision as part of certification reporting of information that specifies the compressor frequency set points and settings for multi-step or variable-position components.

8. Refrigerant Charging Requirements

In the November 2015 SNOPR, DOE proposed to require that near-azeotropic and zeotropic refrigerant blends be charged in the liquid state rather than the vapor state. This was proposed for section 2.2.5.7 of Appendix M. 80 FR 69278, 69307 (Nov. 9, 2015).

DOE also proposed in the June 2010 NOPR to adopt into the test procedure select parts of the 2008 AHRI General Operations Manual indicating that the refrigerant charge cannot be changed after system setup. 75 FR at 31224, 31234–35 (June 2, 2010). DOE retained this requirement in the November 2015 SNOPR, specifically proposing that once the system has been charged with refrigerant consistent with the installation instructions shipped with the unit (or with other provisions of the test procedure, if the installation instructions are not provided or not clear), all tests must be conducted with this charge. 80 FR 69278, 69307 (Nov. 9, 2015).

Also, because the charging procedure would be different for systems with different metering devices, DOE also proposed to require manufacturers to report the type of metering device used during certification testing. 80 FR 69278, 69308 (Nov. 9, 2015).

If charging instructions are not provided in the manufacturer’s installation instructions shipped with the unit, DOE proposed standardized charging procedures consistent with the type of expansion device to ensure consistency between testing and field practice. For a unit equipped with a fixed orifice type metering device for which the manufacturer’s installation instructions shipped with the unit do not provide refrigerant charging procedures, DOE proposed that the unit be charged at the A or A₂ test condition, requiring addition of charge until the

superheat temperature measured at the suction line upstream of the compressor is 12 °F.¹² For a unit equipped with a TXV or electronic expansion valve (EXV) type metering device for which the manufacturer’s installation instructions shipped with the unit do not provide refrigerant charging procedures, DOE proposed that the unit be charged at the A or A₂ condition, requiring addition of charge until the subcooling¹³ temperature measured at the condenser outlet is 10 °F plus or minus the proposed tolerance range.¹⁴ 80 FR 69278, 69308 (Nov. 9, 2015).

For heating-only heat pumps for which refrigerant charging instructions are not provided in the manufacturer’s installation instructions shipped with the unit, the proposed standardized charging procedure would be followed while performing refrigerant charging at the H1 or H1₂ condition. DOE also proposed that charging be done for the H1 or H1₂ test condition for cooling/heating heat pumps which fail to operate properly in heating mode when charged using the standardized charging procedure for the A or A₂ test condition. In such cases, some of the tests conducted using the initial charge may have to be repeated to ensure that all tests (cooling and heating) are conducted using the same refrigerant charge. DOE proposed to add this requirement to use the same charge for all tests to Appendix M in a new section 2.2.5.8. 80 FR 69278, 69308 (Nov. 9, 2015).

DOE understands that manufacturers may provide installation instructions with different charging procedures for the indoor and outdoor units. In such cases, DOE proposed to require charging based on the installation instructions shipped with the outdoor unit for OUM products and based on the installation instructions shipped with the indoor unit for ICM products, unless otherwise specified by either installation instructions. 80 FR 69278, 69308 (Nov. 9, 2015).

DOE also proposed that one or more refrigerant line pressure gauges be installed during the setup of single-

package and split-system central air conditioner and heat pump products, depending on which parameters are used to set charge, unless otherwise specified by the installation instructions. DOE also proposed that the refrigerant charge be verified per the charging instructions provided in the installation instructions shipped with the unit, or, if no charging instructions are provided, the refrigerant charge would be verified based on the standardized charging procedure described above. 80 FR 69278, 69308 (Nov. 9, 2015).

As discussed in section III.E.14, DOE included in its proposal several aspects of the charging procedures that are included in a draft revision of AHRI 210/240. 80 FR 69278, 69308 (Nov. 9, 2015).

UTC/Carrier, Unico, Rheem, and JCI supported the November 2015 SNOPR proposal to require charging near-azeotropic and zeotropic refrigerant blends in the liquid state only. (UTC/Carrier, No. 62 at p. 14; Unico, No. 63 at p. 9; Rheem, No. 69 at p. 12; JCI, No. 66 at p. 18) There were no comments that disagreed with this proposal, so DOE is adopting it unchanged.

The California IOUs supported giving priority to the OUM charging instructions if the indoor and outdoor unit instructions differ but did not explain why the OUM charging instructions should take priority if both components include instructions and they are not consistent. DOE responds that integration of a system incorporating an OUM’s outdoor unit and an ICM’s indoor unit is the responsibility of the ICM. Consequently, DOE adopts the charging instruction priority as proposed, *i.e.* ICM instruction priority in this case.

The California IOUs also commented that providing generic superheat and subcooling temperatures is not appropriate or necessary, adding that manufacturers are required to include other types of installation instructions and should be required to do the same with something as basic as refrigerant charge. (California IOUs, No. 67 at p. 5) In response, DOE notes that most CAC/HP systems are shipped with installation instructions which discuss how to set refrigerant charge, and that it expects the provisions proposed to address cases where such instructions are not provided will not have to be used frequently. DOE notes further that providing clarity in the test procedure regarding how to address these situations will ensure that there is no question during testing about how to test products shipped without instructions.

¹² The range of superheating temperatures was generalized from industry-accepted practice and state-level authority regulations on refrigerant charging for non-TXV systems.

¹³ The degree of subcooling or subcooling temperature is the extent to which a fluid is cooler than its refrigerant bubble point temperature at the measured pressure, *i.e.*, the bubble point temperature at a fluid’s measured pressure minus its measured temperature. Bubble point temperature is the temperature at a given pressure at which vapor bubbles just begin to form in the refrigerant liquid.

¹⁴ The range of subcooling temperatures was generalized from manufacturer-published and technician-provided service instructions and are typical of industry practice.

Rheem added that it provides refrigerant charging instructions that are dependent on the design of the unit; the charging instructions are different for different expansion devices (Rheem, No. 69 at p. 15). Consequently, DOE is adopting the proposal to provide standardized charging procedures that are based on the type of expansion device. Rheem commented that if the manufacturer does not specify a target superheat or subcooling point, 10 °F +/− 1 °F superheat should be used for systems with a fixed refrigerant restrictor and 10 °F +/− 0.6 °F subcooling should be used for systems with a TXV or electronic expansion valve. (Rheem, No. 69 at p. 15). As mentioned above, DOE does not expect the “generic” values of 12 °F superheat and 10 °F subcooling to be used frequently and notes that manufacturers that desire that different target values be used should be sure to include installation instructions with the units. DOE did not receive other comments regarding the specific values of the targets in case instructions are not provided, and DOE’s research suggests that the proposed values are a good representation of the ranges of values provided in installations instructions for existing products. Hence, DOE is adopting the target values proposed in case instructions are not provided.

Unico did not support charging to a specific subcooling value in heating unless the product is heating-only (Unico, No. 63 at p. 10).

Responding to DOE’s question about confirming proper operation in the H1 or H₁₂ test for heat pumps following charging at the A or A₂ test condition, JCI requested that manufacturers be permitted to set charge levels in either heating or cooling mode (JCI, No. 66 at p. 19). Rheem agreed with the proposal to test a heat pump in the H1 or H₁₂ test in case it does not operate properly in heating mode with a charge set in the cooling mode, provided a definition of nonfunctional is added to the test procedure. (Rheem, No. 69 at p. 13) In response, DOE added explanation in section 2.2.5.2.b that shutdown of a unit by its limiting devices would constitute non-operation.

DOE notes that the proposal in the November 2015 SNOPIR requires that the installation instructions shipped with the system be consulted for instructions about how to charge the unit, and that the generic instructions be used only if no instructions are provided with the unit. Hence, a manufacturer has the option of requiring that charge be adjusted in cooling mode or to higher subcooling levels than indicated in section 2.2.5.4 of the

November 2015 SNOPIR, both of which would address Unico’s concerns. Likewise, a manufacturer could specify that charge be set in either heating or cooling mode, which addresses JCI’s concerns. 80 FR 69278, 69308 (Nov. 9, 2015).

In order to clarify that the manufacturer can specify the operating mode to be used for setting charge, DOE has added language to section 2.2.5.2 of this final rule notice allowing manufacturers the option of specifying tests for charging other than the A or A₂ test. DOE maintains, however, the requirement that air volume rate must be determined by the A or A₂ test.

Goodman disagreed that all single-package units must be pressure-verified, requesting an option for manufacturers to specify whether or not to connect pressure measurement devices (Goodman, No. 73 at p. 9). In response, section 2.2.5.5 of this final rule notice allows for manufacturers to specify in installation instructions whether or not pressure measurement instruments should be attached. Otherwise, DOE is adopting the proposal regarding refrigerant pressure gauges.

For the final rule, DOE has explicitly designated the charging tolerances as test condition tolerances (see section 2.2.5.4). This clarifies that the charging tolerances refer to the maximum permissible differences between the average value of the measured temperature and the specified temperature in the DOE test procedure.

Also for the final rule, DOE has relaxed the tolerance on subcooling in section 2.2.5.4 from +/− 0.6 °F (the maximum tolerance listed in the draft version of AHRI 210/240) to +/− 2.0 °F. DOE is adopting this change for two reasons. First, in re-examining past tests, DOE has observed considerable variation in subcooling temperatures even for properly installed systems that are operating correctly. DOE believes a test condition tolerance of +/− 0.6 °F will unnecessarily increase the difficulty of testing these units. Second, the minimum accuracy requirements in the current test procedure on the temperature and pressure instruments could result in as much as a 3.0 °F measurement uncertainty on subcooling. Using today’s typical instrumentation, however, the expected measurement uncertainty is about 1.0 °F. DOE does not wish to require tighter tolerances than measurement uncertainties. Based on this, DOE settled on the average, a 2.0 °F test condition tolerance on subcooling.

DOE analyzed the impact of this tolerance change on capacity and EER by simulating performance across split-

system and single-package air-conditioners as well as split-system heat pumps, varying the subcooling. On both capacity and EER, the impact of a 2.0 °F fluctuation was less than 1% of the capacity and EER at baseline subcooling. DOE concluded that the advantages of increasing the tolerance in reducing test burden outweighed this impact. Hence, as mentioned, DOE is adopting the 2.0 °F tolerance on subcooling.

DOE received no other comments on proposals concerned with changing the refrigerant charge after setup, reporting the type of metering device, refrigerant charge verification, and/or any other DOE proposals. Consequently, DOE is adopting these proposals for this final rule notice.

9. Alternative Arrangement for Thermal Loss Prevention for Cyclic Tests

In the November 2015 SNOPIR, DOE proposed an alternative testing arrangement to prevent thermal losses during the compressor OFF period that would eliminate the need to install a damper in the inlet duct that conveys indoor chamber air to the indoor coil. The proposed alternative testing arrangement would allow the use of a duct configuration that relies on changes in duct height, rather than a damper, to eliminate natural convection thermal transfer out of the indoor duct during OFF periods of the “cold” (for tests of cooling mode) or heat (for tests of heating mode) generated by the system during the ON periods. An example of such an arrangement would be an upturned duct installed at the inlet of the indoor duct, such that the indoor duct inlet opening, facing upwards, is sufficiently high to prevent natural convection transfer out of the duct. The approach was developed for situations where insufficient space is available to install a damper box for both the inlet and outlet ductwork—the approach still requires use of a damper box on the outlet. DOE also proposed to require installation of a dry bulb temperature sensor near the inlet opening of the indoor duct at a centerline location not higher than the lowest elevation of the duct edges at the inlet. Measurement and recording of dry bulb temperature at this location would be required at least every minute during the compressor OFF period to confirm that no thermal loss occurs. DOE proposed a maximum permissible variation in temperature measured at this location during the OFF period of ±1.0 °F. 80 FR 69278, 69308–09 (Nov. 9, 2015). ADP supported this approach. (ADP, No. 59 at p. 11)

Rheem commented that the currently required damper in the inlet portion of the indoor air ductwork has not been a source of variation in their test results. Rheem plans to continue using the current damper configuration. Rheem did not support an optional configuration. (Rheem, No. 69 at p. 13, 14) Rheem has not explained their objection to allowing use of the alternative approach sufficiently for DOE to understand the concern. Hence, in this final rule, DOE is adopting the option to allow an alternative testing arrangement to prevent thermal losses for cyclic testing. If the alternative testing arrangement is used, installation of a dry bulb temperature sensor near the inlet opening of the indoor duct would be required, as well as measuring and recording the dry bulb temperature from this sensor.

JCI agreed with the proposal, but was concerned that it may not be possible to maintain the 1.0 °F tolerance at the duct inlet with continuous readings. (JCI, No. 66 at p.18). In response, DOE has relaxed the requirement such that any pair of 5-minute averages of the dry bulb temperature at the inlet, measured at least every minute during the compressor OFF period of the cyclic test, do not differ by more than 1.0 °F.

10. Test Unit Voltage Supply

In the November 2015 SNOPR, DOE clarified that the outdoor voltage supply requirement supersedes the indoor requirement if the provisions result in a difference for the indoor and outdoor voltage supply. DOE proposed that both the indoor and outdoor units be tested at the nameplate voltage of the outdoor unit. 80 FR 69278, 69309 (Nov. 9, 2015).

DOE received no comment on this proposal, however DOE recognized that it is possible that the nameplate voltages of the indoor and outdoor units could be so different that one unit cannot operate with the other's voltage supply. For example, if the outdoor unit requires 230V while the indoor unit requires 120V, applying 230V to the indoor unit would not be appropriate. DOE reviewed the range of nameplate voltages typically used for single-phase products as listed in Table 1 on page 3 of AHRI Standard 110–2012, “Air-Conditioning, Heating and Refrigerating Equipment Nameplate Voltages” and determined that the only pair of nameplate voltages for which the electrical components for a product rated with one could operate using the voltage rated with the other are 208 V (200 V) and 230V. Hence, DOE has decided to require use of the outdoor voltage supply for both indoor and outdoor components only when one is

rated with 208V or 200V and the other one is rated with 230V. For all other voltage combinations, DOE will require supplying each unit with its own nameplate voltage.

11. Coefficient of Cyclic Degradation

The current test procedure gives manufacturers the option to use a default cyclic degradation coefficient for cooling mode (C_{D^c}) value of 0.25 instead of running the optional cyclic test. In the November 2015 SNOPR, DOE proposed to update the default cooling C_{D^c} value in Appendix M to 0.2 based on testing of 19 units for which the measured degradation coefficient for cooling ranged from 0.02 to 0.18. DOE did not propose to update the default heating C_{D^h} value. 80 FR 69278, 69309 (Nov. 9, 2015).

Responding to DOE's proposal on the coefficient of cyclic degradation, stakeholders generally agreed with the proposed default of 0.2 for cooling. (see, e.g., AHRI, No. 70 at p. 12 or Ingersoll Rand, No. 65 at p. 1) The test procedure adopted in this final rule includes the proposed value of 0.2 as the default degradation coefficient for cooling for single-speed and two-capacity units.

However, DOE is aware that units with variable-speed compressors consistently have a higher coefficient of cyclic degradation than units with single-speed or two-capacity compressors. DOE reviewed the California Energy Commission (CEC) database of variable speed air conditioners and observed that the variable speed products rarely have a cooling C_{D^c} as low as 0.2. In its review of the CEC database, DOE noticed that many variable speed units are listed as multiple speed units. DOE separated the variable speed units from this group based on review of the product specification sheets, thus leading to a more complete list of variable speed models. As a result DOE found that, of 639 listed models that have variable-speed operation, only 76 (*i.e.* 11%) are rated with a C_{D^c} value less than or equal to 0.2. As discussed above, DOE initially proposed reducing the default value from 0.25 to 0.2 based on test data showing C_{D^c} values consistently below 0.2. However, these data did not include measurements for variable-speed units. Based on the clear evidence as illustrated by the CEC database information, the 0.2 value is not representative of the cyclic performance of variable-speed units. Hence, DOE has maintained the current default cooling C_{D^c} of 0.25 for variable speed products and unmatched outdoor units (see section III.A.3.g), while changing to a

default value of 0.2 for all other products as proposed.

DOE also proposed significant changes to the cyclic test. DOE proposed that before determining C_{D^c} , three “warm up” cycles for a unit with a single-speed compressor or two-speed compressor or two “warm up” cycles for a unit with a variable speed compressor must be conducted. Then a minimum of three complete cycles would be conducted after the warm-up period, taking a running average of C_{D^c} after each additional cycle. If after three cycles, the average of three cycles does not differ from the average of two cycles by more than 0.02, the three-cycle average should be used. If it differs by more than 0.02, up to two more valid cycles must be conducted. If the average C_{D^c} of the last three cycles are within 0.02 of or lower than the previous three cycles, use the average C_{D^c} of all valid cycles. After the fifth valid cycle, if the average C_{D^c} of the last three cycles is more than 0.02 higher than the previous three cycles, the default value must be used. DOE proposed the same changes for the test method to determine the heating coefficient of degradation. 80 FR 69278, 69309 (Nov. 9, 2015).

As a departure from the current test procedure approach, DOE proposed that manufacturers would have to conduct cyclic testing to determine C_{D^c} for each tested unit, rather than allowing them to use the default and avoid cyclic testing. Per the proposal, the default value would be used only if stability was not achieved during testing or when rating outdoor units with no match. 80 FR 69278, 69309 (Nov. 9, 2015).

AHRI, Lennox, UTC/Carrier, Ingersoll Rand, JCI, and Rheem commented that manufacturers should be allowed to use the default value without having to run the cyclic test. (AHRI, No. 70 at p. 12; Lennox, No. 61 at p. 18; UTC/Carrier, No. 62 at p. 17; Ingersoll Rand, No. 65 at p. 2, JCI, No. 66 at p. 10; Rheem, No. 69 at p. 14) In contrast, NEEA commented in response to the June 2010 NOPR that laboratory measurements are often “at odds” with the 0.25 default value, and suggested that testing is more accurate and should always be conducted. The comment did not indicate whether the measurements were generally higher or lower than the default. (NEEA, No. 7 at p. 6)

Lennox, UTC/Carrier, Rheem and AHRI suggested that a manufacturer should be allowed to use the first two cycles meeting a stability requirement, rather than requiring three warm-up cycles before official measurement begins. (Lennox, No. 61 at p. 18; UTC/Carrier, No. 62 at p. 17; Rheem, No. 69 at p. 14; AHRI, No. 70 at p.11). If

stability is not reached after eight cycles, several manufacturers suggested use of either a measured value or the default value, whichever is lower, rather than requiring use of the default value. Lennox, Rheem and UTC/Carrier suggested that this measured value be the highest C_{D^c} recorded for any of the eight test cycles. (Lennox, No. 61 at p.18; Rheem, No. 69 at p. 14; UTC/Carrier, No. 62 at p. 17) JCI suggested that the measured value be the average of the three highest measured C_{D^c} values (JCI, No. 66 at p. 10), and Ingersoll Rand suggested that the measured value be the highest C_{D^c} recorded in cycles four through eight (Ingersoll Rand, No. 65 at p. 3).

After reviewing all the stakeholders' comments, DOE has decided to allow manufacturers to use the default value without testing. Also, DOE is removing the requirement to conduct three warm-up cycles prior to making measurements. In the test finalized in this notice, a minimum of three cycles must be measured, and the test may then be terminated if the stability requirement is achieved. The test will still be required to continue for up to eight cycles if stability is not achieved. When the test is terminated, the highest C_{D^c} value recorded for any one test cycle would be used, unless it is higher than the default C_{D^c} , in which case the default would be used. The same approach is also adopted for the heating mode cyclic test. In response to the NEEA comment, DOE's data suggest that most single-stage and two-stage units have cyclic degradation coefficients less than the default and, in DOE's experience, manufacturers of such products nearly always run the cyclic test. DOE specifically re-evaluated selection of the default value so that it is higher than the expected result, but DOE retains in its procedures use of the default value rather than testing to limit test burden for cases where a low C_{D^c} is not critical to assuring that the represented value is compliant with the standard (e.g. for variable-speed units, which generally have higher C_{D^c} than single-stage or two-stage units).

In order to improve the accuracy of the cyclic test, DOE proposed in the June 2010 NOPR a calibration step in which the temperature difference between measurements of the inlet and outlet thermocouple grids used to make the cyclic test capacity measurements is checked during the steady state test which precedes the cyclic test (e.g. the steady state C test for cooling). If this temperature difference compares unfavorably to the more accurate dry bulb temperature difference based on air samplers and sample-air temperature

sensors (e.g. resistance temperature detectors (RTDs)), the proposal required that a calibration adjustment be made for the thermocouple grid measurements for use in the cyclic test. 75 FR 31235 (June 2, 2010). NEEA commented that they have no objection to DOE's proposal. (NEEA, No. 7 at p. 4) In contrast, AHRI disagreed with DOE's proposal and supported using the same temperature devices between the steady-state tests and cyclic tests to calculate C_D in order to ensure consistency of measurement between the two tests. (AHRI, No. 6 at p. 3) DOE notes that AHRI's recommended solution, use of the thermocouple grids for measurement of the inlet/outlet temperature difference for both the steady-state and cyclic tests used as the basis for calculating C_D , does not fully resolve the potential error in measurement if the measured temperature difference is high or low. In such a case, both the steady state and cyclic capacity estimates may be incorrect, and the overall measurement less precise than if the calibration step is taken. In order to achieve the original goal of improving the accuracy of the cyclic test, the test procedure in this final rule notice includes the proposed calibration step.

12. Break-in Periods Prior to Testing

DOE proposed in the November 2015 SNOFR to allow manufacturers the option of specifying a break-in period to be conducted prior to testing under the DOE test procedure. DOE proposed to limit the optional break-in period to 20 hours, which is consistent with the test procedure final rule for commercial HVAC equipment. DOE also proposed to adopt the same provisions as the commercial HVAC rule regarding the requirement for manufacturers to report the use of a break-in period and its duration as part of the test data underlying their product certifications, the use of the same break-in period specified in product certifications for testing conducted by DOE, and use of the 20 hour break-in period for products certified using an AEDM. 80 FR 69278, 69310 (Nov. 9, 2015).

In response to the November 2015 SNOFR, Unico supported the option of having a break-in period and had no comment on the number of hours. (Unico, No. 63 at p. 11) Several other commenters requested longer break-in periods than 20 hours. LG and Ingersoll Rand commented that on average 40 hours of operation are required to reach peak capacity and efficiency. (LG, No. 55 at pp. 1–2; Ingersoll Rand, No. 65 at pp. 10–11) Rheem commented that manufacturers should have the option of up to a 48 hour break-in period. (Rheem,

No. 69 at p. 14) Goodman commented that at least 72 hours should be permitted for break-in period testing because they believe that shorter break-in periods could produce test results that are inaccurate. (Goodman, No. 73 at pp. 12–13) Lennox, UTC/Carrier, and JCI also commented that some compressor manufacturers recommend up to 72 hours break-in. (Lennox, No. 61 at p. 19; UTC/Carrier, No. 62 at p. 17; JCI, No. 66 at p. 19) UTC/Carrier requested that DOE research directly with compressor manufacturers to align with their recommended compressor break-in periods. (UTC/Carrier, No. 62 at p. 17) Lennox commented that manufacturers should be able to specify break-in conditions. (Lennox, No. 61 at p. 19) JCI commented that if a manufacturer is willing to pay for an extended break-in time, it is reasonable to allow it, as it more closely represents what the consumer will see in the installation. (JCI, No. 66 at p. 19)

LG and Ingersoll Rand further commented that they have worked towards a process for reducing the required break-in period for scroll compressors, and have developed a process to reduce the required break-in period to 12 hours. (LG, No. 55 at pp. 1–2; Ingersoll Rand, No. 65 at pp. 10–11) LG commented that they will be phasing in this new process through 2016, and requested DOE to adopt a phase-in approach for the rule implementation, with the limit being 40 hours on the rule effective date followed by the final 20 hour limit that would commence one year after the effective date. (LG, No. 55 at pp. 1–2) Ingersoll Rand recommended the effective date of the maximum break-in time be January 1, 2017. (Ingersoll Rand, No. 65 at pp. 10–11)

In a supplemental response to the October 2011 SNOFR, AHRI requested that DOE implement an optional 75-hour break-in period for testing central air conditioners and heat pumps. It stated that scroll compressors, which are the type of compressors most commonly used in central air conditioners and heat pumps, achieve their design efficiency after 75 hours of operation. AHRI also cited a study of compressor break-in periods to justify this period of time.¹⁵ 80 FR 69278, 69309–310 (Nov. 9, 2015).

In the November 2015 SNOFR, DOE noted that, in reviewing the paper that AHRI cited, while the data indicate that products with scroll compressors do appear to converge upon a more

¹⁵ Khalifa, H.E. "Break-in Behavior of Scroll Compressors" (1996). *International Compressor Engineering Conference*. Paper 1145.

consistent result after compressor break-in periods exceeding 75 hours, the most significant improvement in compressor performance and reduction in variation among compressor models both appear to occur during roughly the first 20 hours of run time.¹⁶ 80 FR 69278, 69310 (Nov. 9, 2015). Considering the improvements in break-in as discussed in the comments of LG and Ingersoll-Rand, as well as the 1996 data which shows that most of the break-in occurs within 20 hours, DOE concludes that setting the break-in period at 20 hours appropriately balances test burden and full completion of the break-in process.

After reviewing the comments, DOE maintains its proposal from the SNOPR, and will allow a break-in period up to a maximum of 20 hours. As noted in the November 2015 SNOPR, DOE believes that a lengthy break-in period is not appropriate or justified. Since DOE determined in the May 16, 2012 commercial HVAC equipment final rule that a 20 hour maximum break-in time would be sufficient for small commercial air-conditioning products, which are of a capacity similar to central air-conditioning products, DOE does not see justification for a break-in period longer than 20 hours for central air conditioners and heat pumps. DOE acknowledges the research being done to reduce the break-in period as highlighted by LG and Ingersoll Rand, but DOE notes that at this time, none of the commenters has provided new information or data that sufficiently justifies the need for a longer break-in period.

Some commenters also requested that DOE provide additional specification regarding the break-in. The California IOUs recommended that DOE specify the operation of systems during the break in period or require the OUM to specify how the break-in should be done. (California IOUs, No. 67 at p. 5) Rheem commented that the break-in period should be at the A test cooling condition after the unit is properly charged. (Rheem, No. 69 at p. 14)

Without test results clearly showing the benefits of a particular set of break-in conditions, DOE is reluctant to require conditions for break-in that will require it to be conducted in the psychrometric chamber as part of a test, due to the significant test burden that such a requirement would impose. DOE declines to add more specification to the break-in period at this time but may consider modifications in a future rulemaking, provided sufficient information is provided to justify specific recommendations.

13. Industry Standards That Are Incorporated by Reference

In the November 2015 SNOPR, DOE proposed a number of updates to industry standards that are incorporated by reference. DOE proposed to update the IBR from ARI 210/240–2006 to AHRI 210/240–2008; ASHRAE 37–2005, Methods of Testing for Rating Unitary Air-Conditioning and Heat Pump Equipment to ANSI/ASHRAE 37–2009, Methods of Testing for Rating Electrically Driven Unitary Air-Conditioning and Heat Pump Equipment; ASHRAE 41.9–2000, Calorimeter Test Standard Methods for Mass Flow Measurements of Volatile Refrigerants to ASHRAE 41.9–2011, Standard Methods for Volatile-Refrigerant Mass Flow Measurements Using Calorimeters; ASHRAE/AMCA 51–1999/210–1999, Laboratory Methods of Testing Fans for Aerodynamic Performance Rating to AMCA 210–2007, Laboratory Methods of Testing Fans for Certified Aerodynamic Performance Rating; ASHRAE 41.1–1986 (Reaffirmed 2006), Standard Method for Temperature Measurement, to ANSI/ASHRAE 41.1–2013, Standard Method for Temperature Measurement; ASHRAE 41.6–1994, Standard Method for Measurement of Moist Air Properties to ASHRAE 41.6–2014, Standard Method for Humidity Measurement; and ASHRAE 23–2005, Methods of Testing for Rating Positive Displacement Refrigerant Compressors and Condensing Units, to ASHRAE 23.1–2010 Methods of Testing for Rating the Performance of Positive Displacement Refrigerant Compressors and Condensing Units That Operate at Subcritical Temperatures of the Refrigerant. DOE expressed the view that none of these updates includes significant changes to the sections referenced in the DOE test procedure and thus will not impact the ratings or energy conservation standards for central air conditioners and heat pumps.¹⁷ 80 FR 69278, 69310–11 (Nov. 9, 2015).

In response, JCI encouraged DOE to utilize industry standards to the fullest extent possible. (JCI, No. 66 at p. 20) Goodman requested that DOE, along with other stakeholders, continue participation in the revision of AHRI 210/240 to assist in getting to the point where DOE can potentially adopt this standard outright. (Goodman, No. 73 at p. 16)

¹⁷ ANSI/ASHRAE 37–2009 only updates to more recent versions of other standards it references. AMCA 210–2007 made slight changes to the figure referenced by DOE, which DOE has determined to be insignificant.

Ingersoll Rand requested DOE to remove all references to AMCA 210–2007, because it is for standalone air moving systems and does not match the configuration used for ducted HVAC equipment. (Ingersoll Rand, No. 65 at p. 13) AHRI and UTC/Carrier commented that the reference to AMCA 210–2007 in lieu of ASHRAE 116–1995 (RA 2005) for the air flow measurement apparatus is incorrect, and that instead the reference should be to section 6.3 of ANSI/ASHRAE 37–2009 or ASHRAE 41.2. (AHRI, No. 70 at p. 12; UTC/Carrier, No. 62 at p. 18)

DOE believes that the referenced sections are applicable to the airflow measurements required in Appendix M, as demonstrated by the installation types referenced in section 5.1.1 of AMCA 210–2007. DOE also notes that AHRI 210/240–2008 references the same sections of AMCA 210–2007 as Appendix M does, but DOE has simply chosen to reference AMCA 210–2007 directly. In response to AHRI and UTC/Carrier, DOE notes that section 2.6 of this final rule notice does reference sections 6.2 and 6.3 of ANSI/ASHRAE 37–2009 for fabricating and operating the Airflow Measurement Apparatus, and the manufacturer may refer to either Figure 12 of AMCA 210–2007 or Figure 14 of ASHRAE 41.2–1987 (RA 1992) for guidance on placing the static pressure taps and positioning the diffusion baffle. For these reasons, DOE maintains its incorporation by reference of AMCA 210–2007. DOE received no other comments on these proposed updates to industry standards, and in this final rule, DOE adopts all references to industry standards as proposed in the November 2015 SNOPR.

In the November 2015 SNOPR, DOE also proposed to revise the definition of “continuously recorded” based on changes to ASHRAE 41.1. ASHRAE 41.1–1986 (RA 2006) specified the maximum time interval of one minute for sampling dry-bulb temperature during a steady state test, with shorter sampling intervals based on expected rate of temperature change. The updated version, ANSI/ASHRAE 41.1–2013, does not contain specifications for sampling intervals. DOE proposed to require that dry-bulb temperature, wet bulb temperature, dew point temperature, and relative humidity data be “continuously recorded,” that is, sampled and recorded at 5 second intervals or less. DOE proposed this requirement as a means of verifying that temperature condition requirements are met for the duration of the test. 80 FR 69278, 69311 (Nov. 9, 2015).

UTC/Carrier and Rheem supported the proposed sampling interval. (UTC/

¹⁶ Ibid. pp. 442–443.

Carrier, No. 62 at p. 18; Rheem, No. 69 at p. 15) On the other hand, JCI recommended a longer sampling interval of 10 to 15 seconds, as there may be capital investment and programming required. (JCI, No. 66 at p. 20) Rheem commented that clarification is needed on how measurements such as the air leaving temperature are calculated from the multitude of values in the data sample. (Rheem, No. 69 at p. 15)

In response to JCI, DOE believes that the current standard of care requires digital data acquisition of all temperature and humidity measurements. DOE understands that for measurements being taken and recorded digitally, decreasing the sampling interval generally should have an insignificant impact on burden, since state-of-the-art data acquisition systems can easily record data at faster rates and the cost of the additional data storage is minimal. However, DOE understands that any specific test laboratory may require significant investment to upgrade to a faster data rate, depending on the capabilities of their current data acquisition systems, and hence has decided to increase the required sampling interval to 15 seconds. In response to Rheem's request for clarification, DOE believes that it is common industry practice, when continuously recording a parameter such as air leaving temperature, to average the value over the sampled interval. However, to enhance clarity, DOE has added words to sections 3.3.c and 3.7.b of Appendix M indicating that capacity is to be calculated using the averages of the 30-minute continuously-recorded measurements made for the parameters that are used to determine capacity (e.g. indoor air inlet and outlet temperatures).

14. References to ASHRAE Standard 116–1995 (RA 2005)

In the June 2010 NOPR, DOE proposed referencing ASHRAE Standard 116–1995 (RA 2005) within the DOE test procedure to provide additional information about the equations used to calculate SEER and HSPF for variable-speed systems. 75 FR 31223, 31243 (June 2, 2010). However, in section III.H.4 of the November 2015 SNOPR, DOE proposed to change the heating load line, and as such the equations for HSPF in ASHRAE 116–1995 (RA 2005) are no longer applicable. In order to prevent confusion, DOE proposed to withdraw the original proposal made in the June 2010 NOPR to reference ASHRAE 116–1995 (RA 2005) for both HSPF and SEER by removing those

instances of these references. 80 FR 69278, 69311 (Nov. 9, 2015).

DOE also proposed to revise its reference to the requirements of the air flow measuring apparatus from ASHRAE 116–1995 (RA 2005) to ANSI/ASHRAE 37–2009. As this was the only other reference to ASHRAE 116 in Appendix M, DOE proposed to remove the incorporation by reference to ASHRAE 116–1995 (RA 2005) from the Code of Federal Regulations related to central air conditioners and heat pumps. 80 FR 69278, 69311 (Nov. 9, 2015).

AHRI, UTC/Carrier, Ingersoll Rand, Goodman, Rheem, and JCI disagreed with the proposal to withdraw the incorporation by reference of ASHRAE 116–1995 (RA 2005). (AHRI, No. 70 at p. 12; UTC/Carrier, No. 62 at pp. 17–18, Ingersoll Rand, No. 65 at p. 3; Goodman, No. 73 at p. 11; Rheem, No. 69 at p. 14; JCI, No. 66 at p. 10) AHRI, UTC/Carrier, Ingersoll Rand, Goodman, and JCI suggested adding a reference to the section on thermal mass correction to the cyclic capacity (section 7.4.3.4.5) to reduce variability. (AHRI, No. 70 at p. 12; UTC/Carrier, No. 62 at pp. 17–18, Ingersoll Rand, No. 65 at p. 3; Goodman, No. 73 at p. 11; JCI, No. 66 at p. 10)

DOE notes that the current test procedure does not reference the thermal mass correction to cyclic capacity. DOE acknowledges that, because ASHRAE 116 has been incorporated by reference into the DOE test procedure, and because the cyclic test would first have been developed as part of ASHRAE 116, it is understandable that the prevailing interpretation may have been that the correction has always been included in the DOE test procedure. DOE also acknowledges that the thermal mass stored in devices and connections located between measured points must be accounted for to ensure repeatability and accuracy of a cyclic test. DOE understands that accounting for thermal mass in this way is common industry practice. Therefore, DOE has included provisions in section 3.5 of the final rule requiring a thermal mass adjustment, referencing section 7.4.3.4.5 of ASHRAE 116–2010. DOE notes that it has updated the IBR from ASHRAE 116–1995 (RA 2005) to ASHRAE 116–2010, but the content of the referenced section has not changed.

15. Additional Changes Based on AHRI 210/240-Draft

In August 2015, AHRI provided a draft version of AHRI 210/240 for the docket that will supersede the 2008 version once it is published. (AHRI Standard 210/240-Draft, No. 45, See EERE–2009–BT–TP–0004–0045) The

draft version includes a number of revisions from the 2008 version, some of which already exist in DOE's test procedure, and some of which do not. In the November 2015 SNOPR, DOE proposed to adopt several of these revisions. DOE noted that the final published version of what is currently the AHRI 210/240-Draft may not be identical to the docketed draft, and that if AHRI makes other than minor editorial changes to the sections DOE referenced in the SNOPR after publication, DOE would adopt the current draft content into its regulations and not incorporate by reference the modified test procedure. 80 FR 69278, 69312 (Nov. 9, 2015).

The AHRI 210/240-Draft added new size requirements for the inlet duct to the indoor unit, new external static pressure requirements for units intended to be installed with the airflow to the outdoor coil ducted, and a new requirement for the dew point temperature of the indoor test room when the air surrounding the indoor unit is not supplied from the same source as the air entering the indoor unit. DOE proposed to adopt these three revisions in the November 2015 SNOPR. 80 FR 69278, 69311 (Nov. 9, 2015).

DOE received comments from Ingersoll Rand regarding the proposed requirements for the inlet duct, which are discussed in section III.E.18. DOE did not receive any comments on the new external static pressure and dew point requirements and is adopting these revisions in this final rule.

The AHRI 210/240-Draft included differences as compared to the current DOE test procedure for setting air volume rates during testing. DOE proposed to adopt three of these changes because they would improve repeatability and the consistency of testing among different laboratories. 80 FR 69278, 69312 (Nov. 9, 2015). They include (a) use of air volume rates specified by manufacturers, (b) setting ESP requirements for operating modes other than full-load cooling, and (c) establishing an instability criterion for testing of units with constant-air-volume indoor blowers. DOE received no comments regarding these proposals and adopts them in this final rule.

DOE did receive several comments on other proposals related to setting air volume rates and has addressed these comments and revisions in section III.E.1.

The AHRI 210/240-Draft also included a more thorough procedure for setting of refrigerant charge than exists in the DOE test procedure. DOE proposed these changes because they improve test repeatability.

The AHRI 210/240-Draft also specifies both a target value tolerance and a maximum tolerance but does not specify in what circumstances each of these apply. In response, UTC/Carrier commented that they would like more detail, as correct refrigerant charging has a significant impact on performance and product reliability. (UTC/Carrier, No. 62 at p. 18) DOE interprets this comment as support of the additional detail regarding instructions for setting charge that were proposed in the November 2015 SNO PR, since the comment does not provide clarification regarding potential additional details that might be needed.

As an elaboration on DOE's past methodology, DOE believed that the AHRI 210/240-Draft did not clearly delineate how target value and maximum tolerances should be applied. Following from this lack of clarity, in the November 2015 SNO PR, DOE proposed to adopt the most liberal restriction on tolerance, the maximum tolerance, disregarding the AHRI 210/240-Draft target value. In addition, DOE proposed tolerances on the measured superheat and other parameters that would be set to specified levels during charging. 80 FR 69278, 69312 (Nov. 9, 2015). In this final rule, DOE continues to reference the maximum tolerance only. Additional comments regarding the procedure for setting of refrigerant charge, and revisions to the proposal are discussed in section III.E.8.

Finally, the AHRI 210/240-Draft included specifications for air sampling that provide more detail than provided in existing standards—DOE proposed incorporation of a number of these air sampling specifications into its test procedures. DOE did not receive comment on this proposal and is adopting the specifications in this final rule. However, DOE initially proposed incorporation by reference of sections of the AHRI 210/240-Draft, expecting that the standard might be published prior to this final rule. Because the AHRI standard was not finalized in time to incorporate the relevant sections of AHRI 210/240 by reference, DOE included the following provisions from the AHRI 210/240 draft in this final rule in order to finalize the proposal to adopt Appendix E4 Air Sampling Requirements in the November 2015 NOPR. DOE implemented these provisions consistent with the way they appear in the AHRI 210/240-Draft.

- DOE provided the definitions of Air Sampling Device and Aspiring Psychrometer to Section 1.2, Definitions, in Appendix M.

- DOE provided Section 2.14, Air Sampling Device and Aspiring

Psychrometer Requirements, to Appendix M based on E 4.4 and E 4.6 of AHRI 210/240-Draft.

- DOE integrated the outdoor test setup instructions in E 4.2, E 4.4 and E 4.6 of AHRI 210/240-Draft and adopted those in Section 2.11 of Appendix M, with some revisions to improve clarity.

- In Section 2.11, DOE provided additional instructions regarding blockage of air sampling holes when this is done to prevent sampling of recirculated air. The revisions are intended to preserve symmetry and uniformity of air flow into the holes.

- In Section 2.11, DOE also clarified that tubes conveying sampled air may have reduced insulation requirements if dry bulb temperature measurements are made at the exit of each air sampler.

16. Damping Pressure Transducer Signals

In the June 2010 NOPR, DOE proposed to loosen the existing test operating tolerance assigned to the external resistance to airflow (ESP) from 0.05 to 0.12 in wc and the nozzle pressure drop tolerance from 2.0 percent to 8.0 percent. 75 FR 31223, 31234 (June 2, 2010).

In response to the June 2010 NOPR proposal, NEEA commented that it strongly disagreed with DOE's proposal, particularly for the ESP tolerance. NEEA also commented that it strongly supported another option presented by DOE at the June 11, 2010 public meeting, which is to lengthen the time constant for the measurements by signal integration and averaging, using a DOE-specified interval. (NEEA, No. 7 at p. 4)

AHRI commented that they disagreed with DOE's proposal to relax ESP and nozzle pressure drop tolerances. AHRI believed that the pressure transducer fluctuation issues could be resolved by implementing a time averaging routine or some kind of electronic damping algorithm that would provide the same results as a liquid manometer, using an algorithm agreed upon by AHRI members. (AHRI, No. 6 at p. 3)

In the November 2015 SNO PR, rather than proposing a revision of the operating tolerances for external resistance to airflow or nozzle pressure drop, DOE proposed to add clarifying language in the test procedure that would allow for damping of the measurement system to prevent high-frequency fluctuations from affecting recorded pressure measurements. The proposal allowed for damping of the measurement system so that the time constant for response to a step change in pressure (*i.e.* the time required for the indicated measurement to change 63% of the way from its initial value to its

final value) would be no more than five seconds. This damping could be achieved in any portion of the measurement system. 80 FR 69278, 69312 (Nov. 9, 2015).

Rheem agreed with DOE's November 2015 SNO PR proposal regarding operating tolerances for external resistance to airflow or nozzle pressure drop. (Rheem, No. 69 at p. 15) JCI also agreed with that approach, but suggested that the time constant for response to a step pressure signal should be increased to 10 or 15 seconds, without providing an explanation why the slower response is needed. (JCI, No. 66 at p. 20) No commenters disagreed with the proposal. The intent of the damping is to address fluctuations associated with turbulence that would have a frequency so high that they would not be captured with a system with a 5 second response time. In the absence of more explanation regarding why the 5 second response is insufficient, DOE maintains this value for the damping allowance and, due to the absence of dissenting comments, DOE adopts this revision in the test procedure.

17. Clarify Inputs for the Demand Defrost Credit Equation

In the June 2010 NOPR, DOE proposed language in the test procedure to clarify that manufacturers must assign $\Delta\tau_{\text{def}}$ (the greater of the time in hours between defrost terminations and 1.5) the value of 6 hours if this limit is reached during a frost accumulation test and the heat pump has not completed a defrost cycle. A sentence was also proposed to be added in section 3.9.2 of Appendix M to indicate that the manufacturer must use a value of $\Delta\tau_{\text{max}}$, that is either the maximum time between defrosts as allowed by the controls (in hours) or 12, whichever is less. 75 FR at 31237 (June 2, 2010). In the proposal of the November 2015 SNO PR, this was changed to indicate that the value would be as provided in the installation manuals shipped with the unit. 80 FR at 69373 (Nov. 9, 2016).

AHRI supported DOE's proposal to clarify inputs to the demand defrost credit equation with the understanding that HSPF values would not be affected by such clarifications. (AHRI, No. 6 at p. 4) Ingersoll Rand stated that the facts do not support AHRI's understanding as there are significant numbers of heat pumps for which the reduction of the maximum permissible test duration from 12 to 6 hours would decrease the calculated HSPF. Ingersoll Rand further commented that reducing max duration of frost accumulation tests from 12 hours to 6 hours and eliminating the

short-cut method for determining SEER would reduce the rated performance of AC/HP, which would be an adverse situation for manufacturers. Ingersoll Rand commented that this would require re-rating of units that are above 13 SEER and un-rating units that are at 13 SEER. (Ingersoll Rand, No. 10 at p. 1)

As noted in the June 2010 SNOPIR, for most two-capacity and variable-speed heat pumps the proposal for the 6-hour limit reduces manufacturer test burden when defrost does not occur. DOE believes that when defrost does occur, the proposal has a negligible impact on the calculation of the average heating capacity and power consumption at a 35 °F outdoor temperature. Shortening the maximum duration of the frost accumulation test affects heat pumps that would otherwise conduct a defrost after 6 but before 12 hours in two ways. First, such heat pumps benefit slightly from not having a defrost cycle factored into their average heating capacity calculation. Second, they earn a higher demand defrost credit than they would have earned previously. As a worst case (e.g., unit's demand defrost controls actuate at 11.999 hours while the unit's maximum duration is 12 hours or more), the approximated demand defrost credit is now 1.017 compared to the "true" value of 1.000. 75 FR 31223, 31236–37 (June 2, 2010). The HSPF is directly proportional to the demand defrost credit factor (see Equation 4.2–1 of Appendix M), hence, this would represent a 1.7 percent increase in HSPF. Ingersoll Rand did not provide any justification for why it did not agree with DOE's analysis regarding the impact of the change. Therefore, DOE adopts this revision in the test procedure.

18. Improving Test Consistency Associated With Indoor Unit Air Inlet Geometry

Ingersoll Rand commented that the range of inlet geometries allowed by the DOE test procedure for ducted units may lead to different test results, specifically different measurements of static pressure and (for blower coil and single-package units) fan input power, depending on what specific inlet geometry is selected for conducting a test. They recommended that DOE adopt the short duct minimal requirement described in the draft version of AHRI 210/240–2015. (Ingersoll Rand, No. 65 at p. 6–10)

DOE first reviewed the inlet configurations that Ingersoll Rand evaluated and claimed are all compliant with the DOE inlet equipment connection requirements. DOE does not

agree that the current test procedure allows Configuration #7, in which the inlet plenum for measurement of inlet static pressure is upstream of the damper box. Section 2.5.1.1 of the current test procedure states, "install the inlet damper box upstream of the inlet plenum." This was proposed to be modified in the November 2015 SNOPIR to read, "Install the airflow prevention device upstream of the inlet plenum . . .". Configuration #7 is inconsistent with both descriptions. DOE notes that the greatest deviation in static pressure measurements presented by Ingersoll Rand is associated with Configuration #1, in which there is neither an inlet plenum nor a damper box, and the inlet static pressure simply measures room pressure. In this case, the measured inlet static pressure would generally be higher than measured using an inlet plenum, because part of the static pressure within the room is converted to inlet velocity pressure as the room air is accelerated towards the unit's inlet. DOE agrees that for consistency it would be beneficial to avoid Configuration #1 in testing. Hence, the final rule established in today's notice does not allow use of this arrangement. DOE believes that most units will be tested with damper boxes (or other airflow prevention devices) in order to conduct the cyclic test, because of the measured performance improvement associated with use of the measured cyclic degradation coefficient, which is often less than the default coefficient that can be used if the cyclic test is not conducted. Hence, DOE does not believe that many, if any, tests are conducted using Configuration #1. Thus, adopting this change should ensure test consistency with inconsequential impact on test burden.

Responding to potential misinterpretation of the requirements for air inlet geometry (e.g. regarding Configuration #7 discussed above), DOE made some clarifying revisions in this final rule that were not part of the proposals in the NOPR or SNOPIRs. The revisions include, (a) rearranging the text of section 2.4.2 regarding the inlet plenum for the indoor unit, (b) clarifying that figures 7b and 7c of ANSI/ASHRAE 37–2009 are for blower coil indoor units or single-package units while figure 8 is for coil-only units, and (c) clarifying that when an inlet plenum is not used that the length of straight duct upstream of the unit's inlet within the airflow prevention device must still adhere to the inlet plenum length requirements, as illustrated in ANSI/ASHRAE 37–2009, figures 7b, 7c, and 8.

F. Clarification of Test Procedure Provisions

This section discusses clarifications to the test procedure to address test procedure provisions that may lack sufficient specificity to ensure reproducibility. None of the clarifications listed in this section would alter the average measured energy consumption of a representative set of models.

1. Manufacturer Consultation

In the November 2015 SNOPIR, DOE proposed to clarify the test procedure provisions regarding the specifications for refrigerant charging prior to testing, with input on certain details from the AHRI 210/240-Draft, as discussed in section III.E.15. Specifically, DOE proposed to remove the current test procedure's allowance for contacting the manufacturer to receive charging instructions. In instances where multiple sets of instructions are specified or are included with the unit and the instructions are unclear on which set to test with, DOE proposed the use of field installation criteria. 80 FR 69278, 69313 (Nov. 9, 2015).

ADP and Lennox commented that before using standard sub-cooling and superheat values, the test facility should contact the manufacturer to obtain instructions in cases where they have been misplaced, and in all cases the test facility should contact the manufacturer to request the latest version of the installation instructions. ADP and Lennox commented that given the level of inventory in the industry, testing an off-the-shelf unit solely based on the installation instructions in the box with the unit could result in outdated instructions being used. (ADP, No. 59 at p. 10; Lennox, No. 61 at p. 17–18)

After reviewing these comments, DOE maintains that it is not necessary to contact the manufacturer for the latest refrigerant charging requirements, and that the instructions provided with the unit should be used as the unit should have been certified by the manufacturer as compliant with the information provided with the unit. Therefore, DOE has adopted this provision in the final rule.

In the November 2015 SNOPIR, DOE also proposed to revise language proposed in previous NOPRs regarding the metering of low-voltage transformers to eliminate the need for communication between third party test laboratories and manufacturers. 80 FR 69278, 69313 (Nov. 9, 2015). No comments were received on this proposal, and DOE adopts this provision in the final rule.

DOE also proposed to require manufacturers to report on their certification report whether the test was conducted with or without an inlet plenum installed in order to eliminate the need for the test laboratory to confirm this with the manufacturer. 80 FR 69278, 69313 (Nov. 9, 2015).

In response, AHRI, Nortek commented that it is burdensome and unnecessary to submit this data. (AHRI, No. 70 at p. 14; Nortek, No. 58 at p. 11) ADP, Unico, and Ingersoll Rand commented that they agreed with AHRI on this matter. (ADP, No. 59 at p. 7; Unico, No. 63 at p. 6; Ingersoll Rand, No. 65 at p. 12) JCI, UTC/Carrier, Lennox, and Mitsubishi commented generally that additional reporting requirements impose an unnecessary burden on manufacturers, which is discussed in section III.A.5. (JCI, No. 66 at p. 12; UTC/Carrier, No. 62 at p. 7; Lennox, No. 61 at pp. 14–15; Mitsubishi, No. 68 at pp. 1–2)

As discussed in section III.E.18, DOE has modified the test procedure to require the use of an inlet plenum or an inlet airflow prevention device that also provides the function of an inlet plenum, for ducted split-system or single-package units. Hence, this reporting requirement is not needed and DOE has removed it in the final rule.

DOE proposed to amend references in the test procedure to test setup instructions or manufacturer specifications by specifying that these refer to the test setup instructions included with the unit. DOE proposed to implement this change in the following sections: 2.2.2, 3.1.4.2(c), 3.1.4.4.2(c), 3.1.4.5(d), and 3.5.1(b)(3). 80 FR 69278, 69313 (Nov. 9, 2015). No comments were received on this proposal, and DOE adopts this provision in the final rule.

2. Incorporation by Reference of AHRI 1230–2010

ANSI/AHRI Standard 1230–2010 “Performance Rating of Variable Refrigerant Flow (VFR) Multi-Split Air-Conditioning and Heat Pump Equipment” with Addendum 2 (AHRI 1230–2010) prescribes test requirements for both consumer and commercial variable refrigerant flow multi-split systems. In the November 2015 SNOPR, DOE proposed to incorporate by reference the sections of AHRI 1230–2010 that are relevant to consumer variable refrigerant flow multi-split systems (namely, sections 3 (except 3.8, 3.9, 3.13, 3.14, 3.15, 3.16, 3.23, 3.24, 3.26, 3.27, 3.28, 3.29, 3.30, and 3.31), 5.1.3, 5.1.4, 6.1.5 (except Table 8), 6.1.6, and 6.2) into the existing test procedure for central air conditioners and heat

pumps at Appendix M to Subpart B of 10 CFR part 430. 80 FR 69278, 69313 (Nov. 9, 2015).

In response to this proposal, JCI, AHRI, Nortek, Unico, Mitsubishi and Rheem supported applying AHRI 1230 for VRF testing. (JCI, No. 66 at p. 20; AHRI, No. 70 at p. 17; Nortek, No. 58 at p. 14; Unico, No. 63 at p. 12; Mitsubishi, No. 68 at p. 4; Rheem, No. 69 at p. 15) In contrast, Goodman commented that all products in the residential market should be tested using the same test procedure, and suggested multi-split air conditioners should be tested via AHRI 210/240. (Goodman, No. 73 at p. 15–16) As virtually all commenters support the use of the industry test procedure AHRI 1230 for multi-split air conditioners, DOE incorporates by reference certain sections of AHRI 1230–2010 as proposed.

DOE also proposed to define the terms “Multiple-split (or multi-split) system”, “Small-duct, high-velocity system”, “Tested combination”, “Variable refrigerant flow system” and “Variable-speed compressor system” in its list of definitions in Appendix M to Subpart B of 10 CFR part 430. 80 FR 69278, 69313 (Nov. 9, 2015).

Regarding tested combination, AHRI had requested in response to the June 2010 NOPR that DOE use the “tested combination” definition in AHRI 1230–2010 (the definition appears in section 3.26 of this standard). (AHRI, No. 6 at pp. 1–2) In the November 2015 SNOPR, DOE proposed a definition which is nearly identical to the AHRI 1230–2010 definition, except that (a) the AHRI definition allows a maximum of 12 indoor units in the tested combination—the DOE proposal calls for up to five indoor units, (b) the DOE proposal allows use of an indoor unit model family other than the highest sales volume family if the 95 percent capacity threshold cannot be met with units of the highest sales volume family, and (c) DOE’s proposal provided clarification of what is meant by indoor unit nominal capacity. 80 FR at 69313–14 (Nov. 9, 2015). Commenters did not specifically address these provisions in their comments regarding the November 2015 SNOPR, and hence the final rule adopts them.

In addition, both AHRI and Mitsubishi had commented in response to the June 2010 NOPR that DOE should remove the requirement to turn off one of the indoor units when testing at minimum compressor speed. (AHRI, No. 6 at p. 2, Mitsubishi, No. 12 at p. 1) DOE established this test requirement for multi-split systems in a final rule published October 22, 2007. 72 FR

59906–59909. DOE had initially considered a more aggressive approach in the October 2007 Final Rule for turning off indoor units at part load in which the number of operating units would be proportional to the load level, but settled instead on turning off just one unit for minimum compressor speed. *Id.* at 59909. Multi-split systems have indoor units that respond individually to separate thermostats. The outdoor units are designed to operate when one or more of the indoor units are not operating. It certainly would be expected that, for a large percentage of the time that such a unit operates at minimum compressor speed, at least one of the indoor units would have cycled off. The test approach suggested by AHRI and Mitsubishi is more consistent with the operation of multi-head mini-split systems, for which all of the indoor units operate in unison in response to a single thermostat, rather than the operation of multi-split systems—for such systems, all indoor units would always be operating when the outdoor unit is at minimum compressor speed. DOE is not aware of any field test information that shows that all of the indoor units of a multi-split system continue to operate when the compressor is at minimum speed. Hence, DOE is maintaining the requirement to turn off one indoor unit for the minimum-speed tests.

Finally, Mitsubishi had also commented, in response to the June 2010 NOPR, that the 50% requirement be waived for multi-split systems with cooling capacity less than 24,000 Btu/h, and that the 95% to 105% capacity requirement for match between indoor and outdoor nominal capacities be considered a guideline rather than a requirement. (AHRI, No. 6 at p. 2, Mitsubishi, No. 12 at pp. 1–2) The 50% requirement (*i.e.* that none of the indoor units of the tested combination have a nominal cooling capacity greater than 50% of the outdoor unit’s nominal cooling capacity) has been adopted by DOE. DOE will not adopt the latter recommendation, since it would essentially eliminate any requirement for capacity matching, but has instead increased the flexibility of the requirements by allowing use of model families of indoor units other than the highest sales volume model family, if all of the tested combination requirements cannot be met by the highest sales volume family.¹⁸ DOE notes that it has clarified this allowance in this final

¹⁸ Examples of model families include configurations such as mid-range static ducted, high-static ducted, wall-mount, ceiling-mount 4-way cassette, ceiling-mount 2-way cassette, etc.

rule—whereas the proposed wording referenced inability to meet the 95% capacity threshold as the basis for considering other model families, the allowance in this final rule explicitly states that if all the requirements for “tested combination” cannot be met by indoor units selected from the highest sales volume model family, that one or more indoor units could be selected from a different sales model family.

Comments received regarding the term “multiple-split system” are discussed in section III.F.5. DOE did not receive comments on the other definitions and adopts them as proposed.

In the November 2015 SNOPR, DOE also proposed to omit Table 8 of AHRI 1230–2010 from the IBR in Appendix M and to set minimum ESP requirements for systems with short-run ducted indoor units in Table 3 of Appendix M as follows: 0.03 in. w.c. for units less than 28,800 Btu/h; 0.05 in. w.c. for units between 29,000 Btu/h and 42,500 Btu/h; and 0.07 in. w.c. for units greater than 43,000 Btu/h. Furthermore, DOE proposed to define the term “short duct systems,” to refer to ducted systems whose indoor units can deliver no more than 0.07 in. w.c. ESP when delivering the full load air volume rate for cooling operation. 80 FR 69278, 69314 (Nov. 9, 2015).

DOE received several comments in response to its proposal related to short duct systems and the required ESP. However, the CAC/HP ECS Working Group included recommendations to DOE regarding definitions and ESP for low-static and mid-static units rather than short duct systems. (Docket No. EERE–2014–BT–STD–0048, No. 76 at p. 1–2) Therefore, in this final rule, DOE is not adopting a definition or ESP requirement for short duct systems and will consider changes to the ESP for certain kinds of systems in a separate notice.

3. Replacement of the Informative Guidance Table for Using the Federal Test Procedure

In the November 2015 SNOPR, DOE proposed replacing the set of four tables at the beginning of “Section 2, Testing Conditions” of the current test procedure (10 CFR part 430, subpart B, Appendix M) with a more concise table to provide guidance to manufacturers regarding testing conditions, testing procedures, and calculations appropriate to a product class, system configuration, modulating capability, and special features of products. 80 FR 69278, 69314 (Nov. 9, 2015).

JCI commented the tables provide adequate clarity but that the table would

be more viewable if placed in a portrait view. (JCI, No. 66 at p. 20–21). UTC/Carrier responded that they would like any clarity DOE can provide. (UTC/Carrier, No. 62 at p. 19) Rheem expressed the preference of the current table over the proposed table in the November 2015 SNOPR and suggested that DOE further clarify the proposed table, including adding a title and explanation of how it should be used. Rheem also pointed out a possible error under testing conditions for single-split-system coil-only. (Rheem, No. 69 at p.16).

Given the general consensus on the proposed table, DOE is adopting the format of the proposed table in this final rule with some clarification. DOE found it difficult to fit the eight columns within the table in the portrait view suggested by JCI, and maintains the landscape format. In response to Rheem, the proposed table is titled “Informative Guidance for Using Appendix M” and an explanation of how it should be used is given in section 2 (B) of this final rule notice. DOE conducted further review and revision to the proposed table to clarify the sections each test should refer to, including fixing the identified error on single-split-system coil-only test conditions.

4. Clarifying the Definition of a Mini-Split System

In the November 2015 SNOPR, DOE proposed deleting the definition of mini-split air conditioners and heat pumps, and adding two definitions for: (1) single-zone-multiple-coil split system, representing a split system that has one outdoor unit and that has two or more coil-only or blower coil indoor units connected with a single refrigeration circuit, where the indoor units operate in unison in response to a single indoor thermostat; and (2) single-split system, representing a split system that has one outdoor unit and that has one coil-only or blower coil indoor unit connected to its other component(s) with a single refrigeration circuit. 80 FR 69278, 69314 (Nov. 9, 2015).

ADP, Lennox, and UTC/Carrier supported DOE’s proposal. (ADP, No. 59 at p. 12; Lennox, No. 61 at p. 19; UTC/Carrier, No. 62 at p. 20)

AHRI and Nortek proposed modifying the current definition to reflect common terminology used in the field. (AHRI, No. 70 at p. 17–18; Nortek, No. 58 at p. 14) AHRI and Mitsubishi recommended the terminology and definitions be revised as follows: (1) single head mini-split system, representing split systems that have a single outdoor section and one indoor section, where the indoor

section cycles on and off in unison in response to a single indoor thermostat; and (2) multi head mini-split system, representing split systems that have a single outdoor section and more than one indoor sections, where the indoor sections cycle on and off in unison in response to a single indoor thermostat. (AHRI, No. 70 at p. 17–18; Mitsubishi, No. 68 at p. 4)

Goodman commented that they do not support the terminology of “single-zone-multiple-coil split system” and that there is no need to separate a one-to-one split system and a one-to-multiple split system. However, Goodman also suggested using the terms single-head mini-split and multi-head mini-split if DOE desires to separate the definition of mini-split into two categories. (Goodman, No. 73 at p. 7)

Mitsubishi also specifically recommended that the references to “coil-only” be removed since Appendix M does not permit the matching of a variable speed outdoor unit with a coil without a blower that can match the airflow required for each of the tests. (Mitsubishi, No. 68 at p. 4)

In response to the recommended terminology from AHRI, Nortek, Mitsubishi, and Goodman, DOE is adopting the term “multi-head mini-split system” in the regulatory text rather than the proposed “single-zone multiple-coil system.” However, DOE believes it is important to specify that this system has a single refrigerant circuit, which is not part of the definition proposed by AHRI and Mitsubishi. In response to Mitsubishi, DOE has removed “coil-only” from the definition but cautions that this does not mean that the definition does not include systems with coil-only indoor units. DOE notes that the definition is not explicitly limited to variable-speed units, although DOE is aware that most of not all commercially available units that fit the definition have variable-speed compressors. For these reasons, DOE adopts the following definition for “multi-head mini-split system”:

Multi-head mini-split system means a split system that has one outdoor unit and that has two or more indoor units connected with a single refrigeration circuit. The indoor units operate in unison in response to a single indoor thermostat.

DOE is adopting the definition for single-split system as proposed in the SNOPR. DOE is not adopting a definition for “single-head mini-split,” as this variety of unit is included in the “single-split system” definition and there are no different test procedure requirements or energy conservation standard levels that would require

establishing a separate definition to distinguish these products.

5. Clarifying the Definition of a Multi-Split System

In the November 2015 SNOPR, DOE proposed to clarify the definition of multi-split system to specify that multi-split systems are to have only one outdoor unit. (DOE notes that it proposed to separately define multi-circuit units as units that incorporate multiple outdoor units into the same package. This is discussed in section III.C.1.) DOE also proposed to clarify that if a model of outdoor unit could be used both for single-zone-multiple-coil split systems (multi-head mini-split systems) and for multi-split systems, it should be tested as a multi-split system. 80 FR 69278, 69315 (Nov. 9, 2015).

In response, the California IOUs stated that the proposed definition was unclear and recommended the following definition: A multiple zone, multiple coil, split system is a split system with one outdoor unit and at least two coil-only or blower coil indoor units which operate separately as required to provide comfort in the zone each serves. (California IOUs, No. 67 at p. 6). DOE received no other comments on this issue.

The multi-split system definition suggested by California IOUs does not specify that the outdoor units and the indoor units are within a single refrigerant circuit, and therefore multi-circuit systems, which are tested differently, would fit in this definition. In order to preserve the distinction between multi-split and multi-circuit products, DOE adopts the proposed multi-split system definition from the

November 2015 SNOPR, which clarifies that for multi-split systems all components are connected with a single refrigerant circuit.

6. Clarifying the Housing for Uncased Coil

The current test procedure provides instructions for installing uncased coil indoor units, indicating that an enclosure be provided for them using 1 in. fiberglass ductboard (see Appendix M, section 2.2.c). DOE is aware of issues associated with the use of fiberglass ductboard, as its lack of rigidity can present challenges in maintaining tight seals where it connects to upstream and downstream ducts used in the test set-up. DOE also notes that the requirements of section 2.2.c regarding both the ductboard and its installation are unnecessarily limited in the approaches listed for fabricating an enclosure for the test. DOE is aware that test laboratories fabricate enclosures for testing uncased coils that consist of materials other than just the listed fiberboard or alternative insulation. DOE also understands that the term “fiberboard” is not sufficiently descriptive to assure that a foil-faced fiberboard be used, which would be consistent with the expectation that such a casing provide a barrier to both air flow and water vapor transmission. As a result, DOE is clarifying these instructions with additional language in this final rule regarding the installation of uncased coils, including (a) indicating that the ductboard must be foil-faced, (b) allowing alternative housings, consisting of sheet metal or similar material and separate insulation, and (c) indicating that sizing and

installation of the casing should be done as described in the installation instructions shipped with the unit. These clarifications are consistent with DOE’s proposal in the November 2015 SNOPR and its understanding and expectations of how these tests are being conducted and should be conducted. Although most ductboard material is foil-faced, DOE has clarified that alternative materials claimed to be ductboard should not be used—without the foil facing, the ductboard would not present a sufficient barrier to vapor and air penetration. These alternative housing materials (*i.e.* alternatives to foil-faced fiberboard) will allow for more rigid construction of the coil housing. Finally, DOE recognizes that details regarding the fabrication and installation of the housing may affect test results and hence clarifies that they should be performed as described in installation instructions shipped with the unit. These changes would not affect any tests being conducted consistent with existing requirements (*e.g.* for negligible air leakage and installation according to shipped instructions.) but are intended to clarify set-up procedures to enhance consistency of testing.

7. Test Procedure Reprint

DOE has reprinted the entirety of Appendix M to 10 CFR part 430 Subpart B in the regulatory text for this final rule to improve clarity regarding the revisions established by this final rule. Table III.6 lists proposals from the previous notices that appear in this regulatory text reprint, and provides reference to the respective revised section(s) in the regulatory text.

TABLE III.6.—TEST PROCEDURE AMENDMENTS ADOPTED IN THIS FINAL RULE
[By original proposal]

Section	Proposal to . . .	Reference	Preamble discussion	Regulatory text location*
June 2010 NOPR				
A.7	Add Calculations for Sensible Heat Ratio	75 FR 31229	III.G.1	3.3c, 4.5.
A.9	Modify Definition of Tested Combination	75 FR 31230	III.F.2	10 CFR 430.2 Definitions.
A.10	Add Definitions Terms Regarding Standby Power	75 FR 31231	None	Definitions.
B.1	Modify the Definition of “Tested Combination”	75 FR 31231	III.F.2	10 CFR 430.2 Definitions.
B.3	Clarify That Optional Tests May Be Conducted Without Forfeiting Use of the Default Value(s).	75 FR 31233	III.E.11	3.2.1, 3.2.2.1, 3.2.3
B.4	Allow a Wider Tolerance on Air Volume Rate To Yield More Repeatable Laboratory Setups.	75 FR 31233	III.E.1	3.1.4.1.1a.4(ii)
B.5	Change the Magnitude of the Test Operating Tolerance Specified for the External Resistance to Airflow.	75 FR 31234	III.E.17	3.3d Table, 3.5h Table, 3.7a Table, 3.8.1 Table, 3.9f Table.
	Change the Magnitude of the Test Operating Tolerance Specified for the Nozzle Pressure Drop.	75 FR 31234	III.E.17	3.3d Table, 3.5h Table, 3.7a Table, 3.8.1 Table.
B.6	Modify Refrigerant Charging Procedures: Disallow Charge Manipulation after the Initial Charge.	75 FR 31234	III.E.7	2.2.5.
B.7	Require All Tests be Performed with the Same Refrigerant Charge Amount.	75 FR 31235, 31250	III.F.1	2.2.5.8.
	When Determining the Cyclic Degradation Coefficient C _D , Correct the Indoor-Side Temperature Sensors Used During the Cyclic Test To Align With the Temperature Sensors Used During the Companion Steady-State Test, If Applicable: Equation.	75 FR 31235	III.E.11	3.4c, 3.5i, 3.7e, 3.8

TABLE III.6.—TEST PROCEDURE AMENDMENTS ADOPTED IN THIS FINAL RULE—Continued
[By original proposal]

Section	Proposal to . . .	Reference	Preamble discussion	Regulatory text location *
B.8	When Determining the Cyclic Degradation Coefficient C_D , Correct the Indoor-Side Temperature Sensors Used During the Cyclic Test To Align With the Temperature Sensors Used During the Companion Steady-State Test, If Applicable: Sampling Rate.	75 FR 31236	None	3.3b, 3.7a, 3.9e, 3.11.1.1, 3.11.1.3, 3.11.2a.
B.9	Clarify Inputs for the Demand Defrost Credit Equation	75 FR 31236	III.E.17	3.9.2a.
B.10	Add Calculations for Sensible Heat Ratio	75 FR 31237	III.G.1	3.3c, 4.5.
B.11	Incorporate Changes To Cover Testing and Rating of Ducted Systems Having More Than One Indoor Blower.	75 FR 31237	III.C.3	2.2.3, 2.2.3b, 2.4.1b, 3.1.4.1.1d, 3.1.4.2e, 3.1.4.4.2d, 3.1.4.5.2f, 3.2.2, 3.2.2.1, 3.6.2, 3.2.6, 3.6.7, 4.1.5, 4.1.5.1, 4.1.5.2, 4.2.7, 4.2.7.1, 4.2.7.2, 3.2.2.2 Table, 3.6.2 Table.
B.12	Add Changes To Cover Triple-Capacity, Northern Heat Pumps	75 FR 31238	III.C.4	3.6.6, 4.2.6.
B.13	Specify Requirements for the Low-Voltage Transformer Used When Testing for Off-Mode Power Consumption.	75 FR 31238	III.F.1	2.2d.
B.14	Add Testing Procedures and Calculations for Off Mode Power Consumption.	75 FR 31238	III.D	Definitions, 3.13, 4.3.
B.17	Update Test Procedure References	75 FR 31243	III.E.12	10 CFR 430.3 Definitions.
April 2011 SNOPR				
III.A	Revise Test Methods and Calculations for Off-Mode Power and Energy Consumption.	76 FR 18107	III.D	Definitions, 3.13, 4.3.
III.B	Revise Requirements for Selecting the Low-Voltage Transformer Used During Off-Mode Test(s).	76 FR 18109	III.F.1	2.2d.
III.D	Add Calculation of the Energy Efficiency Ratio for Cooling Mode Steady-State Tests.	76 FR 18111	None	4.7.
III.E	Revise Off-Mode Performance Ratings	75 FR 31238	III.D	Definitions, 3.13, 4.3.
October 2011 SNOPR				
III.A	Reduce Testing Burden and Complexity	76 FR 65618	III.D	Definitions, 3.13, 4.3.
III.C	Add Definition for Shoulder Season	76 FR 65620	III.D	Definitions.
III.D	Revise Test Methods and Calculations for Off-Mode Power and Energy Consumption.	76 FR 65620	III.D	Definitions, 3.13, 4.3.
III.D.1	Add Provisions for Large Tonnage Systems	76 FR 65621	III.D	Definitions, 3.13, 4.3.
III.D.2	Add Requirements for Multi-Compressor Systems	76 FR 65622	III.D	Definitions, 3.13.
November 2015 SNOPR				
III.A.1	Basic Model Definition	80 FR 69282	III.A.1	430.2.
III.A.2	Additional Definitions	80 FR 69284	III.A.2	430.2.
III.A.3	Determination of Certified Rating	80 FR 69285	III.A.3	429.16, 1.2.
III.A.4	Compliance with Federal (National or Regional) Standards	80 FR 69289	III.A.4	429.16(a).
III.A.5	Certification Reports	80 FR 69290	III.A.5	429.16(c).
III.A.6	Represented Values	80 FR 69291	III.A.6	429.16(a), 430.23.
III.A.7	Product-Specific Enforcement Provisions	80 FR 69292	III.A.7	429.134.
III.B.1	AEDM General Background	80 FR 69292	III.B.1	429.70(e).
III.B.2	AED< Terminology	80 FR 69292	III.B.2	429.70(e).
III.B.3	Elimination of the ARM Pre-Approval Requirement	80 FR 69293	III.B.3	
III.B.4	AEDM Validation	80 FR 69294	III.B.4	429.70(e)(2).
III.B.5	AEDM Requirements for Independent Coil Manufacturers	80 FR 69296	III.B.5	429.16.
III.B.6	AEDM Verification Testing	80 FR 69296	III.B.6	429.104, 429.70(e)(5).
III.B.7	Failure to Meet Certified Ratings	80 FR 69297	III.B.7	429.70(e)(5)(iv).
III.B.8	Action Following a Determination of Noncompliance	80 FR 69297	III.B.8	429.110, 429.70.
III.C.2	Termination of Waivers Pertaining to Multi-Circuit Products	80 FR 69299	III.C.2	429.16(a)(1)(ii)(A), 2.4.1b.
III.C.3	Termination of Waiver and Clarification of the Test Procedure Pertaining to Multi-Blower Products.	80 FR 69299	III.C.3	3.1.4.1.1.d, 3.1.4.2.e.
III.D.1	Off-Mode Test Temperatures	80 FR 69300	III.D.1	3.13.2.b.
III.D.2	Off-Mode Calculation and Weighting of P1 and P2	80 FR 69301	III.D.2	3.13.1, 4.3.
III.D.3	Off-Mode: Products with Large, Multiple or Modulated Compressors.	80 FR 69302	III.D.2	3.13.1.e, 3.13.2.g.
III.D.4	Off-Mode: Procedure for Measuring Low-Voltage Component Power.	80 FR 69302	III.D.7	3.13.1.c, 3.13.1.d, 3.13.2.c, 3.13.2.e, 3.13.2.f.
III.D.5	Off-Mode: Revision of Off-Mode Power Consumption Equations	80 FR 69302	III.D.7	3.13.1.e, 3.13.1.f, 3.13.2.g, 3.13.2.h.
III.D.6	Off-Mode Power Consumption for Split Systems	80 FR 69303	III.D.7	3.13.1, 3.13.2.
III.D.8	Test Metric for Off-Mode Power Consumption	80 FR 69304	III.D.3	429.16(a).
III.E.1	Indoor Fan Speed Settings	80 FR 69305	III.E.1	Table 2, 2.3.1.a, 3.1.4.1.1, 3.3(d).
III.E.2	Requirements for the Refrigerant Lines and Mass Flow Meter	80 FR 69306	III.E.3	2.2(a), 2.10.3.
III.E.3	Outdoor Room Temperature Variation	80 FR 69306	III.E.4	2.5, 2.11.b, 3.1.8.
III.E.4	Method of Measuring Inlet Air Temperature on the Outdoor Side.	80 FR 69307	III.E.5	2.11.b.
III.E.5	Requirements for the Air Sampling Device	80 FR 69307	III.E.6	2.5, 2.11.
III.E.6	Variation in Maximum Compressor Speed with Outdoor Temperature.	80 FR 69307	III.E.7	3.2.4, 3.6.4, 4.1.4, 4.2.4.
III.E.7	Refrigerant Charging Requirements	80 FR 69307	III.E.8	2.2.5.8.
III.E.8	Alternative Arrangement for Thermal Loss Prevention for Cyclic Tests.	80 FR 69308	III.E.9	2.5(c).
III.E.9	Test Unit Voltage Supply	80 FR 69309	III.E.10	2.7.
III.E.10	Coefficient of Cyclic Degradation	80 FR 69309	III.E.11	3.2.1, 3.2.2, 3.2.3, 3.2.4, 3.5, 3.6, 3.8.

TABLE III.6.—TEST PROCEDURE AMENDMENTS ADOPTED IN THIS FINAL RULE—Continued
[By original proposal]

Section	Proposal to . . .	Reference	Preamble discussion	Regulatory text location *
III.E.11	Break-in Periods Prior to Testing	80 FR 69309	III.E.12	3.1.7.
III.E.12	Industry Standards that are Incorporated by Reference	80 FR 69310	III.E.13	430.3.
III.E.13	Withdrawing References to ASHRAE 116–1995 (RA 2005)	80 FR 69311	III.E.14	
III.E.14	Additional Changes Based on AHRI 210/240-Draft	80 FR 69311	III.E.15	Table 2, 2.2.5.4.a, 2.2.5.5, 2.3.1.a, 2.4.2, 2.5, 2.11, 3.1.3.1, 3.1.4.1.1, 3.1.5, 3.3(d).
III.E.15	Damping Pressure Transducer Signals	80 FR 69312	III.E.16	2.6(a).
III.F.1	Manufacturer Consultation	80 FR 69313	III.F.1	2.2.5, 2.4.2, 2.2.2, 3.1.4.2(c), 3.1.4.4.2(c), 3.1.4.5(d), 3.5.1(b)(3).
III.F.2	Incorporation by Reference of AHRI 1230–2010	80 FR 69313	III.F.2	1, 3.12, 2.2.a, 2.2.b, 2.2.c, 2.2.1, 2.2.2, 2.2.3(a), 2.2.3(c), 2.2.4, 2.2.5, 2.4–2.12, Table 3, section 3.1 (except sections 3.1.3, 3.1.4), 3.3, 3.4, 3.5, 3.7–3.10, 3.13, 4.
III.F.3	Replacement of the Informative Guidance Table for Using the Federal Test Procedure.	80 FR 69314	III.F.3	Table 1.
III.F.4	Clarifying the Definition of a Mini-Split System	80 FR 69314	III.F.4	1.2.
III.F.5	Clarifying the Definition of a Multi-Split System	80 FR 69315	III.F.5	1.2.

* Section numbers in this column refer to the Appendix M test procedure finalized in this notice.

G. Additional Comments From Interested Parties

This section discusses additional comments made by interested parties during this rulemaking that were unrelated to any of DOE’s proposals.

1. Wet Coil Performance

NREL requested DOE require reporting of latent load or amount of water condensation removal at each test condition to be able to compare equipment performance between dry and humid regions. NREL also recommend adding two new cooling-mode test conditions to provide better representation of performance in hot dry regions and three new test cooling-mode conditions for hot humid regions. (NREL, No. 14 at p. 1)

In the June 2010 NOPR DOE proposed to add a calculation of the sensible heat ratio (SHR) to its test procedure to provide consumers and their contractors with more information to allow them to make more informed decisions regarding product selections. 75 FR 31223, 31237 (June 2, 2010). In response, UTC/Carrier and JCI noted in its comments that SHR is currently provided in manufacturer’s product data. (UTC/Carrier, No. 62 at p. 7; JCI, No. 66 at p. 12). In this final rule, DOE agrees that SHR was intended to be provided in manufacturer literature and has not adopted the November 2015 SNO PR proposal to require SHR be reported to DOE (see Section III.A.5) The latent load and water condensate rate can be calculated based on the SHR in manufacturers’ product literature and the rated cooling capacity, which should provide sufficient representation of wet coil performance.

The DOE test procedure requires units to be tested at 80 °F dry bulb temperature and 67 °F wet bulb

temperature during wet-coil cooling test to represent typical indoor conditions. DOE does not disagree that the additional test points proposed by NREL would provide additional representation of performance in hot dry and hot humid regions. However, requiring those additional tests would impose significant test burden on manufacturers. Currently, for a single-capacity air-conditioner, a manufacturer must conduct four tests and generally conducts in addition the dry and cyclic tests. Adding five tests would roughly double the test time for these units. It is not clear how the five additional tests recommended by NREL would improve the accuracy or field-representativeness of the measurements of SEER or EER. Hence, DOE has determined not to include these test points in the test procedure.

2. Barometric Pressure Correction

AHRI and JCI proposed that DOE implement a barometric pressure correction specification for testing. They suggested that barometric pressure be corrected to the altitude where the mean of the U.S. population lives. (AHRI, No. 70 at p. 13; JCI, No. 66 at p. 11) JCI suggested addressing barometric pressure by maintaining the enthalpy or humidity ratio of the entering air, indicating that this has been used effectively for lab correlation. (JCI, No. 66 at p. 11)

DOE has noted the industry’s concern regarding the impact of barometric pressure on the repeatability of tests and represented values. Currently, there is no systematic data to demonstrate the effect of barometric pressure on unit performance. However, JCI did not describe in sufficient detail how the correlation it proposed would work, nor

provide data showing that it properly addresses the barometric pressure issue.

DOE also notes that there has not been a study leading to selection of a standard altitude or pressure level. DOE is not adopting a barometric pressure correction in this final rule because an approach for addressing it has not been described in sufficient detail nor shown to provide the correct adjustment for pressure changes.

3. Inlet Screen

DOE proposed in the November 2015 SNO PR the use of a screen downstream of the air mixer in the outlet of the indoor unit if necessary to improve temperature uniformity. 80 FR at 69278, 69353 (Nov. 9, 2015). Ingersoll Rand commented that inlet and outlet screens on the indoor unit air stream will impose pressure drop, potentially requiring an increase in the code tester fan motor size. The code tester is the airflow measuring apparatus as discussed in section 2.6 of Appendix M. They also recommended that regardless of whether the cyclic test is carried out, the measured performance should be equivalent to the no damper test setup. (Ingersoll Rand, No. 65 at p. 5–6) DOE notes that the proposal included no requirement for an inlet screen, and that the screen in the outlet is an option to help meet the temperature uniformity requirements, but is not required if other means are sufficient to attain uniformity. Further, requirement for temperature uniformity for the outlet temperature measurement applies whether or not an outlet damper box is used, i.e., to conduct a cyclic test. DOE has made no changes in response to the Ingersoll Rand comment.

H. Compliance With Other Energy Policy and Conservation Act Requirements

This section discusses and responds to comments related to compliance with Energy Policy and Conservation Act Requirements.

1. Dates

HARDI commented that given the challenging and complex nature of the test procedure, the comment period should have been extended by 30 days. HARDI believes that restricting the comment period to 30 days has a negative impact to smaller companies as they may not have the means to fully assess the true impact of such a proposal in a narrow time frame. (HARDI, No. 57 at p. 1) JCI requested that the comment period remain open an additional 60 days to finalize their analysis of the proposed test procedure and any resulting clarifying comments. Goodman commented that the Department has not complied with federal law because it has failed to provide a 60-day comment period on this proposed test procedure per 42 U.S.C. 6293(b)(2). (Goodman, No. 73 at p. 22)

DOE notes that it received a request from AHRI to extend the comment period while the comment period was still open. (AHRI, No. 54, attachment 1). DOE considered the request from AHRI, but declined to do so. The November 2015 SNOPI represented the third round of comment on the CAC test procedure rulemaking. DOE is limited by a statutory cap on the number of days on which it can request public comment, and after three rounds of rulemaking, DOE is closer to that cap. Consequently, DOE declined the request and did not extend the comment period for the CAC/HP TP SNOPI. (AHRI, No. 54, Attachment 2)

JCI commented that the raw scope of changes proposed within the SNOPI coupled with the CAC/HP ECS Working Group and other DOE rulemaking activities is such that a complete and thorough review, understanding of the proposed changes, and resulting required laboratory changes, coupled with potential rerating and off mode standby test requirements make complying with the new test procedure within 180 days of being final particularly challenging if not impossible, and that the nature of many of the proposed changes to the test procedure require some level of capital investment and software programming. JCI formally requested that an additional 180 days were required to fully and completely implement all of the

proposed changes in the SNOPI in addition to the standard 180 days as currently prescribed. (JCI, No. 66 at p. 2–3)

First Co. commented that the 180 day effective date for AEDM compliance proposed by DOE is unrealistic and suggested an effective date of 18 months from the date the rule is finalized. (First Co., No. 56 at p. 1)

AHRI, ADP, Mortex, and Lennox commented that even with the adoption of the recommended “Similarity Group” framework, ICMs anticipate that the industry will face significant challenges to perform all the required testing in the currently required time of 180 days after the publication of the final rule. AHRI formally petitions the Department to extend the time period to comply to 360 days, as is consistent with its authority. See 42 U.S.C. 6293(c)(3). (AHRI, No. 70 at p. 7; ADP, No. 59 at p. 4; Mortex, No. 71 at p. 6–7; Lennox, No. 61 at p. 7)

In response to JCI, DOE notes that this final rule has a reduced scope from that of the SNOPI. In addition, DOE has made modifications to the off mode test requirement proposals to reduce test burden, as discussed in section III.D.10. For these reasons, DOE believes that a 180 day time period will be sufficient to implement the finalized test procedure. In response to First Co., AHRI, ADP, Mortex, and Lennox, DOE notes that 42 U.S.C. 6293(c)(3) allows individual manufacturers to petition DOE for additional time to comply. DOE cannot grant this additional time based on a blanket request from AHRI. However, as discussed in section III.H.2, the changes adopted in this final rule do not impact measured energy use; and as such, additional test burden is expected to be limited.

2. Measured Energy Use

EPCA requires that if DOE determines that the amended test procedure would alter the measured efficiency of a covered product, DOE must amend the applicable energy conservation standard accordingly. (42 U.S.C. 6293(e)(2)) In the November 2015 SNOPI, DOE determined that all proposed changes for Appendix M would not alter the measured efficiency of central air conditioners and heat pumps. DOE proposed all changes that it anticipated might alter the measured efficiency for Appendix M1, which will be addressed in a separate notice.

AHRI, Nortek and UTC/Carrier disagreed that the proposed changes to Appendix M will not alter the measured efficiency of a covered product. (AHRI, No. 70 at p. 1–2; Nortek, No. 58 at p. 1; UTC/Carrier, No. 62 at p. 23) UTC/Carrier commented that this could be

due to C_D testing changing the resultant SEER or HSPF, as it has slightly different stability requirements, or could be due to manufacturers losing the ability to de-rate and require ratings to be at the mean of the data/testing results. (UTC/Carrier, No. 62 at p. 23) AHRI contended that the following proposed changes may impact efficiency: Changes to the C_D ; requirement that manufacturers rate to the mean of the cooling capacity, heating capacity, and sensible heat ratio (SHR) and the prohibition on manufacturers’ conservative ratings; requirement that two-speed products must be tested coil-only, which has the potential to change ratings derived previously using a blower coil or the alternative rating method; and limit on compressor break-in period. (AHRI, No. 70 at p. 1–2)

Rheem commented that that each of the changes that have been proposed made a difference in the rating of a specific equipment sample subject to verification or enforcement testing and that it is not clear whether the certification rating will increase or decrease for each proposed change. Rheem commented that it is not clear how the conclusion that proposed changes do not impact standards was reached. (Rheem, No. 69 at p. 2)

DOE notes that with the exception of compressor break-in period, DOE has made modifications to its proposals on all the topics for which UTC/Carrier and AHRI expressed concern over change in represented value. In addition, DOE notes that the current test procedure does not include a compressor break-in period, and any change in represented value for testing a specific unit with a break-in period would only serve to improve the value as compared to the standard. For these reasons, DOE confirms that the changes adopted in this final rule do not alter the measured efficiency of the covered product.

Nortek commented that if the test procedure does not change the efficiency, then all existing ratings are still valid. (Nortek, No. 58 at p. 1) Similarly, First Co. commented that the final rule should make clear that ICM test results remain valid until the energy efficiency standard changes. Retesting is not required merely because the OUM discontinues the outdoor unit tested by the ICM. (First Co., No. 56 at p. 2) Finally, AHRI, ADP, Mortex, and Lennox asked for clarity on using data from existing tests to satisfy testing requirements especially considering the burden associated with outside lab testing. These parties stated that, based on the proposed framework, ICMs and OUMs would expect that data from

existing tests performed to the current test standard and meeting all other requirements could be used to satisfy the testing requirement for existing products. In addition, they said that ICMs and OUMs also expect that tests will remain valid until the energy conservation standard is changed and Appendix M1 becomes effective. (AHRI, No. 70 at p. 7; ADP, No. 59 at p. 4; Mortex, No. 71 at p. 6–7; Lennox, No. 61 at p. 7)

DOE acknowledges that manufacturers have large amounts of pre-existing data that they currently use to make representations about and certify the performance of their equipment and that regenerating all of this data within the 180 day timeframe would be burdensome. As such, manufacturers may continue to use such data to make representations about the performance of models after the 180 day timeframe, provided manufacturers are confident that the values are consistent with those that would be generated under the adopted test procedure.

3. Test Burden

EPCA requires that any test procedures prescribed or amended shall be reasonably designed to produce test results which measure energy efficiency, energy use, or estimated annual operating cost of a covered product during a representative average use cycle or period of use, and shall not be unduly burdensome to conduct. (42 U.S.C. 6293(b)(3)) For the reasons that follow, DOE has concluded that revising the DOE test procedure, per the amendments in this final rule, to measure the energy consumption of central air conditioners and heat pumps in active mode and off mode would produce the required test results and would not result in any undue burden.

As discussed in section IV.B of this final rule, the revised test procedures to determine the active-mode and standby-mode energy use would require use of the same testing equipment and facilities that manufacturers are currently using for testing to determine CAC/HP represented values for certifying performance to DOE. While this notice clarifies the test procedures, and adopts into regulation the test procedures associated with a number of test procedure waivers, most of the amendments would not affect test time or the equipment and facilities required to conduct testing. Possible changes in test burden associated with the amendments of this notice apply to off mode testing.

The amendments include additional testing to determine off mode energy use, as required by EPCA. (42 U.S.C.

6295(gg)(2)(A)) This additional testing may require investment in additional temperature-controlled facilities. However, DOE's revised test procedure does not require that every individual combination be tested for off mode, allowing extensive use of AEDMs in order to reduce test burden.

In addition, DOE carefully considered the testing burden on manufacturers in a modified off mode test procedure that is less burdensome than the proposals it made in the April 2011 SNOPR and October 2011 SNOPR and that addresses stakeholder comment regarding the test burden of such prior proposals. DOE made further changes to reduce test burden of the off-mode test procedure in response to comments regarding the November 2015 SNOPR, specifically (a) allowing the test to be conducted in a temperature-controlled room rather than a psychrometric test facility, and (b) allowing the test to be conducted without room temperature control for more designs than allowed by the proposal. Further discussion regarding test burden associated with the proposals set forth in this notice for determining off mode power consumption can be found in section III.D.

The November 2015 SNOPR also proposed amendments calling for testing to determine performance for ICMs. These amendments have been revised in this final rule such that far fewer models will have to be tested (see the discussion in section III.A.1.d).

DOE allows manufacturers to develop and apply an alternative efficiency determination method to certify products without the need of testing. In this notice, DOE revises and clarifies such requirements, as detailed in section III.B, to continue to enable manufacturers who wish to reduce testing burden to utilize this method.

As detailed in section III.C, manufacturers of certain products covered by test procedure waivers have already been using the alternative test procedures provided to them for certification testing. Thus, the inclusion of those alternative test procedures into the test procedure, as revised in this notice, does not add test burden.

DOE set forth amendments to improve test repeatability, improve the readability and clarity of the test procedure, and utilize industry procedures that manufacturers may be aware of in an effort to reduce the test burden. Sections III.E, III.F, and III.G present additional detail regarding such amendments.

DOE carefully considered the impact on testing burden and made efforts to balance accuracy, repeatability, and test

burden during the course of the development of all of the test procedure amendments. Therefore, DOE determined that the revisions to the central air conditioner and heat pump test procedure will produce test results that measure energy consumption during a period of representative use, and that the test procedure will not be unduly burdensome to conduct.

4. Potential Incorporation of International Electrotechnical Commission Standard 62301 and International Electrotechnical Commission Standard 62087

Under 42 U.S.C. 6295(gg)(2)(B), EPCA directs DOE to consider IEC Standard 62301 and IEC Standard 62087 when amending test procedures for covered products to include standby mode and off mode power measurements.

DOE reviewed IEC Standard 62301, “Household electrical appliances—Measurement of standby power” (Edition 2.0 2011–01),¹⁹ and determined that the procedures contained therein are not sufficient to properly measure off mode power for the unique characteristics of the components that contribute to off-mode power for CAC/HP products, *i.e.*, the crankcase heaters. Therefore, DOE determined that referencing IEC Standard 62301 is not appropriate for the revised test procedure that is the subject of this rulemaking.

DOE reviewed IEC Standard 62087, “Methods of measurement for the power consumption of audio, video, and related equipment” (Edition 3.0 2011–04), and determined that it would not be applicable to measuring power consumption of products such as central air conditioners and heat pumps. Therefore, DOE determined that referencing IEC Standard 62087 is not necessary for the revised test procedure that is the subject of this rulemaking.

IV. Procedural Issues and Regulatory Review

A. Review Under Executive Order 12866

The Office of Management and Budget (OMB) has determined that test procedure rulemakings do not constitute “significant regulatory actions” under section 3(f) of Executive Order 12866, Regulatory Planning and Review, 58 FR 51735 (Oct. 4, 1993). Accordingly, this action was not subject to review under the Executive Order by the Office of Information and Regulatory Affairs (OIRA) in the Office of Management and Budget.

¹⁹ IEC Standard 62301 covers measurement of power consumption for standby mode and low power modes, as defined therein.

B. Review Under the Regulatory Flexibility Act

The Regulatory Flexibility Act (5 U.S.C. 601 *et seq.*) requires preparation of a final regulatory flexibility analysis (FRFA) for any final rule, unless the agency certifies that the rule, if promulgated, will not have a significant economic impact on a substantial number of small entities. As required by Executive Order 13272, "Proper Consideration of Small Entities in Agency Rulemaking," 67 FR 53461 (August 16, 2002), DOE published procedures and policies on February 19, 2003, to ensure that the potential impacts of its rules on small entities are properly considered during the DOE rulemaking process. 68 FR 7990. DOE has made its procedures and policies available on the Office of the General Counsel's Web site: <http://energy.gov/gc/office-general-counsel>.

DOE reviewed today's final rule under the provisions of the Regulatory Flexibility Act and the procedures and policies published on February 19, 2003. This final rule prescribes clarifications to DOE's already-existing test procedures that will be used to test compliance with energy conservation standards for the products that are the subject of this rulemaking. It also adds a requirement to conduct testing to determine off mode power consumption. DOE has estimated the impacts of the test procedure changes on small business manufacturers.

For the purpose of the regulatory flexibility analysis for this rule, DOE adopts the Small Business Administration (SBA) definition of a small entity within this industry as a manufacturing enterprise with 1,250 employees or fewer. DOE used the small business size standards published by the SBA to determine whether any small entities would be required to comply with the rule. The size standards are codified at 13 CFR part 121. The standards are listed by North American Industry Classification System (NAICS) code and industry description and are available at https://www.sba.gov/sites/default/files/files/Size_Standards_Table.pdf.

Central air conditioner and heat pump manufacturing is classified under NAICS 333415, "Air-Conditioning and Warm Air Heating Equipment and Commercial and Industrial Refrigeration Equipment Manufacturing." 70 FR 12395 (March 11, 2005). DOE reviewed AHRI's listing of central air conditioner and heat pump product manufacturer members and surveyed the industry to develop a list of domestic manufacturers. As a result of this

review, DOE identified 24 domestic small manufacturers of central air conditioners and heat pumps.

Potential impacts of the amended test procedure on all manufacturers, including small businesses, come from impacts associated with the cost of proposed additional testing. In the June 2010 NOPR, DOE estimated the incremental cost of the proposed additional tests described in 10 CFR part 430, subpart B, Appendix M (proposed section 3.13) to be an increase of \$1,000 to \$1,500 per unit tested, indicating that the largest additional cost would be associated with conducting steady-state cooling mode tests and the dry climate tests for the SEER-HD rating). 75 FR 31243 (June 2, 2010). DOE has eliminated tests associated with SEER-HD from this rulemaking. DOE conservatively estimates that off mode testing might cost \$1,000 (roughly one-fifth of the \$5000 cost of active mode testing—see 75 FR 31243 (June 2, 2010)). Assuming two off mode tests per tested model, this is an average test cost of \$2,000 per model. This estimate does not take into consideration the possibility of the use of AEDMs for establishing off-mode represented values, which could significantly reduce the off-mode testing burden. It also does not take into account the changes in off-mode testing adopted in this final rule to reduce test burden, *i.e.*, specifically allowing more units to test off-mode energy use in a room without temperature control, and clarifying that off-mode testing does not need to be conducted in a psychrometric chamber (see section III.D for details).

The off mode test procedure primarily measures energy use of outdoor units. The off-mode power input represented values for CAC/HP model combinations including indoor units manufactured by ICMs would be equal to the off-mode represented values of other combinations using the same outdoor units. Hence, it is expected that small-business ICM manufacturers would use these same represented values rather than retesting the outdoor units and thus not be affected by the off-mode testing required by this rule. Because the incremental cost of running the extra off mode tests is the same for all other manufacturers, DOE believes that they would incur comparable costs for testing to certify off mode power use for basic models as a result of this final test procedure.

With respect to the provisions addressing AEDMs, the amendments contained herein will not increase the testing or reporting burden of OUMs who currently use, or are eligible to use,

an AEDM to certify their products. The amendments eliminate the ARM nomenclature and treat these methods as AEDMs, eliminate the pre-approval requirement for product AEDMs, revise the requirements for validation of an AEDM in a way that would not require more testing than that required by the AEDM provisions included in the March 7, 2011 Certification, Compliance and Enforcement Final Rule (76 FR 12422) ("March 2011 Final Rule"), and amend the process that DOE promulgated in the March 2011 Final Rule for validating AEDMs and verifying certifications based on the use of AEDMs. Because these AEDM-related amendments will either have no effect on test burden or decrease burden related to testing and determination of represented values of products (*e.g.*, elimination of ARM pre-approval), DOE has determined these amendments will result in no significant change in testing or reporting burden.

To evaluate the potential cost impact of off-mode testing for small OUMs, DOE estimated small manufacturers' total cost of testing. As discussed above, DOE identified 24 domestic small business manufacturers of CAC/HP products. Of these, only OUMs that operate their own manufacturing facilities (*i.e.*, are not private labelers selling only products manufactured by other entities) and OUM importing private labelers would be subject to the additional requirements for testing required by this rule. DOE identified 12 such manufacturers, but was able to estimate the number of basic models associated only with nine of these. DOE calculated the additional testing expense for these nine domestic small businesses. Assuming the \$2,000 estimate of additional test cost per basic model, and that testing of basic models may not have to be updated more than once every five years, DOE estimated that the annual cost impact of the additional testing is \$400 per basic model when the cost is spread over five years.

DOE currently requires that only one combination associated with any given outdoor unit be laboratory tested. 10 CFR 430.24(m). The majority of central air conditioners and heat pumps offered by a manufacturer are typically split systems that are not required to be laboratory tested but can be certified using an AEDM that does not require DOE testing of these units. DOE reviewed available data for the nine small businesses to estimate the incremental testing cost burden those firms might experience due to the revised test procedure. These manufacturers had an average of 35

models requiring testing. DOE determined the numbers of models using DOE's Compliance Certification Database (<https://www.regulations.doe.gov/certification-data/>). The additional testing cost for final certification for 35 models was estimated at \$70,000. Meanwhile, these certifications would be expected to last the product life, estimated to be at least five years. This test burden is therefore estimated to be approximately \$14,000 annually.

In addition to off-mode testing costs facing small OUMs of central air conditioners and heat pumps, this final rule will require ICMs to conduct testing for their basic models. However, DOE has modified its definition of basic model for ICM to match the Similarity Group concept suggested by several stakeholders (see section III.A.1.d). Further, DOE has relaxed its requirement for testing of ICM heat pump combinations, such that only a limited number of heat pump basic models would require testing, *i.e.*, those for which a test has not been conducted for an equivalent air-conditioner model. DOE identified three domestic small ICMs subject to testing costs under this final rule.

To calculate the additional testing costs facing small ICMs, DOE used data provided by AHRI regarding what they referred to as Similarity Groups and which DOE is considering to be basic models. Specifically, DOE assumed an average of 42 basic models per ICM based on the AHRI data. (AHRI, No. 70 at p. 6) DOE also assumed \$7,500 in added costs per test and two tests per basic model. (AHRI, No. 70 at p. 4) Assuming \$15,000 in additional testing costs per basic model (to cover two tests per model), and that testing of basic models may not have to be updated more than once every five years, DOE estimated that the total additional testing cost for final certification of 42 basic models for each small ICM would amount to costs averaging \$126,000 per year.

DOE will provide its certification and final supporting statement of factual basis to the Chief Counsel for Advocacy of the SBA for review under 5 U.S.C. 605(b).

C. Review Under the Paperwork Reduction Act of 1995

Manufacturers of central air conditioners and heat pumps must certify to DOE that their products comply with any applicable energy conservation standards. In certifying compliance, manufacturers must test their products according to the DOE test procedures for central air conditioners

and heat pumps, including any amendments adopted for those test procedures. DOE has established regulations for the certification and recordkeeping requirements for all covered consumer products and commercial equipment, including central air conditioners and heat pumps. 76 FR 12422 (March 7, 2011); 80 FR 5099 (Jan. 30, 2015). The collection-of-information requirement for the certification and recordkeeping is subject to review and approval by OMB under the Paperwork Reduction Act (PRA). This requirement has been approved by OMB under OMB control number 1910-1400. Public reporting burden for the certification is estimated to average 30 hours per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information.

Notwithstanding any other provision of the law, no person is required to respond to, nor shall any person be subject to a penalty for failure to comply with, a collection of information subject to the requirements of the PRA, unless that collection of information displays a currently valid OMB Control Number.

D. Review Under the National Environmental Policy Act of 1969

In this final rule, DOE amends its test procedure for central air conditioners and heat pumps. DOE has determined that this final rule falls into a class of actions that are categorically excluded from review under the National Environmental Policy Act of 1969 (42 U.S.C. 4321 *et seq.*) and DOE's implementing regulations at 10 CFR part 1021. Specifically, this rule amends the existing test procedures without affecting the amount, quality or distribution of energy usage, and, therefore, would not result in any environmental impacts. Thus, this rulemaking is covered by Categorical Exclusion A5 under 10 CFR part 1021, subpart D, which applies to any rulemaking that interprets or amends an existing rule without changing the environmental effect of that rule. Accordingly, neither an environmental assessment nor an environmental impact statement is required.

DOE's CX determination for this rule is available at <http://energy.gov/nepa/categorical-exclusion-cx-determinations-cx>.

E. Review Under Executive Order 13132

Executive Order 13132, "Federalism," 64 FR 43255 (August 4, 1999) imposes certain requirements on agencies formulating and implementing policies

or regulations that preempt State law or that have Federalism implications. The Executive Order requires agencies to examine the constitutional and statutory authority supporting any action that would limit the policymaking discretion of the States and to carefully assess the necessity for such actions. The Executive Order also requires agencies to have an accountable process to ensure meaningful and timely input by State and local officials in the development of regulatory policies that have Federalism implications. On March 14, 2000, DOE published a statement of policy describing the intergovernmental consultation process it will follow in the development of such regulations. 65 FR 13735. DOE has examined this final rule and has determined that it would not have a substantial direct effect on the States, on the relationship between the national government and the States, or on the distribution of power and responsibilities among the various levels of government. EPCA governs and prescribes Federal preemption of State regulations as to energy conservation for the products that are the subject of this rule. States can petition DOE for exemption from such preemption to the extent, and based on criteria, set forth in EPCA. (42 U.S.C. 6297(d)) No further action is required by Executive Order 13132.

F. Review Under Executive Order 12988

Regarding the review of existing regulations and the promulgation of new regulations, section 3(a) of Executive Order 12988, "Civil Justice Reform," 61 FR 4729 (Feb. 7, 1996), imposes on Federal agencies the general duty to adhere to the following requirements: (1) Eliminate drafting errors and ambiguity; (2) write regulations to minimize litigation; (3) provide a clear legal standard for affected conduct rather than a general standard; and (4) promote simplification and burden reduction. Section 3(b) of Executive Order 12988 specifically requires that Executive agencies make every reasonable effort to ensure that the regulation: (1) Clearly specifies the preemptive effect, if any; (2) clearly specifies any effect on existing Federal law or regulation; (3) provides a clear legal standard for affected conduct while promoting simplification and burden reduction; (4) specifies the retroactive effect, if any; (5) adequately defines key terms; and (6) addresses other important issues affecting clarity and general draftsmanship under any guidelines issued by the Attorney General. Section 3(c) of Executive Order 12988 requires Executive agencies to

review regulations in light of applicable standards in sections 3(a) and 3(b) to determine whether they are met or it is unreasonable to meet one or more of them. DOE has completed the required review and determined that, to the extent permitted by law, the rule meets the relevant standards of Executive Order 12988.

G. Review Under the Unfunded Mandates Reform Act of 1995

Title II of the Unfunded Mandates Reform Act of 1995 (UMRA) requires each Federal agency to assess the effects of Federal regulatory actions on State, local, and Tribal governments and the private sector. Public Law 104–4, sec. 201 (codified at 2 U.S.C. 1531). For a regulatory action likely to result in a rule that may cause the expenditure by State, local, and Tribal governments, in the aggregate, or by the private sector of \$100 million or more in any one year (adjusted annually for inflation), section 202 of UMRA requires a Federal agency to publish a written statement that estimates the resulting costs, benefits, and other effects on the national economy. (2 U.S.C. 1532(a), (b)) The UMRA also requires a Federal agency to develop an effective process to permit timely input by elected officers of State, local, and Tribal governments on a proposed “significant intergovernmental mandate,” and requires an agency plan for giving notice and opportunity for timely input to potentially affected small governments before establishing any requirements that might significantly or uniquely affect small governments. On March 18, 1997, DOE published a statement of policy on its process for intergovernmental consultation under UMRA. 62 FR 12820; also available at <http://energy.gov/gc/office-general-counsel>. DOE examined this final rule according to UMRA and its statement of policy and determined that the rule contains neither an intergovernmental mandate, nor a mandate that may result in the expenditure of \$100 million or more in any year, so these requirements do not apply.

H. Review Under the Treasury and General Government Appropriations Act, 1999

Section 654 of the Treasury and General Government Appropriations Act, 1999 (Pub. L. 105–277) requires Federal agencies to issue a Family Policymaking Assessment for any rule that may affect family well-being. This final rule will not have any impact on the autonomy or integrity of the family as an institution. Accordingly, DOE has concluded that it is not necessary to

prepare a Family Policymaking Assessment.

I. Review Under Executive Order 12630

DOE has determined, under Executive Order 12630, “Governmental Actions and Interference with Constitutionally Protected Property Rights” 53 FR 8859 (March 18, 1988), that this regulation will not result in any takings that might require compensation under the Fifth Amendment to the U.S. Constitution.

J. Review Under the Treasury and General Government Appropriations Act, 2001

Section 515 of the Treasury and General Government Appropriations Act, 2001 (44 U.S.C. 3516 note) provides for agencies to review most disseminations of information to the public under guidelines established by each agency pursuant to general guidelines issued by OMB. OMB’s guidelines were published at 67 FR 8452 (Feb. 22, 2002), and DOE’s guidelines were published at 67 FR 62446 (Oct. 7, 2002). DOE has reviewed this final rule under the OMB and DOE guidelines and has concluded that it is consistent with applicable policies in those guidelines.

K. Review Under Executive Order 13211

Executive Order 13211, “Actions Concerning Regulations That Significantly Affect Energy Supply, Distribution, or Use,” 66 FR 28355 (May 22, 2001), requires Federal agencies to prepare and submit to OMB, a Statement of Energy Effects for any significant energy action. A “significant energy action” is defined as any action by an agency that promulgated or is expected to lead to promulgation of a final rule, and that: (1) is a significant regulatory action under Executive Order 12866, or any successor order; and (2) is likely to have a significant adverse effect on the supply, distribution, or use of energy; or (3) is designated by the Administrator of OIRA as a significant energy action. For any significant energy action, the agency must give a detailed statement of any adverse effects on energy supply, distribution, or use associated with the rule’s implementation, and of reasonable alternatives to the action and their expected benefits on energy supply, distribution, and use.

The regulatory action is not a significant regulatory action under Executive Order 12866. Moreover, it will not have a significant adverse effect on the supply, distribution, or use of energy, nor has it been designated as a significant energy action by the Administrator of OIRA. Therefore, it is

not a significant energy action, and, accordingly, DOE has not prepared a Statement of Energy Effects.

L. Review Under Section 32 of the Federal Energy Administration Act of 1974

Under section 301 of the Department of Energy Organization Act (Pub. L. 95–91; 42 U.S.C. 7101), DOE must comply with section 32 of the Federal Energy Administration Act of 1974, as amended by the Federal Energy Administration Authorization Act of 1977. (15 U.S.C. 788; FEAA) Section 32 essentially provides in relevant part that, where a proposed rule authorizes or requires use of commercial standards, the notice of proposed rulemaking must inform the public of the use and background of such standards. In addition, section 32(c) requires DOE to consult with the Attorney General and the Chairman of the Federal Trade Commission (FTC) concerning the impact of the commercial or industry standards on competition.

The rule incorporates testing methods contained in the following commercial standards: AHRI 210/240–2008, Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment; and AHRI 1230–2010, Performance Rating of Variable Refrigerant Flow Multi-Split Air-Conditioning and Heat Pump Equipment. While the amended test procedure is not exclusively based on AHRI 210/240–2008 or AHRI 1230–2010, one component of the test procedure, namely test setup requirements, adopts language from AHRI 210/240–2008 without amendment; and another component of the test procedure, namely test setup and test performance requirements for multi-split systems, adopts language from AHRI 1230–2010 without amendment. DOE has evaluated these standards and consulted with the Attorney General and the Chairman of the FTC and has concluded that this final rule fully complies with the requirements of section 32(b) of the FEAA.

M. Congressional Notification

As required by 5 U.S.C. 801, DOE will report to Congress on the promulgation of this rule before its effective date. The report will state that it has been determined that the rule is not a “major rule” as defined by 5 U.S.C. 804(2).

N. Description of Materials Incorporated by Reference

In this final rule, DOE is incorporating by reference specific sections, figures, and tables in the following two test

standards published by AHRI: ANSI/AHRI 210/240–2008 with Addenda 1 and 2, titled “Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment;” and ANSI/AHRI 1230–2010 with Addendum 2, titled “Performance Rating of Variable Refrigerant Flow (VRF) Multi-Split Air-Conditioning and Heat Pump Equipment.” DOE is also updating its incorporation by reference (IBR) to the most recent versions of specific standards, figures, and tables in the following standards published by ASHRAE: ASHRAE 23.1–2010 titled “Methods of Testing for Rating the Performance of Positive Displacement Refrigerant Compressors and Condensing Units that Operate at Subcritical Temperatures of the Refrigerant”, ANSI/ASHRAE 37–2009, Methods of Testing for Rating Electrically Driven Unitary Air-Conditioning and Heat Pump Equipment, ANSI/ASHRAE 41.1–2013 titled “Standard Method for Temperature Measurement”, ASHRAE 41.6–2014 titled “Standard Method for Humidity Measurement”, and ASHRAE 41.9–2011 titled “Standard Methods for Volatile-Refrigerant Mass Flow Measurements Using Calorimeters”. Finally, DOE is updating its IBR to specific figures in the most recent version of the following test procedure from ASHRAE and AMCA: ANSI/AMCA 210–2007, ANSI/ASHRAE 51–2007, Laboratory Methods of Testing Fans for Certified Aerodynamic Performance Rating.

AHRI 210/240–2008 is an industry accepted test procedure that measures the cooling and heating performance of central air conditioners and heat pumps and is applicable to products sold in North America. The test procedure in this final rule references various sections of AHRI 210/240–2008 that address test setup, test conditions, and rating requirements. AHRI 210/240–2008 is readily available on AHRI’s Web site at <http://www.ahrinet.org/site/686/Standards/HVACR-Industry-Standards/Search-Standards>.

AHRI 1230–2010 is an industry accepted test procedure that measures the cooling and heating performance of variable refrigerant flow (VRF) multi-split air conditioners and heat pumps and is applicable to products sold in North America. The test procedure in this final rule for VRF multi-split systems references various sections of AHRI 1230–2010 that address test setup, test conditions, and rating requirements. AHRI 1230–2010 is readily available on AHRI’s Web site at [*HVACR-Industry-Standards/Search-Standards*.](http://www.ahrinet.org/site/686/Standards/</p>
</div>
<div data-bbox=)

ASHRAE 23.1–2010 is an industry accepted test procedure for rating the thermodynamic performance of positive displacement refrigerant compressors and condensing units that operate at subcritical temperatures. The test procedure in this final rule references sections of ASHRAE 23.1–2010 that address requirements, instruments, methods of testing, and testing procedure specific to compressor calibration. ASHRAE 23.1–2010 can be purchased from ASHRAE’s Web site at <https://www.ashrae.org/resources-publications>.

ANSI/ASHRAE 37–2009 is an industry accepted standard that provides test methods for determining the cooling capacity of unitary air-conditioning equipment and the cooling or heating capacities, or both, of unitary heat pump equipment. The test procedure in this final rule references various sections of ANSI/ASHRAE 37–2009 that address test conditions and test procedures, updating the IBR from a previous version of this standard, ASHRAE 37–2005. ANSI/ASHRAE 37–2009 can be purchased from ASHRAE’s Web site at <https://www.ashrae.org/resources-publications>.

ANSI/ASHRAE 41.1–2013 is an industry accepted method for measuring temperature in testing heating, refrigerating, and air-conditioning equipment. The test procedure in this final rule references sections of ANSI/ASHRAE 41.1–2013 that address requirements, instruments, and methods for measuring temperature. ANSI/ASHRAE 41.1–2013 can be purchased from ASHRAE’s Web site at <https://www.ashrae.org/resources-publications>.

ASHRAE 41.2–1987 (RA 1992) is an industry accepted test method for measuring airflow. The test procedure in this final rule references sections of ASHRAE 41.2–1987 (RA 1992) that address test setup and test methods. ASHRAE 41.2–1987 (RA 1992) can be purchased from ASHRAE’s Web site at <https://www.ashrae.org/resources-publications>.

ASHRAE 41.6–2014 is an industry accepted test method for measuring humidity of moist air. The test procedure in this final rule references sections of ASHRAE 41.6–2014 that address requirements, instruments, and methods for measuring humidity. ASHRAE 41.6–2014 can be purchased from ASHRAE’s Web site at <https://www.ashrae.org/resources-publications>.

ASHRAE 41.9–2011 is an industry accepted standard that provides recommended practices for measuring the mass flow rate of volatile

refrigerants using calorimeters. The test procedure in this final rule references sections of ASHRAE 41.9–2011 that address requirements, instruments, and methods for measuring refrigerant flow during compressor calibration. ASHRAE 41.9–2011 can be purchased from ASHRAE’s Web site at <https://www.ashrae.org/resources-publications>.

ANSI/ASHRAE Standard 116–2010 is an industry accepted standard that provides test methods and calculation procedures for determining the capacities and cooling seasonal efficiency ratios for unitary air-conditioning, and heat pump equipment and heating seasonal performance factors for heat pump equipment. The test procedure in this final rule references various sections of ANSI/ASHRAE 116–2010 that addresses test methods and calculations, updating the IBR from a previous version of the standard, ASHRAE 116–1995 (RA 2005). ANSI/ASHRAE Standard 116–2010 can be purchased from ASHRAE’s Web site at <https://www.ashrae.org/resources-publications>.

AMCA 210–2007 is an industry accepted standard that establishes uniform test methods for a laboratory test of a fan or other air moving device to determine its aerodynamic performance in terms of air flow rate, pressure developed, power consumption, air density, speed of rotation, and efficiency for rating or guarantee purposes. The test procedure in this final rule references various sections of AMCA 210–2007 that address test conditions, updating the IBR from a previous version of this standard, ASHRAE/AMCA 51–1999/210–1999. AMCA 210–2007 can be purchased from AMCA’s Web site at <http://www.amca.org/store/index.php>.

V. Approval of the Office of the Secretary

The Secretary of Energy has approved publication of this final rule.

List of Subjects

10 CFR Part 429

Administrative practice and procedure, Confidential business information, Energy conservation, Reporting and recordkeeping requirements.

10 CFR Part 430

Administrative practice and procedure, Confidential business information, Energy conservation, Energy conservation test procedures, Household appliances, Imports, Incorporation by reference, Intergovernmental relations, Small businesses.

Issued in Washington, DC, on May 19, 2016.

Kathleen B. Hogan,

Deputy Assistant Secretary for Energy Efficiency, Energy Efficiency and Renewable Energy.

For the reasons set forth in the preamble, DOE amends parts 429 and 430 of chapter II of title 10, Code of Federal Regulations, to read as follows:

PART 429—CERTIFICATION, COMPLIANCE, AND ENFORCEMENT FOR CONSUMER PRODUCTS AND COMMERCIAL AND INDUSTRIAL EQUIPMENT

■ 1. The authority citation for part 429 continues to read as follows:

Authority: 42 U.S.C. 6291–6317.

■ 2. Section 429.12 is amended by revising paragraphs (b)(8) and (12) to read as follows:

§ 429.12 General requirements applicable to certification reports.

* * * * *

(b) * * *

(8) The test sample size (*i.e.*, number of units tested for the basic model, or in the case of single-split system or single-package central air conditioners and central air conditioning heat pumps, or multi-split, multi-circuit, or multi-head mini-split systems other than the “tested combination,” for each individual combination or individual model). Enter “0” if an AEDM was used in lieu of testing (and in the case of central air conditioners and central air conditioning heat pumps, this must be indicated separately for each metric);

* * * * *

(12) If the test sample size is listed as “0” to indicate the certification is based upon the use of an alternate way of determining measures of energy conservation, identify the method used for determining measures of energy

conservation (such as “AEDM,” or linear interpolation). Manufacturers of commercial packaged boilers, commercial water heating equipment, commercial refrigeration equipment, commercial HVAC equipment, and central air conditioners and central air conditioning heat pumps must provide the manufacturer’s designation (name or other identifier) of the AEDM used; and

* * * * *

■ 3. Section 429.16 is revised to read as follows:

§ 429.16 Central air conditioners and central air conditioning heat pumps.

(a) *Determination of Represented Value*—(1) *Required represented values.* Determine the represented values (including SEER, EER, HSPF, P_{w,OFF}, cooling capacity, and heating capacity, as applicable) for the individual models/combinations (or “tested combinations”) specified in the following table.

Category	Equipment subcategory	Required represented values
Single-Package Unit	Single-Package AC (including Space-Constrained). Single-Package HP (including Space-Constrained).	Every individual model distributed in commerce.
Outdoor Unit and Indoor Unit (Distributed in Commerce by OUM).	Single-Split System AC with Single-Stage or Two-Stage Compressor (including Space-Constrained and Small-Duct, High Velocity Systems (SDHV)).	Every individual combination distributed in commerce, including all coil-only and blower coil combinations. For each model of outdoor unit, this must include at least one coil-only value that is representative of the least efficient combination distributed in commerce with the particular model of outdoor unit.
	Single-Split System AC with Other Than Single-Stage or Two-Stage Compressor (including Space-Constrained and SDHV).	Every individual combination distributed in commerce, including all coil-only and blower coil combinations.
	Single-Split-System HP (including Space-Constrained and SDHV).	Every individual combination distributed in commerce.
	Multi-Split, Multi-Circuit, or Multi-Head Mini-Split Split System—non-SDHV.	For each model of outdoor unit, at a minimum, a non-ducted “tested combination.” For any model of outdoor unit also sold with models of ducted indoor units, a ducted “tested combination.” Additional representations are allowed, as described in paragraph (c)(3)(i) of this section.
Indoor Unit Only (Distributed in Commerce by ICM).	Multi-Split, Multi-Circuit, or Multi-Head Mini-Split Split System—SDHV.	For each model of outdoor unit, an SDHV “tested combination.” Additional representations are allowed, as described in paragraph (c)(3)(ii) of this section.
	Single-Split-System Air Conditioner (including Space-Constrained and SDHV).	Every individual combination distributed in commerce.
	Single-Split-System Heat Pump (including Space-Constrained and SDHV).	
Outdoor Unit with no Match	Multi-Split, Multi-Circuit, or Multi-Head Mini-Split Split System—SDHV.	For a model of indoor unit within each basic model, an SDHV “tested combination.” Additional representations are allowed, as described in section (c)(3)(ii).
		Every model of outdoor unit distributed in commerce (tested with a model of coil-only indoor unit as specified in paragraph (c)(2) of this section).

(2) P_{w,OFF}. If individual models of single-package systems or individual combinations (or “tested combinations”) of split systems that are otherwise identical are offered with

multiple options for off mode-related components, determine the represented value for the individual model/combination with the crankcase heater and controls that are the most

consumptive. A manufacturer may also determine represented values for individual models/combinations with less consumptive off mode options; however, all such options must be

identified with different model numbers for single-package systems or for outdoor units (in the case of split systems).

(3) *Limitations for represented values of individual combinations.* The following paragraphs explains the limitations for represented values of individual combinations (or “tested combinations”).

(i) *Regional.* A basic model may only be certified as compliant with a regional standard if all individual combinations within that basic model meet the regional standard for which it is certified. If a model of outdoor unit is certified below a regional standard, then the model of outdoor unit must have a unique model number for distribution in each region. An ICM cannot certify a

basic model containing a representative value that is more efficient than any combination certified by an OUM containing the same outdoor unit.

(ii) *Multiple product classes.* Models of outdoor units that are rated and distributed in individual combinations that span multiple product classes must be tested, rated, and certified pursuant to paragraph (a) of this section as compliant with the applicable standard for each product class. This includes multi-split systems, multi-circuit systems, and multi-head mini-split systems with a represented value for a mixed combination including both SDHV and either non-ducted or ducted indoor units.

(4) *Requirements.* All represented values under paragraph (a) of this

section must be based on testing in accordance with the requirements in paragraph (b) of this section or the application of an AEDM or other methodology as allowed in paragraph (c) of this section.

(b) *Units tested*—(1) *General.* The general requirements of § 429.11 apply to central air conditioners and heat pumps; and

(2) *Individual model/combination selection for testing.* (i) The table identifies the minimum testing requirements for each basic model that includes multiple individual models/combinations. For each basic model that includes only one individual model/combination, that individual model/combination must be tested.

Category	Equipment subcategory	Must test:	With:
Single-Package Unit	Single-Package AC (including Space-Constrained). Single-Package HP (including Space-Constrained).	The lowest SEER individual model.	N/A.
Outdoor Unit and Indoor Unit (Distributed in Commerce by OUM).	Single-Split-System AC with Single-Stage or Two-Stage Compressor (including Space-Constrained and Small-Duct, High Velocity Systems (SDHV)).	The model of outdoor unit	The model of coil-only indoor unit that is likely to have the largest volume of retail sales with the particular model of outdoor unit.
	Single-Split System AC with Other Than Single-Stage or Two-Stage Compressor (including Space-Constrained and SDHV).	The model of outdoor unit	The model of indoor unit that is likely to have the largest volume of retail sales with the particular model of outdoor unit.
	Single-Split-System HP (including Space-Constrained and SDHV). Multi-Split, Multi-Circuit, or Multi-Head Mini-Split Split System—non-SDHV.	The model of outdoor unit	At a minimum, a “tested combination” composed entirely of non-ducted indoor units. For any models of outdoor units also sold with models of ducted indoor units, a second “tested combination” composed entirely of ducted indoor units must be tested (in addition to the non-ducted combination).
Indoor Unit Only (Distributed in Commerce by ICM).	Multi-Split, Multi-Circuit, or Multi-Head Mini-Split Split System—SDHV.	The model of outdoor unit	A “tested combination” composed entirely of SDHV indoor units.
	Single-Split-System Air Conditioner (including Space-Constrained and SDHV).	A model of indoor unit	The least efficient model of outdoor unit with which it will be paired where the least efficient model of outdoor unit is the model of outdoor unit in the lowest SEER combination as certified by the OUM. If there are multiple models of outdoor unit with the same lowest SEER represented value, the ICM may select one for testing purposes.
	Single-Split-System Heat Pump (including Space-Constrained and SDHV).	Nothing, as long as an equivalent air conditioner basic model has been tested. If an equivalent air conditioner basic model has not been tested, must test a model of indoor unit.	

Category	Equipment subcategory	Must test:	With:
	Multi-Split, Multi-Circuit, or Multi-Head Mini-Split Split System—SDHV.	A model of indoor unit.	A “tested combination” composed entirely of SDHV indoor units, where the outdoor unit is the least efficient model of outdoor unit with which the SDHV indoor unit will be paired. The least efficient model of outdoor unit is the model of outdoor unit in the lowest SEER combination as certified by the OUM. If there are multiple models of outdoor unit with the same lowest SEER represented value, the ICM may select one for testing purposes.
Outdoor Unit with No Match		The model of outdoor unit	A model of coil-only indoor unit meeting the requirements of section 2.2e of Appendix M to subpart B of part 430.

(ii) Each individual model/combination (or “tested combination”) identified in paragraph (b)(2)(i) of this section is not required to be tested for P_{W,OFF}. Instead, at a minimum, among individual models/combinations with similar off-mode construction (even spanning different models of outdoor units), a manufacturer must test at least one individual model/combination for P_{W,OFF}.

(3) *Sampling plans and representative values.* (i) For individual models (for single-package systems) or individual combinations (for split-systems, including “tested combinations” for multi-split, multi-circuit, and multi-head mini-split systems) with represented values determined through testing, each individual model/combination (or “tested combination”) must have a sample of sufficient size tested in accordance with the applicable provisions of this subpart. For heat pumps (other than heating-only heat pumps), all units of the sample population must be tested in both the cooling and heating modes and the results used for determining all representations. The represented values for any individual model/combination must be assigned such that:

(i) *Off-Mode.* Any represented value of power consumption or other measure of energy consumption for which consumers would favor lower values must be greater than or equal to the higher of:

(A) The mean of the sample, where:

$$\bar{x} = \frac{1}{n} \sum_{i=1}^n x_i$$

and, \bar{x} is the sample mean; n is the number of samples; and x_i is the i^{th} sample; Or,

(B) The upper 90 percent confidence limit (UCL) of the true mean divided by 1.05, where:

$$UCL = \bar{x} + t_{.90} \left(\frac{s}{\sqrt{n}} \right)$$

And \bar{x} is the sample mean; s is the sample standard deviation; n is the number of samples; and $t_{0.90}$ is the t statistic for a 90 percent one-tailed confidence interval with n – 1 degrees of freedom (from appendix D). Round represented values of off-mode power consumption to the nearest watt.

(ii) *SEER, EER, and HSPF.* Any represented value of the energy efficiency or other measure of energy consumption for which consumers would favor higher values shall be less than or equal to the lower of:

(A) The mean of the sample, where:

$$\bar{x} = \frac{1}{n} \sum_{i=1}^n x_i$$

and, \bar{x} is the sample mean; n is the number of samples; and x_i is the i^{th} sample; or,

(B) The lower 90 percent confidence limit (LCL) of the true mean divided by 0.95, where:

$$LCL = \bar{x} - t_{.90} \left(\frac{s}{\sqrt{n}} \right)$$

And \bar{x} is the sample mean; s is the sample standard deviation; n is the number of samples; and $t_{0.90}$ is the t statistic for a 90 percent one-tailed

confidence interval with n – 1 degrees of freedom (from Appendix D). Round represented values of EER, SEER, and HSPF to the nearest 0.05.

(iii) *Cooling Capacity.* The represented value of cooling capacity must be a self-declared value that is no less than 95 percent of the mean of the cooling capacities measured for the units in the sample, rounded:

(A) To the nearest 100 Btu/h if cooling capacity is less than 20,000 Btu/h,

(B) To the nearest 200 Btu/h if cooling capacity is greater than or equal to 20,000 Btu/h but less than 38,000 Btu/h, and

(C) To the nearest 500 Btu/h if cooling capacity is greater than or equal to 38,000 Btu/h and less than 65,000 Btu/h.

(iv) *Heating Capacity.* The represented value of heating capacity must be a self-declared value that is no less than 95 percent of the mean of the heating capacities measured for the units in the sample, rounded:

(A) To the nearest 100 Btu/h if heating capacity is less than 20,000 Btu/h,

(B) To the nearest 200 Btu/h if heating capacity is greater than or equal to 20,000 Btu/h but less than 38,000 Btu/h, and

(C) To the nearest 500 Btu/h if heating capacity is greater than or equal to 38,000 Btu/h and less than 65,000 Btu/h.

(c) *Determination of represented values for all other individual models/combinations besides those specified in paragraph (b)(2) of this section—(1) All basic models except outdoor units with no match and multi-split systems, multi-circuit systems, and multi-head mini-split systems.* (i) For every individual model/combination within a basic model other than the individual model/

combination required to be tested pursuant to paragraph (b)(2) of this section, either—

(A) A sample of sufficient size, comprised of production units or representing production units, must be tested as complete systems with the resulting represented values for the individual model/combination obtained in accordance with paragraphs (b)(1) and (3) of this section; or

(B) The represented values of the measures of energy efficiency or energy consumption must be assigned through the application of an AEDM in accordance with paragraph (d) of this section and § 429.70. An AEDM may only be used to rate individual models/combinations in a basic model other than the individual model/combination required for mandatory testing under paragraph (b)(2)(i) of this section. No basic model may be rated with an AEDM (except for determination of $P_{W,OFF}$).

(ii) For every individual model/combination within a basic model tested pursuant to paragraph (b)(2) of this section, but for which $P_{W,OFF}$ testing was not conducted, the represented value of $P_{W,OFF}$ may be assigned through, either:

(A) The testing result from an individual model/combination of similar off-mode construction, or

(B) The application of an AEDM in accordance with paragraph (d) of this section and § 429.70.

(2) *Outdoor units with no match.* All models of outdoor unit within a basic model must be tested. No model of outdoor unit may be rated with an AEDM.

(3) *Multi-split systems, multi-circuit systems, and multi-head mini-split systems.* The following applies:

(i) For basic models composed of both non-ducted and ducted combinations, the represented value for the mixed non-ducted/ducted combination is the mean of the represented values for the non-ducted and ducted combinations as determined in accordance with paragraph (b)(3)(i) of this section.

(ii) For basic models composed of both SDHV and non-ducted or ducted combinations, the represented value for the mixed SDHV/non-ducted or SDHV/ducted combination is the mean of the

represented values for the SDHV, non-ducted, or ducted combinations, as applicable, as determined in accordance with paragraph (b)(3)(i) of this section.

(iii) All other individual combinations of models of indoor units for the same model of outdoor unit for which the manufacturer chooses to make representations must be rated as separate basic models, and the provisions in paragraphs (b)(1) through (3) and (c)(3)(i) and (ii) of this section apply.

(iv) For every individual combination (or “tested combination”) within a basic model tested pursuant to paragraph (b)(2) of this section, but for which $P_{W,OFF}$ testing was not conducted, the representative values of $P_{W,OFF}$ may be assigned through either:

(A) The testing result from an individual combination (or “tested combination”) of similar off-mode construction, or

(B) Application of an AEDM in accordance with paragraph (d) of this section and § 429.70. No basic model may be rated with an AEDM for SEER, EER, or HSPF.

(d) *Alternative efficiency determination methods.* In lieu of testing, represented values of efficiency or consumption may be determined through the application of an AEDM pursuant to the requirements of § 429.70(e) and the provisions of this section.

(1) *Power or energy consumption.* Any represented value of the average off mode power consumption or other measure of energy consumption of an individual model/combination for which consumers would favor lower values must be greater than or equal to the output of the AEDM but no less than the standard.

(2) *Energy efficiency.* Any represented value of the SEER, EER, HSPF or other measure of energy efficiency of an individual model/combination for which consumers would favor higher values must be less than or equal to the output of the AEDM but no greater than the standard.

(3) *Cooling capacity.* The represented value of cooling capacity of an individual model/combination must be

no less than 95% of the cooling capacity output simulated by the AEDM.

(4) *Heating capacity.* The represented value of heating capacity of an individual model/combination must be no less than 95% of the heating capacity output simulated by the AEDM.

(e) *Certification reports.* This paragraph specifies the information that must be included in a certification report.

(1) *General.* The requirements of § 429.12 apply to central air conditioners and heat pumps.

(2) *Public product-specific information.* Pursuant to § 429.12(b)(13), for each individual model (for single-package systems) or individual combination (for split-systems, including “tested combinations” for multi-split, multi-circuit, and multi-head mini-split systems), a certification report must include the following public product-specific information: The seasonal energy efficiency ratio (SEER in British thermal units per Watt-hour (Btu/W-h)); the average off mode power consumption ($P_{W,OFF}$ in Watts); the cooling capacity in British thermal units per hour (Btu/h); the region(s) in which the basic model can be sold; and

(i) For heat pumps, the heating seasonal performance factor (HSPF in British thermal units per Watt-hour (Btu/W-h));

(ii) For air conditioners (excluding space constrained), the energy efficiency ratio (EER in British thermal units per Watt-hour (Btu/W-h));

(iii) For single-split-system equipment, whether the represented value is for a coil-only or blower coil system; and

(iv) For multi-split, multiple-circuit, and multi-head mini-split systems (including VRF), whether the represented value is for a non-ducted, ducted, mixed non-ducted/ducted system, SDHV, mixed non-ducted/SDHV system, or mixed ducted/SDHV system.

(3) *Basic and individual model numbers.* The basic model number and individual model number(s) required to be reported under § 429.12(b)(6) must consist of the following:

Equipment type	Basic model number	Individual model number(s)		
		1	2	3
Single-Package (including Space-Constrained).	Number unique to the basic model.	Package	N/A	N/A.
Single-Split System (including Space-Constrained).	Number unique to the basic model.	Outdoor Unit	Indoor Unit	Air Mover (could be same as indoor unit if fan is part of indoor unit model number).

Equipment type	Basic model number	Individual model number(s)		
		1	2	3
Multi-Split, Multi-Circuit, and Multi-Head Mini-Split System (including SDHV).	Number unique to the basic model.	Outdoor Unit	When certifying a basic model based on tested combination(s): ***. When certifying an individual combination: Indoor Unit(s).	When certifying a basic model based on tested combination(s): *** When certifying an individual combination: Air Mover(s).
Outdoor Unit with No Match.	Number unique to the basic model.	Outdoor Unit	N/A	N/A.

(4) *Additional product-specific information.* Pursuant to § 429.12(b)(13), for each individual model/combination (or “tested combination”), a certification report must include the following additional product-specific information: the cooling full load air volume rate for the system or for each indoor unit as applicable (in cubic feet per minute (cfm)); the air volume rates for other test conditions including minimum cooling air volume rate, intermediate cooling air volume rate, full load heating air volume rate, minimum heating air volume rate, intermediate heating air volume rate, and nominal heating air volume rate (cfm) for the system or for each indoor unit as applicable, if different from the cooling full load air volume rate; whether the individual model/combination uses a fixed orifice, thermostatic expansion valve, electronic expansion valve, or other type of metering device; the duration of the compressor break-in period, if used; whether the optional tests were conducted to determine the C_D^c value used to represent cooling mode cycling losses or whether the default value was used; the temperature at which the crankcase heater with controls is designed to turn on, if applicable; the maximum time between defrosts as allowed by the controls (in hours); and

(i) For heat pumps, whether the optional tests were conducted to determine the C_D^c value or whether the default value was used;

(ii) For multi-split, multiple-circuit, and multi-head mini-split systems, the number of indoor units tested with the outdoor unit; the nominal cooling capacity of each indoor unit and outdoor unit in the combination; and the indoor units that are not providing heating or cooling for part-load tests;

(iii) For ducted systems having multiple indoor fans within a single indoor unit, the number of indoor fans; the nominal cooling capacity of the indoor unit and outdoor unit; and which fan(s) were operating and the allocation of the air volume rate to each operational fan for each operating mode used to determine represented values;

(iv) For blower coil systems, the airflow-control settings associated with full load cooling operation; and the airflow-control settings or alternative instructions for setting fan speeds for tests other than full load cooling operation to the speeds upon which the represented value is based;

(v) For equipment with time-adaptive defrost control, the frosting interval to be used during frost accumulation tests and the procedure for manually initiating the defrost at the specified time;

(vi) For models of indoor units designed for both horizontal and vertical installation or for both up-flow and down-flow vertical installations, the orientation used for testing;

(vii) For variable speed equipment, the compressor frequency set points, and the required dip switch/control settings for step or variable components; and

(viii) For variable speed heat pumps, whether the unit controls restrict use of minimum compressor speed operation for some range of operating ambient conditions, whether the unit controls restrict use of maximum compressor speed operation for any ambient temperatures below 17 °F, and whether the optional H4₂ low temperature test was used to characterize performance at temperatures below 17 °F.

(f) *Represented values for the Federal Trade Commission.* The following represented value determinations shall be followed to meet the requirements of the Federal Trade Commission.

(1) *Annual Operating Cost—Cooling.* Determine the represented value of estimated annual operating cost for cooling-only units or the cooling portion of the estimated annual operating cost for air-source heat pumps that provide both heating and cooling by calculating the product of:

(i) The quotient of the represented value of cooling capacity, in Btu’s per hour as determined in paragraph (b)(3)(iii) of this section, divided by the represented value of SEER, in Btu’s per watt-hour, as determined in paragraph (b)(3)(ii) of this section;

(ii) The representative average use cycle for cooling of 1,000 hours per year;

(iii) A conversion factor of 0.001 kilowatt per watt; and

(iv) The representative average unit cost of electricity in dollars per kilowatt-hour as provided pursuant to section 323(b)(2) of the Act.

(2) *Annual Operating Cost—Heating.* Determine the represented value of estimated annual operating cost for air-source heat pumps that provide only heating or for the heating portion of the estimated annual operating cost for air-source heat pumps that provide both heating and cooling, as the product of:

(i) The quotient of the mean of the standardized design heating requirement for the sample, in Btu’s per hour, nearest to the Region IV minimum design heating requirement, determined for each unit in the sample in section 4.2 of appendix M to subpart B of part 430, divided by the represented value of heating seasonal performance factor (HSPF), in Btu’s per watt-hour, calculated for Region IV corresponding to the above-mentioned standardized design heating requirement, as determined in paragraph (b)(3)(ii) of this section;

(ii) The representative average use cycle for heating of 2,080 hours per year;

(iii) The adjustment factor of 0.77, which serves to adjust the calculated design heating requirement and heating load hours to the actual load experienced by a heating system;

(iv) A conversion factor of 0.001 kilowatt per watt; and

(v) The representative average unit cost of electricity in dollars per kilowatt-hour as provided pursuant to section 323(b)(2) of the Act.

(3) *Annual Operating Cost—Total.* Determine the represented value of estimated annual operating cost for air-source heat pumps that provide both heating and cooling by calculating the sum of the quantity determined in paragraph (f)(1) of this section added to the quantity determined in paragraph (f)(2) of this section.

(4) *Regional Annual Operating Cost—Cooling.* Determine the represented value of estimated regional annual operating cost for cooling-only units or the cooling portion of the estimated regional annual operating cost for air-source heat pumps that provide both heating and cooling by calculating the product of:

(i) The quotient of the represented value of cooling capacity, in Btu's per hour, determined in paragraph (b)(3)(iii) of this section divided by the represented value of SEER, in Btu's per watt-hour, determined in paragraph (b)(3)(ii) of this section;

(ii) The estimated number of regional cooling load hours per year determined from Table 21 in section 4.4 of appendix M to subpart B of part 430;

(iii) A conversion factor of 0.001 kilowatts per watt; and

(iv) The representative average unit cost of electricity in dollars per kilowatt-hour as provided pursuant to section 323(b)(2) of the Act.

(5) *Regional Annual Operating Cost—Heating.* Determine the represented value of estimated regional annual operating cost for air-source heat pumps that provide only heating or for the heating portion of the estimated regional annual operating cost for air-source heat pumps that provide both heating and cooling as the product of:

(i) The estimated number of regional heating load hours per year determined from Table 21 in section 4.4 of appendix M to subpart B of part 430;

(ii) The quotient of the mean of the standardized design heating requirement for the sample, in Btu's per hour, for the appropriate generalized climatic region of interest (*i.e.*, corresponding to the regional heating load hours from "A") and determined for each unit in the sample in section 4.2 of appendix M to subpart B of Part 430, divided by the represented value of HSPF, in Btu's per watt-hour, calculated for the appropriate generalized climatic region of interest and corresponding to the above-mentioned standardized design heating requirement, and determined in paragraph (b)(3)(iii);

(iii) The adjustment factor of 0.77; which serves to adjust the calculated design heating requirement and heating load hours to the actual load experienced by a heating system;

(iv) A conversion factor of 0.001 kilowatts per watt; and

(v) The representative average unit cost of electricity in dollars per kilowatt-hour as provided pursuant to section 323(b)(2) of the Act; and

(6) *Regional Annual Operating Cost—Total.* For air-source heat pumps that provide both heating and cooling, the

estimated regional annual operating cost is the sum of the quantity determined in paragraph (f)(4) of this section added to the quantity determined in paragraph (f)(5) of this section.

(7) *Annual Operating Cost—Rounding.* Round any represented values of estimated annual operating cost determined in paragraphs (f)(1) through (6) of this section to the nearest dollar per year.

4. Section 429.70 is amended by revising paragraph (e) to read as follows:

§ 429.70 Alternative methods for determining energy efficiency or energy use.

* * * * *

(e) *Alternate Efficiency Determination Method (AEDM) for central air conditioners and heat pumps.* This paragraph (e) sets forth the requirements for a manufacturer to use an AEDM to rate central air conditioners and heat pumps.

(1) *Criteria an AEDM must satisfy.* A manufacturer may not apply an AEDM to an individual model/combination to determine its represented values (SEER, EER, HSPF, and/or $P_{W,OFF}$) pursuant to this section unless authorized pursuant to § 429.16(d) and:

(i) The AEDM is derived from a mathematical model that estimates the energy efficiency or energy consumption characteristics of the individual model or combination (SEER, EER, HSPF, and/or $P_{W,OFF}$) as measured by the applicable DOE test procedure; and

(ii) The manufacturer has validated the AEDM in accordance with paragraph (e)(2) of this section.

(2) *Validation of an AEDM.* Before using an AEDM, the manufacturer must validate the AEDM's accuracy and reliability as follows:

(i) The manufacturer must complete testing of each basic model as required under § 429.16(b)(2). Using the AEDM, calculate the energy use or efficiency for each of the tested individual models/combinations within each basic model. Compare the represented value based on testing and the AEDM energy use or efficiency output according to paragraph (e)(2)(ii) of this section. The manufacturer is responsible for ensuring the accuracy and reliability of the AEDM.

(ii) *Individual model/combination tolerances.* This paragraph (e)(2)(ii) provides the tolerances applicable to individual models/combinations rated using an AEDM.

(A) The predicted represented values for each individual model/combination calculated by applying the AEDM may not be more than four percent greater

(for measures of efficiency) or less (for measures of consumption) than the values determined from the corresponding test of the individual model/combination.

(B) The predicted energy efficiency or consumption for each individual model/combination calculated by applying the AEDM must meet or exceed the applicable federal energy conservation standard.

(iii) *Additional test unit requirements.* (A) Each AEDM must be supported by test data obtained from physical tests of current individual models/combinations; and

(B) Test results used to validate the AEDM must meet or exceed current, applicable Federal standards as specified in part 430 of this chapter; and

(C) Each test must have been performed in accordance with the applicable DOE test procedure with which compliance is required at the time the individual models/combinations used for validation are distributed in commerce.

(3) *AEDM records retention requirements.* If a manufacturer has used an AEDM to determine representative values pursuant to this section, the manufacturer must have available upon request for inspection by the Department records showing:

(i) The AEDM, including the mathematical model, the engineering or statistical analysis, and/or computer simulation or modeling that is the basis of the AEDM;

(ii) Product information, complete test data, AEDM calculations, and the statistical comparisons from the units tested that were used to validate the AEDM pursuant to paragraph (e)(2) of this section; and

(iii) Product information and AEDM calculations for each individual model/combination to which the AEDM has been applied.

(4) *Additional AEDM requirements.* If requested by the Department, the manufacturer must:

(i) Conduct simulations before representatives of the Department to predict the performance of particular individual models/combinations;

(ii) Provide analyses of previous simulations conducted by the manufacturer; and/or

(iii) Conduct certification testing of individual models or combinations selected by the Department.

(5) *AEDM verification testing.* DOE may use the test data for a given individual model/combination generated pursuant to § 429.104 to verify the represented value determined by an AEDM as long as the following process is followed:

(i) *Selection of units.* DOE will obtain one or more units for test from retail, if available. If units cannot be obtained from retail, DOE will request that a unit be provided by the manufacturer;

(ii) *Lab requirements.* DOE will conduct testing at an independent, third-party testing facility of its choosing. In cases where no third-party laboratory is capable of testing the equipment, testing may be conducted at a manufacturer's facility upon DOE's request.

(iii) *Testing.* At no time during verification testing may the lab and the manufacturer communicate without DOE authorization. If during test set-up or testing, the lab indicates to DOE that it needs additional information regarding a given individual model or combination in order to test in accordance with the applicable DOE test procedure, DOE may organize a meeting between DOE, the manufacturer and the lab to provide such information.

(iv) *Failure to meet certified represented value.* If an individual model/combination tests worse than its certified represented value (*i.e.*, lower than the certified efficiency value or higher than the certified consumption value) by more than 5 percent, or the test results in a different cooling capacity than its certified cooling capacity by more than 5 percent, DOE will notify the manufacturer. DOE will provide the manufacturer with all documentation related to the test set up, test conditions, and test results for the unit. Within the timeframe allotted by DOE, the manufacturer:

(A) May present any and all claims regarding testing validity; and

(B) If not on site for the initial test set-up, must test at least one additional unit of the same individual model or combination obtained from a retail source at its own expense, following the test requirements in § 429.110(a)(3). When testing at an independent lab, the manufacturer may choose to have DOE and the manufacturer present.

(v) *Tolerances.* This paragraph specifies the tolerances DOE will permit when conducting verification testing.

(A) For consumption metrics, the result from a DOE verification test must be less than or equal to 1.05 multiplied by the certified represented value.

(B) For efficiency metrics, the result from a DOE verification test must be greater than or equal to 0.95 multiplied by the certified represented value.

(vi) *Invalid represented value.* If, following discussions with the manufacturer and a retest where applicable, DOE determines that the verification testing was conducted appropriately in accordance with the

DOE test procedure, DOE will issue a determination that the represented values for the basic model are invalid. The manufacturer must conduct additional testing and re-rate and re-certify the individual models/combinations within the basic model that were rated using the AEDM based on all test data collected, including DOE's test data.

(vii) *AEDM use.* This paragraph (e)(5)(vii) specifies when a manufacturer's use of an AEDM may be restricted due to prior invalid represented values.

(A) If DOE has determined that a manufacturer made invalid represented values on individual models/combinations within two or more basic models rated using the manufacturer's AEDM within a 24 month period, the manufacturer must test the least efficient and most efficient individual model/combination within each basic model in addition to the individual model/combination specified in § 429.16(b)(2). The twenty-four month period begins with a DOE determination that a represented value is invalid through the process outlined above.

(B) If DOE has determined that a manufacturer made invalid represented values on more than four basic models rated using the manufacturer's AEDM within a 24-month period, the manufacturer may no longer use an AEDM.

(C) If a manufacturer has lost the privilege of using an AEDM, the manufacturer may regain the ability to use an AEDM by:

(1) Investigating and identifying cause(s) for failures;

(2) Taking corrective action to address cause(s);

(3) Performing six new tests per basic model, a minimum of two of which must be performed by an independent, third-party laboratory from units obtained from retail to validate the AEDM; and

(4) Obtaining DOE authorization to resume use of an AEDM.

* * * * *

■ 5. Section 429.134 is amended by adding paragraph (k) to read as follows:

§ 429.134 Product-specific enforcement provisions.

* * * * *

(k) *Central air conditioners and heat pumps—(1) Verification of cooling capacity.* The cooling capacity of each tested unit of the individual model (for single-package systems) or individual combination (for split systems) will be measured pursuant to the test requirements of § 430.23(m) of this chapter. The mean of the

measurement(s) (either the measured cooling capacity for a single unit sample or the average of the measured cooling capacities for a multiple unit sample) will be used to determine the applicable standards for purposes of compliance.

(2) *Verification of C_D value.* (i) For central air conditioners and heat pumps other than models of outdoor units with no match, if manufacturers certify that they did not conduct the optional tests to determine the C_D^c and/or C_D^h value for an individual model (for single-package systems) or individual combination (for split systems), as applicable, the default C_D^c and/or C_D^h value will be used as the basis for calculation of SEER or HSPF for each unit tested. If manufacturers certify that they conducted the optional tests to determine the C_D^c and/or C_D^h value for an individual model (for single-package systems) or individual combination (for split systems), as applicable, the C_D^c and/or C_D^h value will be measured pursuant to the test requirements of § 430.23(m) of this chapter for each unit tested and the result for each unit tested (either the tested value or the default value, as selected according to the criteria for the cyclic test in 10 CFR part 430, subpart B, appendix M, section 3.5e) used as the basis for calculation of SEER or HSPF for that unit.

(ii) For models of outdoor units with no match, DOE will use the default C_D^c and/or C_D^h value pursuant to 10 CFR part 430.

* * * * *

PART 430—ENERGY CONSERVATION PROGRAM FOR CONSUMER PRODUCTS

■ 6. The authority citation for part 430 continues to read as follows:

Authority: 42 U.S.C. 6291–6309; 28 U.S.C. 2461 note.

■ 7. Section 430.2 is amended by:

■ a. Removing the definition of “ARM/simulation adjustment factor;”

■ b. Revising the definitions of “basic model” and “central air conditioner;” and

■ c. Removing the definitions of “coil family,” “condenser-evaporator coil combination,” “condensing unit,” “evaporator coil,” “heat pump,” “indoor unit,” “outdoor unit,” “small duct, high velocity system,” and “tested combination.”

The revisions read as follows:

§ 430.2 Definitions.

* * * * *

Basic model means all units of a given type of covered product (or class thereof) manufactured by one manufacturer; having the same primary

energy source; and, which have essentially identical electrical, physical, and functional (or hydraulic) characteristics that affect energy consumption, energy efficiency, water consumption, or water efficiency; and

(1) With respect to general service fluorescent lamps, general service incandescent lamps, and incandescent reflector lamps: Lamps that have essentially identical light output and electrical characteristics—including lumens per watt (lm/W) and color rendering index (CRI).

(2) With respect to faucets and showerheads: Have the identical flow control mechanism attached to or installed within the fixture fittings, or the identical water-passage design features that use the same path of water in the highest flow mode.

(3) With respect to furnace fans: Are marketed and/or designed to be installed in the same type of installation; and

(4) With respect to central air conditioners and central air conditioning heat pumps essentially identical electrical, physical, and functional (or hydraulic) characteristics means:

(i) For split systems manufactured by outdoor unit manufacturers (OUMs): all individual combinations having the same model of outdoor unit, which means comparably performing compressor(s) [a variation of no more than five percent in displacement rate (volume per time) as rated by the compressor manufacturer, and no more than five percent in capacity and power input for the same operating conditions as rated by the compressor manufacturer], outdoor coil(s) [no more than five percent variation in face area and total fin surface area; same fin material; same tube material], and outdoor fan(s) [no more than ten percent variation in air flow and no more than twenty percent variation in power input];

(ii) For split systems having indoor units manufactured by independent coil manufacturers (ICMs): all individual combinations having comparably performing indoor coil(s) [plus or minus one square foot face area, plus or minus one fin per inch fin density, and the same fin material, tube material, number of tube rows, tube pattern, and tube size]; and

(iii) For single-package systems: all individual models having comparably performing compressor(s) [no more than five percent variation in displacement rate (volume per time) rated by the compressor manufacturer, and no more than five percent variations in capacity and power input rated by the

compressor manufacturer corresponding to the same compressor rating conditions], outdoor coil(s) and indoor coil(s) [no more than five percent variation in face area and total fin surface area; same fin material; same tube material], outdoor fan(s) [no more than ten percent variation in outdoor air flow], and indoor blower(s) [no more than ten percent variation in indoor air flow, with no more than twenty percent variation in fan motor power input];

(iv) Except that,

(A) for single-package systems and single-split systems, manufacturers may instead choose to make each individual model/combination its own basic model provided the testing and represented value requirements in 10 CFR 429.16 of this chapter are met; and

(B) For multi-split, multi-circuit, and multi-head mini-split combinations, a basic model may not include both individual small-duct, high velocity (SDHV) combinations and non-SDHV combinations even when they include the same model of outdoor unit. The manufacturer may choose to identify specific individual combinations as additional basic models.

* * * * *
Central air conditioner or central air conditioning heat pump means a product, other than a packaged terminal air conditioner or packaged terminal heat pump, which is powered by single phase electric current, air cooled, rated below 65,000 Btu per hour, not contained within the same cabinet as a furnace, the rated capacity of which is above 225,000 Btu per hour, and is a heat pump or a cooling unit only. A central air conditioner or central air conditioning heat pump may consist of: a single-package unit; an outdoor unit and one or more indoor units; an indoor unit only; or an outdoor unit with no match. In the case of an indoor unit only or an outdoor unit with no match, the unit must be tested and rated as a system (combination of both an indoor and an outdoor unit). For all central air conditioner and central air conditioning heat pump-related definitions, see appendix M of subpart B of this part.
* * * * *

- 8. Section 430.3 is amended by:
- a. Adding paragraph (b)(2);
- b. Revising paragraph (c)(1);
- c. Adding paragraph (c)(3);
- d. Revising paragraph (g)(2);
- e. Removing paragraph (g)(3);
- f. Redesignating paragraph (g)(4) as (g)(3);
- g. Adding a new paragraph (g)(4);
- h. Removing “, M, ” in paragraph (g)(5);
- i. Removing paragraph (g)(10);

- j. Redesignating paragraphs (g)(7) through (9) as (g)(8) through (10);
- k. Adding new paragraph (g)(7);
- l. Revising newly redesignated paragraphs (g)(8) through (10); and
- m. Revising paragraph (g)(13).

The revisions and additions read as follows:

§ 430.3 Materials incorporated by reference.

* * * * *

(b) * * *

(2) ANSI/AMCA 210–07, ANSI/ASHRAE 51–07 (“AMCA 210–2007”), Laboratory Methods of Testing Fans for Certified Aerodynamic Performance Rating, ANSI approved August 17, 2007, Section 8—Report and Results of Test, Section 8.2—Performance graphical representation of test results, IBR approved for appendix M to subpart B, as follows:

- (i) Figure 2A—Static Pressure Tap, and
- (ii) Figure 12—Outlet Chamber Setup—Multiple Nozzles in Chamber.

(c) * * *

(1) ANSI/AHRI 210/240–2008 with Addenda 1 and 2 (“AHRI 210/240–2008”), 2008 Standard for Performance Rating of Unitary Air-Conditioning & Air-Source Heat Pump Equipment, ANSI approved October 27, 2011 (Addendum 1 dated June 2011 and Addendum 2 dated March 2012), IBR approved for appendix M to subpart B, as follows:

- (i) Section 6—Rating Requirements, Section 6.1—Standard Ratings, 6.1.3—Standard Rating Tests, 6.1.3.2—Electrical Conditions;
- (ii) Section 6—Rating Requirements, Section 6.1—Standard Ratings, 6.1.3—Standard Rating Tests, 6.1.3.4—Outdoor-Coil Airflow Rate;
- (iii) Section 6—Rating Requirements, Section 6.1—Standard Ratings, 6.1.3—Standard Rating Tests, 6.1.3.5—Requirements for Separated Assemblies;
- (iv) Figure D1—Tunnel Air Enthalpy Test Method Arrangement;
- (v) Figure D2—Loop Air Enthalpy Test Method Arrangement; and
- (vi) Figure D4—Room Air Enthalpy Test Method Arrangement.

* * * * *

(3) ANSI/AHRI 1230–2010 with Addendum 2 (“AHRI 1230–2010”), 2010 Standard for Performance Rating of Variable Refrigerant Flow (VRF) Multi-Split Air-Conditioning and Heat Pump Equipment (including Addendum 1 dated March 2011), ANSI approved August 2, 2010 (Addendum 2 dated June 2014), IBR approved for appendix M to subpart B, as follows:

- (i) Section 3—Definitions (except 3.8, 3.9, 3.13, 3.14, 3.15, 3.16, 3.23, 3.24, 3.26, 3.27, 3.28, 3.29, 3.30, and 3.31);

(ii) Section 5—Test Requirements, Section 5.1 (untitled), 5.1.3–5.1.4;

(iii) Section 6—Rating Requirements, Section 6.1—Standard Ratings, 6.1.5—Airflow Requirements for Systems with Capacities <65,000 Btu/h [19,000 W];

(iv) Section 6—Rating Requirements, Section 6.1—Standard Ratings, 6.1.6—Outdoor-Coil Airflow Rate (Applies to all Air-to-Air Systems);

(v) Section 6—Rating Requirements, Section 6.2—Conditions for Standard Rating Test for Air-cooled Systems < 65,000 Btu/h [19,000W] (except Table 8); and

(vi) Table 4—Refrigerant Line Length Correction Factors.

* * * * *

(g) * * *

(2) ANSI/ASHRAE 23.1–2010, (“ASHRAE 23.1–2010”), Methods of Testing for Rating the Performance of Positive Displacement Refrigerant Compressors and Condensing Units that Operate at Subcritical Temperatures of the Refrigerant, ANSI approved January 28, 2010, IBR approved for appendix M to subpart B, as follows:

(i) Section 5—Requirements;

(ii) Section 6—Instruments;

(iii) Section 7—Methods of Testing; and

(iv) Section 8—Compressor Testing.

* * * * *

(4) ANSI/ASHRAE Standard 37–2009, (“ANSI/ASHRAE 37–2009”), Methods of Testing for Rating Electrically Driven Unitary Air-Conditioning and Heat Pump Equipment, ANSI approved June 25, 2009, IBR approved for appendix M to subpart B, as follows:

(i) Section 5—Instruments, Section 5.1—Temperature Measuring Instruments: 5.1.1;

(ii) Section 5—Instruments, Section 5.2—Refrigerant, Liquid, and Barometric Pressure Measuring Instruments;

(iii) Section 5—Instruments, Section 5.5—Volatile Refrigerant Flow Measurement;

(iv) Section 6—Airflow and Air Differential Pressure Measurement Apparatus, Section 6.1—Enthalpy Apparatus (Excluding Figure 3): 6.1.1–6.1.2 and 6.1.4;

(v) Section 6—Airflow and Air Differential Pressure Measurement Apparatus, Section 6.2—Nozzle Airflow Measuring Apparatus (Excluding Figure 5);

(vi) Section 6—Airflow and Air Differential Pressure Measurement Apparatus, Section 6.3—Nozzles (Excluding Figure 6);

(vii) Section 6—Airflow and Air Differential Pressure Measurement Apparatus, Section 6.4—External Static Pressure Measurements;

(viii) Section 6—Airflow and Air Differential Pressure Measurement Apparatus, Section 6.5—Recommended Practices for Static Pressure Measurements;

(ix) Section 7—Methods of Testing and Calculation, Section 7.3—Indoor and Outdoor Air Enthalpy Methods (Excluding Table 1);

(x) Section 7—Methods of Testing and Calculation, Section 7.4—Compressor Calibration Method;

(xi) Section 7—Methods of Testing and Calculation, Section 7.5—Refrigerant Enthalpy Method;

(xii) Section 7—Methods of Testing and Calculation, Section 7.7—Airflow Rate Measurement, Section 7.7.2—Calculations—Nozzle Airflow Measuring Apparatus (Excluding Figure 10), 7.7.2.1–7.7.2.2;

(xiii) Section 8—Test Procedures, Section 8.1—Test Room Requirements: 8.1.2–8.1.3;

(xiv) Section 8—Test Procedures, Section 8.2—Equipment Installation;

(xv) Section 8—Test Procedures, Section 8.6—Additional Requirements for the Outdoor Air Enthalpy Method, Section 8.6.2;

(xvi) Section 8—Test Procedures, Section 8.6—Additional Requirements for the Outdoor Air Enthalpy Method, Table 2a—Test Tolerances (SI Units), and

(xvii) Section 8—Test Procedures, Section 8.6—Additional Requirements for the Outdoor Air Enthalpy Method, Table 2b—Test Tolerances (I-P Units);

(xviii) Section 8—Test Procedures, Section 8.6—Additional Requirements for the Outdoor Air Enthalpy Method, Table 2b—Test Tolerances (I-P Units);

(xix) Section 9—Data to be Recorded, Section 9.2—Test Tolerances; and

(xx) Section 9—Data to be Recorded, Table 3—Data to be Recorded.

* * * * *

(7) ANSI/ASHRAE Standard 41.1–2013, (“ANSI/ASHRAE 41.1–2013”), Standard Method for Temperature Measurement, ANSI approved January 30, 2013, IBR approved for appendix M to subpart B, as follows:

(i) Section 4—Classifications;

(ii) Section 5—Requirements, Section 5.3—Airstream Temperature Measurements;

(iii) Section 6—Instruments; and

(iv) Section 7—Temperature Test Methods (Informative).

(8) ANSI/ASHRAE Standard 41.2–1987 (RA 1992), (“ASHRAE 41.2–1987 (RA 1992)”), Standard Methods for Laboratory Airflow Measurement, ANSI reaffirmed April 20, 1992, Section 5—Section of Airflow-Measuring Equipment and Systems, IBR approved for appendix M to subpart B, as follows:

(i) Section 5.2—Test Ducts., Section 5.2.2—Mixers, 5.2.2.1—Performance of Mixers (excluding Figures 11 and 12 and Table 1); and

(ii) Figure 14—Outlet Chamber Setup for Multiple Nozzles in Chamber.

(9) ANSI/ASHRAE Standard 41.6–2014, (“ASHRAE 41.6–2014”), Standard Method for Humidity Measurement, ANSI approved July 3, 2014, IBR approved for appendix M to subpart B, as follows:

(i) Section 4—Classifications;

(ii) Section 5—Requirements;

(iii) Section 6—Instruments and Calibration; and

(iv) Section 7—Humidity Measurement Methods.

(10) ANSI/ASHRAE 41.9–2011, (“ASHRAE 41.9–2011”), Standard Methods for Volatile-Refrigerant Mass Flow Measurements Using Calorimeters, ANSI approved February 3, 2011, IBR approved for appendix M to subpart B, as follows:

(i) Section 5—Requirements;

(ii) Section 6—Instruments;

(iii) Section 7—Secondary Refrigerant Calorimeter Method;

(iv) Section 8—Secondary Fluid Calorimeter Method;

(v) Section 9—Primary Refrigerant Calorimeter Method; and

(vi) Section 11—Lubrication Circulation Measurements.

* * * * *

(13) ANSI/ASHRAE Standard 116–2010, (“ASHRAE 116–2010”), Methods of Testing for Rating Seasonal Efficiency of Unitary Air Conditioners and Heat Pumps, ANSI approved February 24, 2010, Section 7—Methods of Test, Section 7.4—Air Enthalpy Method—Indoor Side (Primary Method), Section 7.4.3—Measurements, Section 7.4.3.4—Temperature, Section 7.4.3.4.5, IBR approved for appendix M to subpart B.

* * * * *

■ 9. Section 430.23 is amended by revising paragraph (m) to read as follows:

§ 430.23 Test procedures for the measurement of energy and water consumption.

* * * * *

(m) *Central air conditioners and heat pumps.* (1) Determine cooling capacity must be determined from the steady-state wet-coil test (A or A2 Test), as described in section 3.3 of appendix M to this subpart, and round off:

- (i) To the nearest 50 Btu/h if cooling capacity is less than 20,000 Btu/h,
- (ii) To the nearest 100 Btu/h if cooling capacity is greater than or equal to 20,000 Btu/h but less than 38,000 Btu/h, and
- (iii) To the nearest 250 Btu/h if cooling capacity is greater than or equal to 38,000 Btu/h and less than 65,000 Btu/h.

(2) Determine seasonal energy efficiency ratio (SEER) as described in section 4.1 of appendix M to this subpart, and round off to the nearest 0.025 Btu/W-h.

(3) Determine energy efficiency ratio (EER) as described in section 4.6 of appendix M to this subpart, and round off to the nearest 0.025 Btu/W-h.

(4) Determine heating seasonal performance factors (HSPF) as described in section 4.2 of appendix M to this subpart, and round off to the nearest 0.025 Btu/W-h.

(5) Determine average off mode power consumption as described in section 4.3 of appendix M to this subpart, and round off to the nearest 0.5 W.

(6) Determine sensible heat ratio (SHR), as described in section 4.5 of appendix M to this subpart, and round off to the nearest 0.5 percent (%).

(7) Determine all other measures of energy efficiency or consumption or other useful measures of performance using appendix M of this subpart.

* * * * *

■ 10. Appendix M to subpart B of part 430 is revised to read as follows:

Appendix M to Subpart B of Part 430—Uniform Test Method for Measuring the Energy Consumption of Central Air Conditioners and Heat Pumps

Note: Prior to December 5, 2016, any representations, including compliance certifications, made with respect to the energy use, power, or efficiency of central air conditioners and central air conditioning heat pumps must be based on the results of testing pursuant to either this appendix or the procedures in Appendix M as it appeared at 10 CFR part 430, subpart B, Appendix M, in the 10 CFR parts 200 to 499 edition revised as of January 1, 2015. Any representations made with respect to the energy use or efficiency of such central air conditioners and central air conditioning heat pumps must be in accordance with whichever version is selected.

On or after December 5, 2016 and prior to the compliance date for any amended energy conservation standards, any representations, including compliance certifications, made with respect to the energy use, power, or efficiency of central air conditioners and central air conditioning heat pumps must be based on the results of testing pursuant to this appendix.

On or after the compliance date for any amended energy conservation standards, any representations, including compliance certifications, made with respect to the energy use, power, or efficiency of central air conditioners and central air conditioning heat pumps must be based on the results of testing pursuant to appendix M1 of this subpart.

1. Scope and Definitions

1.1 Scope

This test procedure provides a method of determining SEER, EER, HSPF and $P_{W,OFF}$ for

central air conditioners and central air conditioning heat pumps including the following categories:

(a) Split-system air conditioners, including single-split, multi-head mini-split, multi-split (including VRF), and multi-circuit systems

(b) Split-system heat pumps, including single-split, multi-head mini-split, multi-split (including VRF), and multi-circuit systems

(c) Single-package air conditioners

(d) Single-package heat pumps

(e) Small-duct, high-velocity systems (including VRF)

(f) Space-constrained products—air conditioners

(g) Space-constrained products—heat pumps

For purposes of this appendix, the Department of Energy incorporates by reference specific sections of several industry standards, as listed in § 430.3. In cases where there is a conflict, the language of the test procedure in this appendix takes precedence over the incorporated standards.

All section references refer to sections within this appendix unless otherwise stated.

1.2 Definitions

Airflow-control settings are programmed or wired control system configurations that control a fan to achieve discrete, differing ranges of airflow—often designated for performing a specific function (e.g., cooling, heating, or constant circulation)—without manual adjustment other than interaction with a user-operable control (i.e., a thermostat) that meets the manufacturer specifications for installed-use. For the purposes of this appendix, manufacturer specifications for installed-use are those found in the product literature shipped with the unit.

Air sampling device is an assembly consisting of a manifold with several branch tubes with multiple sampling holes that draws an air sample from a critical location from the unit under test (e.g. indoor air inlet, indoor air outlet, outdoor air inlet, etc.).

Airflow prevention device denotes a device that prevents airflow via natural convection by mechanical means, such as an air damper box, or by means of changes in duct height, such as an upturned duct.

Aspirating psychrometer is a piece of equipment with a monitored airflow section that draws uniform airflow through the measurement section and has probes for measurement of air temperature and humidity.

Blower coil indoor unit means an indoor unit either with an indoor blower housed with the coil or with a separate designated air mover such as a furnace or a modular blower (as defined in appendix AA to the subpart).

Blower coil system refers to a split system that includes one or more blower coil indoor units.

Cased coil means a coil-only indoor unit with external cabinetry.

Coefficient of Performance (COP) means the ratio of the average rate of space heating delivered to the average rate of electrical energy consumed by the heat pump. These rate quantities must be determined from a single test or, if derived via interpolation, must be determined at a single set of

operating conditions. COP is a dimensionless quantity. When determined for a ducted coil-only system, COP must include the sections 3.7 and 3.9.1 of this appendix: default values for the heat output and power input of a fan motor.

Coil-only indoor unit means an indoor unit that is distributed in commerce without an indoor blower or separate designated air mover. A coil-only indoor unit installed in the field relies on a separately-installed furnace or a modular blower for indoor air movement. *Coil-only system* refers to a system that includes only (one or more) coil-only indoor units.

Condensing unit removes the heat absorbed by the refrigerant to transfer it to the outside environment and consists of an outdoor coil, compressor(s), and air moving device.

Constant-air-volume-rate indoor blower means a fan that varies its operating speed to provide a fixed air-volume-rate from a ducted system.

Continuously recorded, when referring to a dry bulb measurement, dry bulb temperature used for test room control, wet bulb temperature, dew point temperature, or relative humidity measurements, means that the specified value must be sampled at regular intervals that are equal to or less than 15 seconds.

Cooling load factor (CLF) means the ratio having as its numerator the total cooling delivered during a cyclic operating interval consisting of one ON period and one OFF period, and as its denominator the total cooling that would be delivered, given the same ambient conditions, had the unit operated continuously at its steady-state, space-cooling capacity for the same total time (ON + OFF) interval.

Crankcase heater means any electrically powered device or mechanism for intentionally generating heat within and/or around the compressor sump volume. Crankcase heater control may be achieved using a timer or may be based on a change in temperature or some other measurable parameter, such that the crankcase heater is not required to operate continuously. A crankcase heater without controls operates continuously when the compressor is not operating.

Cyclic Test means a test where the unit's compressor is cycled on and off for specific time intervals. A cyclic test provides half the information needed to calculate a degradation coefficient.

Damper box means a short section of duct having an air damper that meets the performance requirements of section 2.5.7 of this appendix.

Degradation coefficient (C_D) means a parameter used in calculating the part load factor. The degradation coefficient for cooling is denoted by C_{D^c}. The degradation coefficient for heating is denoted by C_{D^h}.

Demand-defrost control system means a system that defrosts the heat pump outdoor coil-only when measuring a predetermined degradation of performance. The heat pump's controls either:

(1) Monitor one or more parameters that always vary with the amount of frost accumulated on the outdoor coil (e.g., coil to air differential temperature, coil differential

air pressure, outdoor fan power or current, optical sensors) at least once for every ten minutes of compressor ON-time when space heating or

(2) Operate as a feedback system that measures the length of the defrost period and adjusts defrost frequency accordingly. In all cases, when the frost parameter(s) reaches a predetermined value, the system initiates a defrost. In a demand-defrost control system, defrosts are terminated based on monitoring a parameter(s) that indicates that frost has been eliminated from the coil. (Note: Systems that vary defrost intervals according to outdoor dry-bulb temperature are not demand-defrost systems.) A demand-defrost control system, which otherwise meets the above requirements, may allow time-initiated defrosts if, and only if, such defrosts occur after 6 hours of compressor operating time.

Design heating requirement (DHR) predicts the space heating load of a residence when subjected to outdoor design conditions. Estimates for the minimum and maximum DHR are provided for six generalized U.S. climatic regions in section 4.2 of this appendix.

Dry-coil tests are cooling mode tests where the wet-bulb temperature of the air supplied to the indoor unit is maintained low enough that no condensate forms on the evaporator coil.

Ducted system means an air conditioner or heat pump that is designed to be permanently installed equipment and delivers conditioned air to the indoor space through a duct(s). The air conditioner or heat pump may be either a split-system or a single-package unit.

Energy efficiency ratio (EER) means the ratio of the average rate of space cooling delivered to the average rate of electrical energy consumed by the air conditioner or heat pump. These rate quantities must be determined from a single test or, if derived via interpolation, must be determined at a single set of operating conditions. EER is expressed in units of Btu/h. When determined for a ducted coil-only system, EER must include, from this appendix, the section 3.3 and 3.5.1 default values for the heat output and power input of a fan motor.

Evaporator coil means an assembly that absorbs heat from an enclosed space and transfers the heat to a refrigerant.

Heat pump means a kind of central air conditioner that utilizes an indoor conditioning coil, compressor, and refrigerant-to-outdoor air heat exchanger to provide air heating, and may also provide air cooling, air dehumidifying, air humidifying, air circulating, and air cleaning.

Heat pump having a heat comfort controller means a heat pump with controls that can regulate the operation of the electric resistance elements to assure that the air temperature leaving the indoor section does not fall below a specified temperature. Heat pumps that actively regulate the rate of electric resistance heating when operating below the balance point (as the result of a second stage call from the thermostat) but do not operate to maintain a minimum delivery temperature are not considered as having a heat comfort controller.

Heating load factor (HLF) means the ratio having as its numerator the total heating

delivered during a cyclic operating interval consisting of one ON period and one OFF period, and its denominator the heating capacity measured at the same test conditions used for the cyclic test, multiplied by the total time interval (ON plus OFF) of the cyclic-test.

Heating season means the months of the year that require heating, e.g., typically, and roughly, October through April.

Heating seasonal performance factor (HSPF) means the total space heating required during the heating season, expressed in Btu's, divided by the total electrical energy consumed by the heat pump system during the same season, expressed in watt-hours. The HSPF used to evaluate compliance with 10 CFR 430.32(c) is based on Region IV, the minimum standardized design heating requirement, and the sampling plan stated in 10 CFR 429.16(a).

Independent coil manufacturer (ICM) means a manufacturer that manufactures indoor units but does not manufacture single-package units or outdoor units.

Indoor unit means a separate assembly of a split system that includes—

- (1) An arrangement of refrigerant-to-air heat transfer coil(s) for transfer of heat between the refrigerant and the indoor air,
- (2) A condensate drain pan, and may or may not include
- (3) Sheet metal or plastic parts not part of external cabinetry to direct/route airflow over the coil(s),
- (4) A cooling mode expansion device,
- (5) External cabinetry, and
- (6) An integrated indoor blower (i.e. a device to move air including its associated motor). A separate designated air mover that may be a furnace or a modular blower (as defined in appendix AA to the subpart) may be considered to be part of the indoor unit. A service coil is not an indoor unit.

Multi-head mini-split system means a split system that has one outdoor unit and that has two or more indoor units connected with a single refrigeration circuit. The indoor units operate in unison in response to a single indoor thermostat.

Multiple-circuit (or multi-circuit) system means a split system that has one outdoor unit and that has two or more indoor units installed on two or more refrigeration circuits such that each refrigeration circuit serves a compressor and one and only one indoor unit, and refrigerant is not shared from circuit to circuit.

Multiple-split (or multi-split) system means a split system that has one outdoor unit and two or more coil-only indoor units and/or blower coil indoor units connected with a single refrigerant circuit. The indoor units operate independently and can condition multiple zones in response to at least two indoor thermostats or temperature sensors. The outdoor unit operates in response to independent operation of the indoor units based on control input of multiple indoor thermostats or temperature sensors, and/or based on refrigeration circuit sensor input (e.g., suction pressure).

Nominal capacity means the capacity that is claimed by the manufacturer on the product name plate. Nominal cooling capacity is approximate to the air conditioner

cooling capacity tested at A or A2 condition. Nominal heating capacity is approximate to the heat pump heating capacity tested in H12 test (or the optional H1N test).

Non-ducted indoor unit means an indoor unit that is designed to be permanently installed, mounted on room walls and/or ceilings, and that directly heats or cools air within the conditioned space.

Normalized Gross Indoor Fin Surface (NGIFS) means the gross fin surface area of the indoor unit coil divided by the cooling capacity measured for the A or A2 Test, whichever applies.

Off-mode power consumption means the power consumption when the unit is connected to its main power source but is neither providing cooling nor heating to the building it serves.

Off-mode season means, for central air conditioners other than heat pumps, the shoulder season and the entire heating season; and for heat pumps, the shoulder season only.

Outdoor unit means a separate assembly of a split system that transfers heat between the refrigerant and the outdoor air, and consists of an outdoor coil, compressor(s), an air moving device, and in addition for heat pumps, may include a heating mode expansion device, reversing valve, and/or defrost controls.

Outdoor unit manufacturer (OUM) means a manufacturer of single-package units, outdoor units, and/or both indoor units and outdoor units.

Part-load factor (PLF) means the ratio of the cyclic EER (or COP for heating) to the steady-state EER (or COP), where both EERs (or COPs) are determined based on operation at the same ambient conditions.

Seasonal energy efficiency ratio (SEER) means the total heat removed from the conditioned space during the annual cooling season, expressed in Btu's, divided by the total electrical energy consumed by the central air conditioner or heat pump during the same season, expressed in watt-hours.

Service coil means an arrangement of refrigerant-to-air heat transfer coil(s), condensate drain pan, sheet metal or plastic parts to direct/route airflow over the coil(s), which may or may not include external cabinetry and/or a cooling mode expansion device, distributed in commerce solely for the intent of replacing an uncased coil or cased coil that has already been placed into service, and that has been labeled accordingly by the manufacturer.

Shoulder season means the months of the year in between those months that require cooling and those months that require heating, e.g., typically, and roughly, April through May, and September through October.

Single-package unit means any central air conditioner or heat pump that has all major assemblies enclosed in one cabinet.

Single-split system means a split system that has one outdoor unit and one indoor unit connected with a single refrigeration circuit. *Small-duct, high-velocity system* means a split system for which all indoor units are blower coil indoor units that produce at least 1.2 inches (of water column) of external static pressure when operated at

the full-load air volume rate certified by the manufacturer of at least 220 scfm per rated ton of cooling.

Split system means any air conditioner or heat pump that has at least two separate assemblies that are connected with refrigerant piping when installed. One of these assemblies includes an indoor coil that exchanges heat with the indoor air to provide heating or cooling, while one of the others includes an outdoor coil that exchanges heat with the outdoor air. Split systems may be either blower coil systems or coil-only systems.

Standard Air means dry air having a mass density of 0.075 lb/ft³.

Steady-state test means a test where the test conditions are regulated to remain as constant as possible while the unit operates continuously in the same mode.

Temperature bin means the 5 °F increments that are used to partition the outdoor dry-bulb temperature ranges of the cooling (≥65 °F) and heating (<65 °F) seasons.

Test condition tolerance means the maximum permissible difference between the average value of the measured test parameter and the specified test condition.

Test operating tolerance means the maximum permissible range that a measurement may vary over the specified test interval. The difference between the maximum and minimum sampled values must be less than or equal to the specified test operating tolerance.

Tested combination means a multi-head mini-split, multi-split, or multi-circuit system having the following features:

(1) The system consists of one outdoor unit with one or more compressors matched with between two and five indoor units;

(2) The indoor units must:

(i) Collectively, have a nominal cooling capacity greater than or equal to 95 percent and less than or equal to 105 percent of the nominal cooling capacity of the outdoor unit;

(ii) Each represent the highest sales volume model family, if this is possible while meeting all the requirements of this section. If this is not possible, one or more of the indoor units may represent another indoor model family in order that all the other requirements of this section are met.

(iii) Individually not have a nominal cooling capacity greater than 50 percent of the nominal cooling capacity of the outdoor unit, unless the nominal cooling capacity of the outdoor unit is 24,000 Btu/h or less;

(iv) Operate at fan speeds consistent with manufacturer's specifications; and

(v) All be subject to the same minimum external static pressure requirement while able to produce the same external static pressure at the exit of each outlet plenum when connected in a manifold configuration as required by the test procedure.

(3) Where referenced, "nominal cooling capacity" means, for indoor units, the highest cooling capacity listed in published product literature for 95 °F outdoor dry bulb temperature and 80 °F dry bulb, 67 °F wet bulb indoor conditions, and for outdoor units, the lowest cooling capacity listed in published product literature for these conditions. If incomplete or no operating conditions are published, the highest (for

indoor units) or lowest (for outdoor units) such cooling capacity available for sale must be used.

Time-adaptive defrost control system is a demand-defrost control system that measures the length of the prior defrost period(s) and uses that information to automatically determine when to initiate the next defrost cycle.

Time-temperature defrost control systems initiate or evaluate initiating a defrost cycle only when a predetermined cumulative compressor ON-time is obtained. This predetermined ON-time is generally a fixed value (e.g., 30, 45, 90 minutes) although it may vary based on the measured outdoor dry-bulb temperature. The ON-time counter accumulates if controller measurements (e.g., outdoor temperature, evaporator temperature) indicate that frost formation conditions are present, and it is reset/remains at zero at all other times. In one application of the control scheme, a defrost is initiated whenever the counter time equals the predetermined ON-time. The counter is reset when the defrost cycle is completed.

In a second application of the control scheme, one or more parameters are measured (e.g., air and/or refrigerant temperatures) at the predetermined, cumulative, compressor ON-time. A defrost is initiated only if the measured parameter(s) falls within a predetermined range. The ON-time counter is reset regardless of whether or not a defrost is initiated. If systems of this second type use cumulative ON-time intervals of 10 minutes or less, then the heat pump may qualify as having a demand defrost control system (see definition).

Triple-capacity, northern heat pump means a heat pump that provides two stages of cooling and three stages of heating. The two common stages for both the cooling and heating modes are the low capacity stage and the high capacity stage. The additional heating mode stage is the booster capacity stage, which offers the highest heating capacity output for a given set of ambient operating conditions.

Triple-split system means a split system that is composed of three separate assemblies: An outdoor fan coil section, a blower coil indoor unit, and an indoor compressor section.

Two-capacity (or two-stage) compressor system means a central air conditioner or heat pump that has a compressor or a group of compressors operating with only two stages of capacity. For such systems, low capacity means the compressor(s) operating at low stage, or at low load test conditions. The low compressor stage that operates for heating mode tests may be the same or different from the low compressor stage that operates for cooling mode tests. For such systems, high capacity means the compressor(s) operating at high stage, or at full load test conditions.

Two-capacity, northern heat pump means a heat pump that has a factory or field-selectable lock-out feature to prevent space cooling at high-capacity. Two-capacity heat pumps having this feature will typically have two sets of ratings, one with the feature disabled and one with the feature enabled. The heat pump is a two-capacity northern

heat pump only when this feature is enabled at all times. The certified indoor coil model number must reflect whether the ratings pertain to the lockout enabled option via the inclusion of an extra identifier, such as "+LO". When testing as a two-capacity, northern heat pump, the lockout feature must remain enabled for all tests.

Uncased coil means a coil-only indoor unit without external cabinetry.

Variable refrigerant flow (VRF) system means a multi-split system with at least three compressor capacity stages, distributing refrigerant through a piping network to multiple indoor blower coil units each capable of individual zone temperature control, through proprietary zone temperature control devices and a common communications network. Note: Single-phase VRF systems less than 65,000 Btu/h are central air conditioners and central air conditioning heat pumps.

Variable-speed compressor system means a central air conditioner or heat pump that has a compressor that uses a variable-speed drive to vary the compressor speed to achieve variable capacities.

Wet-coil test means a test conducted at test conditions that typically cause water vapor to condense on the test unit evaporator coil.

2. Testing Overview and Conditions

(A) Test VRF systems using AHRI 1230–2010 (incorporated by reference, see § 430.3) and appendix M. Where AHRI 1230–2010 refers to the appendix C therein substitute the provisions of this appendix. In cases where there is a conflict, the language of the test procedure in this appendix takes precedence over AHRI 1230–2010.

For definitions use section 1 of appendix M and section 3 of AHRI 1230–2010 (incorporated by reference, see § 430.3). For rounding requirements, refer to § 430.23(m). For determination of certified ratings, refer to § 429.16 of this chapter.

For test room requirements, refer to section 2.1 of this appendix. For test unit installation requirements refer to sections 2.2.a, 2.2.b, 2.2.c, 2.2.1, 2.2.2, 2.2.3(a), 2.2.3(c), 2.2.4, 2.2.5, and 2.4 to 2.12 of this appendix, and sections 5.1.3 and 5.1.4 of AHRI 1230–2010. The "manufacturer's published instructions," as stated in section 8.2 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3) and "manufacturer's installation instructions" discussed in this appendix mean the manufacturer's installation instructions that come packaged with or appear in the labels applied to the unit. This does not include online manuals. Installation instructions that appear in the labels applied to the unit take precedence over installation instructions that are shipped with the unit.

For general requirements for the test procedure, refer to section 3.1 of this appendix, except for sections 3.1.3 and 3.1.4, which are requirements for indoor air volume and outdoor air volume. For indoor air volume and outdoor air volume requirements, refer instead to section 6.1.5 (except where section 6.1.5 refers to Table 8, refer instead to Table 3 of this appendix) and 6.1.6 of AHRI 1230–2010.

For the test method, refer to sections 3.3 to 3.5 and 3.7 to 3.13 of this appendix. For cooling mode and heating mode test

conditions, refer to section 6.2 of AHRI 1230–2010. For calculations of seasonal performance descriptors, refer to section 4 of this appendix.

(B) For systems other than VRF, only a subset of the sections listed in this test procedure apply when testing and determining represented values for a particular unit. Table 1 shows the sections of the test procedure that apply to each system. This table is meant to assist manufacturers in finding the appropriate sections of the test procedure; the appendix sections rather than the table provide the specific requirements for testing, and given the varied nature of available units, manufacturers are responsible for determining which sections apply to each unit tested based on the unit's characteristics. To use this table, first refer to the sections listed under "all units". Then refer to additional requirements based on:

- (1) System configuration(s),
- (2) The compressor staging or modulation capability, and
- (3) Any special features.

Testing requirements for space-constrained products do not differ from similar equipment that is not space-constrained and thus are not listed separately in this table. Air conditioners and heat pumps are not listed separately in this table, but heating procedures and calculations apply only to heat pumps.

Table 1—Informative Guidance for Using Appendix M

		Testing conditions	Testing procedures			Calculations		
		General	General	Cooling*	Heating**	General	Cooling*	Heating**
Requirements for all units (except VRF)		2.1; 2.2a-c; 2.2.1; 2.2.4; 2.2.4.1; 2.2.4.1 (1); 2.2.4.2; 2.2.5.1-5; 2.2.5.7-8; 2.3; 2.3.1; 2.3.2; 2.4; 2.4.1a,d; 2.5a-c; 2.5.1; 2.5.2 - 2.5.4.2; 2.5.5 – 2.13	3.1; 3.1.1-3; 3.1.5-9; 3.11; 3.12	3.3; 3.4; 3.5a-i	3.1.4.7; 3.1.10; 3.7a,b,d; 3.8a,d; 3.8.1; 3.9; 3.10	4.4; 4.5	4.1	4.2
Additional Requirements	System Configurations (more than one may apply)	Single-split system – blower coil	2.2a(1)		3.1.4.1.1; 3.1.4.1.1a,b; 3.1.4.2a-b; 3.1.4.3a-b	3.1.4.4.1; 3.1.4.4.2; 3.1.4.4.3a-b; 3.1.4.5.1; 3.1.4.5.2a-c; 3.1.4.6a-b		
		Single-split system - coil-only	2.2a(1); 2.2d,e; 2.4.2		3.1.4.1.1; 3.1.4.1.1c; 3.1.4.2c; 3.5.1	3.1.4.4.1; 3.1.4.4.2; 3.1.4.4.3c; 3.1.4.5.2d; 3.7c; 3.8b; 3.9f; 3.9.1b		
		Tri-split	2.2a(2)					
		Outdoor unit with no match	2.2e					
		Single-package	2.2.4.1(2); 2.2.5.6b; 2.4.2		3.1.4.1.1; 3.1.4.1.1a,b; 3.1.4.2a-b; 3.1.4.3a-b	3.1.4.4.1; 3.1.4.4.2; 3.1.4.4.3a-b; 3.1.4.5.1; 3.1.4.5.2a-c; 3.1.4.6a-b		
		Heat pump	2.2.5.6.a					
		Heating-only heat pump			3.1.4.1.1 Table 4	3.1.4.4.3		

		Two-capacity northern heat pump		3.1.4.4.2c; 3.1.4.5.2 c- d	3.2.3c	3.6.3				
		Triple-capacity northern heat pump			3.2.5	3.6.6			4.2.6	
		SDHV (non-VRF)	2.2b; 2.4.1c; 2.5.4.3							
		Single- zone-multi-coil split and non-VRF multiple-split with duct	2.2a(1),(3); 2.2.3; 2.4.1b			3.1.4.1.1; 3.1.4.1.1a-b; 3.1.4.2a-b; 3.1.4.3a-b	3.1.4.4.1; 3.1.4.4.2; 3.1.4.4.3a-b; 3.1.4.5.1; 3.1.4.5.2a-c; 3.1.4.6a-b			
		Single-zone-multi-coil split and non-VRF multiple-split, ductless	2.2.a(1),(3); 2.2.3			3.1.4.1.2; 3.1.4.2d; 3.1.4.3c; 3.2.4c; 3.5c,g,h; 3.5.2; 3.8c	3.1.4.4.4; 3.1.4.5.2e; 3.1.4.6c; 3.6.4.c; 3.8c			
		VRF multiple-split [†] and VRF SDHV [†]	2.1; 2.2.a; 2.2.b; 2.2.c; 2.2.1; 2.2.2; 2.2.3(a); 2.2.3(c);, 2.2.4; 2.2.5; 2.4- 2.12	3.1 (except 3.1.3, 3.1.4) 3.1.4.1.1c; 3.11-3.13	3.3-3.5	3.7-3.10	4.4; 4.5	4.1	4.2	
	Modulation Capability	Single speed compressor, fixed air volume rate				3.2.1	3.6.1		4.1.1	4.2.1
		Single speed compressor, VAV fan				3.2.2	3.6.2		4.1.2	4.2.2
		Two-capacity compressor		3.1.10	3.2.3	3.6.3		4.1.3	4.2.3	
		Variable speed compressor			3.2.4	3.6.4		4.1.4	4.2.4	
	Special Features	Heat pump with heat comfort controller					3.6.5			4.2.5
		Units with a multi-speed outdoor fan	2.2.2							
		Single indoor unit having multiple indoor blowers				3.2.6	3.6.2; 3.6.7		4.1.5	4.2.7

*Does not apply to heating-only heat pumps.

**Applies only to heat pumps; not to air conditioners.

†Use AHRI 1230-2010 (incorporated by reference, see § 430.3), with the sections referenced in section 2(A) of this appendix, in conjunction with the sections set forth in the table to perform test setup, testing, and calculations for determining represented values for VRF multiple-split and VRF SDHV systems.

NOTE: For all units, use section 3.13 of this appendix for off mode testing procedures and section 4.3 of this appendix for off mode calculations. For all units subject to an EER standard, use section 4.6 of this appendix to determine the energy efficiency ratio.

2.1 Test Room Requirements

a. Test using two side-by-side rooms: An indoor test room and an outdoor test room. For multiple-split, single-zone-multi-coil or multi-circuit air conditioners and heat pumps, however, use as many indoor test rooms as needed to accommodate the total number of indoor units. These rooms must comply with the requirements specified in sections 8.1.2 and 8.1.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3).

b. Inside these test rooms, use artificial loads during cyclic tests and frost accumulation tests, if needed, to produce stabilized room air temperatures. For one room, select an electric resistance heater(s) having a heating capacity that is approximately equal to the heating capacity of the test unit's condenser. For the second room, select a heater(s) having a capacity that is close to the sensible cooling capacity of the test unit's evaporator. Cycle the heater located in the same room as the test unit evaporator coil ON and OFF when the test unit cycles ON and OFF. Cycle the heater located in the same room as the test unit condensing coil ON and OFF when the test unit cycles OFF and ON.

2.2 Test Unit Installation Requirements

a. Install the unit according to section 8.2 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3), subject to the following additional requirements:

(1) When testing split systems, follow the requirements given in section 6.1.3.5 of AHRI 210/240–2008 (incorporated by reference, see § 430.3). For the vapor refrigerant line(s), use the insulation included with the unit; if no insulation is provided, use insulation meeting the specifications for the insulation in the installation instructions included with the unit by the manufacturer; if no insulation is included with the unit and the installation instructions do not contain provisions for insulating the line(s), fully insulate the vapor refrigerant line(s) with vapor proof insulation having an inside diameter that matches the refrigerant tubing and a nominal thickness of at least 0.5 inches. For the liquid refrigerant line(s), use the insulation included with the unit; if no insulation is provided, use insulation meeting the specifications for the insulation in the installation instructions included with the unit by the manufacturer; if no insulation is included with the unit and the installation instructions do not contain provisions for insulating the line(s), leave the liquid refrigerant line(s) exposed to the air for air conditioners and heat pumps that heat and cool; or, for heating-only heat pumps, insulate the liquid refrigerant line(s) with insulation having an inside diameter that matches the refrigerant tubing and a nominal thickness of at least 0.5 inches. Insulation must be the same for the cooling and heating tests.

(2) When testing split systems, if the indoor unit does not ship with a cooling mode expansion device, test the system using the device as specified in the installation instructions provided with the indoor unit. If none is specified, test the system using a fixed orifice or piston type expansion device that is sized appropriately for the system.

(3) When testing triple-split systems (see section 1.2 of this appendix, Definitions), use the tubing length specified in section 6.1.3.5 of AHRI 210/240–2008 (incorporated by reference, see § 430.3) to connect the outdoor coil, indoor compressor section, and indoor coil while still meeting the requirement of exposing 10 feet of the tubing to outside conditions;

(4) When testing split systems having multiple indoor coils, connect each indoor blower coil unit to the outdoor unit using:

- (a) 25 feet of tubing, or
- (b) tubing furnished by the manufacturer, whichever is longer.

At least 10 feet of the system interconnection tubing shall be exposed to the outside conditions. If they are needed to make a secondary measurement of capacity or for verification of refrigerant charge, install refrigerant pressure measuring instruments as described in section 8.2.5 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3). Section 2.10 of this appendix specifies which secondary methods require refrigerant pressure measurements and section 2.2.5.5 of this appendix discusses use of pressure measurements to verify charge. At a minimum, insulate the low-pressure line(s) of a split system with insulation having an inside diameter that matches the refrigerant tubing and a nominal thickness of 0.5 inch.

b. For units designed for both horizontal and vertical installation or for both up-flow and down-flow vertical installations, use the orientation for testing specified by the manufacturer in the certification report. Conduct testing with the following installed:

- (1) The most restrictive filter(s);
- (2) Supplementary heating coils; and
- (3) Other equipment specified as part of the unit, including all hardware used by a heat comfort controller if so equipped (see section 1 of this appendix, Definitions). For small-duct, high-velocity systems, configure all balance dampers or restrictor devices on or inside the unit to fully open or lowest restriction.

c. Testing a ducted unit without having an indoor air filter installed is permissible as long as the minimum external static pressure requirement is adjusted as stated in Table 3, note 3 (see section 3.1.4 of this appendix). Except as noted in section 3.1.10 of this appendix, prevent the indoor air supplementary heating coils from operating during all tests. For uncased coils, create an enclosure using 1 inch fiberglass foil-faced ductboard having a nominal density of 6 pounds per cubic foot. Or alternatively, construct an enclosure using sheet metal or a similar material and insulating material having a thermal resistance ("R" value) between 4 and 6 hr-ft². °F/Btu. Size the enclosure and seal between the coil and/or drainage pan and the interior of the enclosure as specified in installation instructions shipped with the unit. Also seal between the plenum and inlet and outlet ducts. For cased coils, no extra insulating or sealing is allowed.

d. When testing a coil-only system, install a toroidal-type transformer to power the system's low-voltage components, complying with any additional requirements for the transformer mentioned in the installation

manuals included with the unit by the system manufacturer. If the installation manuals do not provide specifications for the transformer, use a transformer having the following features:

(1) A nominal volt-amp rating such that the transformer is loaded between 25 and 90 percent of this rating for the highest level of power measured during the off mode test (section 3.13 of this appendix);

(2) Designed to operate with a primary input of 230 V, single phase, 60 Hz; and

(3) That provides an output voltage that is within the specified range for each low-voltage component. Include the power consumption of the components connected to the transformer as part of the total system power consumption during the off mode tests; do not include the power consumed by the transformer when no load is connected to it.

e. Test an outdoor unit with no match (*i.e.*, that is not distributed in commerce with any indoor units) using a coil-only indoor unit with a single cooling air volume rate whose coil has:

(1) Round tubes of outer diameter no less than 0.375 inches, and

(2) a normalized gross indoor fin surface (NGIFS) no greater than 1.0 square inches per British thermal unit per hour (sq. in./Btu/hr). NGIFS is calculated as follows:

$$NGIFS = 2 \times L_f \times W_f \times N_f + \dot{Q}_c \quad (95)$$

Where:

L_f = Indoor coil fin length in inches, also height of the coil transverse to the tubes.

W_f = Indoor coil fin width in inches, also depth of the coil.

N_f = Number of fins.

$\dot{Q}_c(95)$ = the measured space cooling capacity of the tested outdoor unit/indoor unit combination as determined from the A2 or A Test whichever applies, Btu/h.

f If the outdoor unit or the outdoor portion of a single-package unit has a drain pan heater to prevent freezing of defrost water, the heater shall be energized, subject to control to de-energize it when not needed by the heater's thermostat or the unit's control system, for all tests.

2.2.1 Defrost Control Settings

Set heat pump defrost controls at the normal settings which most typify those encountered in generalized climatic region IV. (Refer to Figure 1 and Table 19 of section 4.2 of this appendix for information on region IV.) For heat pumps that use a time-adaptive defrost control system (see section 1.2 of this appendix, Definitions), the manufacturer must specify in the certification report the frosting interval to be used during frost accumulation tests and provide the procedure for manually initiating the defrost at the specified time.

2.2.2 Special Requirements for Units Having a Multiple-Speed Outdoor Fan

Configure the multiple-speed outdoor fan according to the installation manual included with the unit by the manufacturer, and thereafter, leave it unchanged for all tests. The controls of the unit must regulate the operation of the outdoor fan during all lab tests except dry coil cooling mode tests. For dry coil cooling mode tests, the outdoor fan

must operate at the same speed used during the required wet coil test conducted at the same outdoor test conditions.

2.2.3 Special Requirements for Multi-Split Air Conditioners and Heat Pumps and Ducted Systems Using a Single Indoor Section Containing Multiple Indoor Blowers That Would Normally Operate Using Two or More Indoor Thermostats

Because these systems will have more than one indoor blower and possibly multiple outdoor fans and compressor systems, references in this test procedure to a singular indoor blower, outdoor fan, and/or compressor means all indoor blowers, all outdoor fans, and all compressor systems that are energized during the test.

a. Additional requirements for multi-split air conditioners and heat pumps. For any test where the system is operated at part load (*i.e.*, one or more compressors “off”, operating at the intermediate or minimum compressor speed, or at low compressor capacity), the manufacturer must designate in the certification report the indoor coil(s) that are not providing heating or cooling during the test such that the sum of the nominal heating or cooling capacity of the operational indoor units is within 5 percent of the intended part load heating or cooling capacity. For variable-speed systems, the manufacturer must designate in the certification report at least one indoor unit that is not providing heating or cooling for all tests conducted at minimum compressor speed. For all other part-load tests, the manufacturer must choose to turn off zero, one, two, or more indoor units. The chosen configuration must remain unchanged for all tests conducted at the same compressor speed/capacity. For any indoor coil that is not providing heating or cooling during a test, cease forced airflow through this indoor coil and block its outlet duct.

b. Additional requirements for ducted split systems with a single indoor unit containing multiple indoor blowers (or for single-package units with an indoor section containing multiple indoor blowers) where the indoor blowers are designed to cycle on and off independently of one another and are not controlled such that all indoor blowers are modulated to always operate at the same air volume rate or speed. For any test where the system is operated at its lowest capacity—*i.e.*, the lowest total air volume rate allowed when operating the single-speed compressor or when operating at low compressor capacity—indoor blowers accounting for at least one-third of the full-load air volume rate must be turned off unless prevented by the controls of the unit. In such cases, turn off as many indoor blowers as permitted by the unit’s controls. Where more than one option exists for meeting this “off” requirement, the manufacturer shall indicate in its certification report which indoor blower(s) are turned off. The chosen configuration shall remain unchanged for all tests conducted at the same lowest capacity configuration. For any indoor coil turned off during a test, cease forced airflow through any outlet duct connected to a switched-off indoor blower.

c. For test setups where the laboratory’s physical limitations requires use of more

than the required line length of 25 feet as listed in section 2.2.a(4) of this appendix, then the actual refrigerant line length used by the laboratory may exceed the required length and the refrigerant line length correction factors in Table 4 of AHRI 1230–2010 are applied to the cooling capacity measured for each cooling mode test.

2.2.4 Wet-Bulb Temperature Requirements for the Air Entering the Indoor and Outdoor Coils

2.2.4.1 Cooling Mode Tests

For wet-coil cooling mode tests, regulate the water vapor content of the air entering the indoor unit so that the wet-bulb temperature is as listed in Tables 4 to 7. As noted in these same tables, achieve a wet-bulb temperature during dry-coil cooling mode tests that results in no condensate forming on the indoor coil. Controlling the water vapor content of the air entering the outdoor side of the unit is not required for cooling mode tests except when testing:

- (1) Units that reject condensate to the outdoor coil during wet coil tests. Tables 4–7 list the applicable wet-bulb temperatures.
- (2) Single-package units where all or part of the indoor section is located in the outdoor test room. The average dew point temperature of the air entering the outdoor coil during wet coil tests must be within ± 3.0 °F of the average dew point temperature of the air entering the indoor coil over the 30-minute data collection interval described in section 3.3 of this appendix. For dry coil tests on such units, it may be necessary to limit the moisture content of the air entering the outdoor coil of the unit to meet the requirements of section 3.4 of this appendix.

2.2.4.2 Heating Mode Tests

For heating mode tests, regulate the water vapor content of the air entering the outdoor unit to the applicable wet-bulb temperature listed in Tables 11 to 14. The wet-bulb temperature entering the indoor side of the heat pump must not exceed 60 °F. Additionally, if the Outdoor Air Enthalpy test method (section 2.10.1 of this appendix) is used while testing a single-package heat pump where all or part of the outdoor section is located in the indoor test room, adjust the wet-bulb temperature for the air entering the indoor side to yield an indoor-side dew point temperature that is as close as reasonably possible to the dew point temperature of the outdoor-side entering air.

2.2.5 Additional Refrigerant Charging Requirements

2.2.5.1 Instructions To Use for Charging

a. Where the manufacturer’s installation instructions contain two sets of refrigerant charging criteria, one for field installations and one for lab testing, use the field installation criteria.

b. For systems consisting of an outdoor unit manufacturer’s outdoor section and indoor section with differing charging procedures, adjust the refrigerant charge per the outdoor installation instructions.

c. For systems consisting of an outdoor unit manufacturer’s outdoor unit and an independent coil manufacturer’s indoor unit with differing charging procedures, adjust the

refrigerant charge per the indoor unit’s installation instructions. If instructions are provided only with the outdoor unit or are provided only with an independent coil manufacturer’s indoor unit, then use the provided instructions.

2.2.5.2 Test(s) To Use for Charging

a. Use the tests or operating conditions specified in the manufacturer’s installation instructions for charging. The manufacturer’s installation instructions may specify use of tests other than the A or A₂ test for charging, but, unless the unit is a heating-only heat pump, the air volume rate must be determined by the A or A₂ test as specified in section 3.1 of this appendix.

b. If the manufacturer’s installation instructions do not specify a test or operating conditions for charging or there are no manufacturer’s instructions, use the following test(s):

- (1) For air conditioners or cooling and heating heat pumps, use the A or A₂ test.
- (2) For cooling and heating heat pumps that do not operate in the H1 or H1₂ test (*e.g.*, due to shut down by the unit limiting devices) when tested using the charge determined at the A or A₂ test, and for heating-only heat pumps, use the H1 or H1₂ test.

2.2.5.3 Parameters To Set and Their Target Values

a. Consult the manufacturer’s installation instructions regarding which parameters (*e.g.*, superheat) to set and their target values. If the instructions provide ranges of values, select target values equal to the midpoints of the provided ranges.

b. In the event of conflicting information between charging instructions (*i.e.*, multiple conditions given for charge adjustment where all conditions specified cannot be met), follow the following hierarchy.

- (1) For fixed orifice systems:
 - (i) Superheat
 - (ii) High side pressure or corresponding saturation or dew-point temperature
 - (iii) Low side pressure or corresponding saturation or dew-point temperature
 - (iv) Low side temperature
 - (v) High side temperature
 - (vi) Charge weight
- (2) For expansion valve systems:
 - (i) Subcooling
 - (ii) High side pressure or corresponding saturation or dew-point temperature
 - (iii) Low side pressure or corresponding saturation or dew-point temperature
 - (iv) Approach temperature (difference between temperature of liquid leaving condenser and condenser average inlet air temperature)
 - (v) Charge weight

c. If there are no installation instructions and/or they do not provide parameters and target values, set superheat to a target value of 12 °F for fixed orifice systems or set subcooling to a target value of 10 °F for expansion valve systems.

2.2.5.4 Charging Tolerances

a. If the manufacturer’s installation instructions specify tolerances on target values for the charging parameters, set the values within these tolerances.

b. Otherwise, set parameter values within the following test condition tolerances for the different charging parameters:

- (1) Superheat: ± 2.0 °F
- (2) Subcooling: ± 2.0 °F
- (3) High side pressure or corresponding saturation or dew point temperature: ± 4.0 psi or ± 1.0 °F
- (4) Low side pressure or corresponding saturation or dew point temperature: ± 2.0 psi or ± 0.8 °F
- (5) High side temperature: ± 2.0 °F
- (6) Low side temperature: ± 2.0 °F
- (7) Approach temperature: ± 1.0 °F
- (8) Charge weight: ± 2.0 ounce

2.2.5.5 Special Charging Instructions

a. Cooling and Heating Heat Pumps

If, using the initial charge set in the A or A₂ test, the conditions are not within the range specified in manufacturer's installation instructions for the H1 or H1₂ test, make as small as possible an adjustment to obtain conditions for this test in the specified range. After this adjustment, recheck conditions in the A or A₂ test to confirm that they are still within the specified range for the A or A₂ test.

b. Single-Package Systems

Unless otherwise directed by the manufacturer's installation instructions, install one or more refrigerant line pressure gauges during the setup of the unit, located depending on the parameters used to verify or set charge, as described:

- (1) Install a pressure gauge at the location of the service valve on the liquid line if charging is on the basis of subcooling, or high side pressure or corresponding saturation or dew point temperature;
- (2) Install a pressure gauge at the location of the service valve on the suction line if charging is on the basis of superheat, or low side pressure or corresponding saturation or dew point temperature.

Use methods for installing pressure gauge(s) at the required location(s) as indicated in manufacturer's instructions if specified.

2.2.5.6 Near-Azeotropic and Zeotropic Refrigerants

Perform charging of near-azeotropic and zeotropic refrigerants only with refrigerant in the liquid state.

2.2.5.7 Adjustment of Charge Between Tests

After charging the system as described in this test procedure, use the set refrigerant charge for all tests used to determine performance. Do not adjust the refrigerant charge at any point during testing. If measurements indicate that refrigerant charge has leaked during the test, repair the refrigerant leak, repeat any necessary set-up steps, and repeat all tests.

2.3 Indoor Air Volume Rates

If a unit's controls allow for overspeeding the indoor blower (usually on a temporary basis), take the necessary steps to prevent overspeeding during all tests.

2.3.1 Cooling Tests

a. Set indoor blower airflow-control settings (e.g., fan motor pin settings, fan motor speed) according to the requirements

that are specified in section 3.1.4 of this appendix.

b. Express the Cooling full-load air volume rate, the Cooling Minimum Air Volume Rate, and the Cooling Intermediate Air Volume Rate in terms of standard air.

2.3.2 Heating Tests

a. Set indoor blower airflow-control settings (e.g., fan motor pin settings, fan motor speed) according to the requirements that are specified in section 3.1.4 of this appendix.

b. Express the heating full-load air volume rate, the heating minimum air volume rate, the heating intermediate air volume rate, and the heating nominal air volume rate in terms of standard air.

2.4 Indoor Coil Inlet and Outlet Duct Connections

Insulate and/or construct the outlet plenum as described in section 2.4.1 of this appendix and, if installed, the inlet plenum described in section 2.4.2 of this appendix with thermal insulation having a nominal overall resistance (R-value) of at least 19 hr • ft² • °F/Btu.

2.4.1 Outlet Plenum for the Indoor Unit

a. Attach a plenum to the outlet of the indoor coil. (Note: For some packaged systems, the indoor coil may be located in the outdoor test room.)

b. For systems having multiple indoor coils, or multiple indoor blowers within a single indoor section, attach a plenum to each indoor coil or indoor blower outlet. In order to reduce the number of required airflow measurement apparatus (section 2.6 of this appendix), each such apparatus may serve multiple outlet plenums connected to a single common duct leading to the apparatus. More than one indoor test room may be used, which may use one or more common ducts leading to one or more airflow measurement apparatus within each test room that contains multiple indoor coils. At the plane where each plenum enters a common duct, install an adjustable airflow damper and use it to equalize the static pressure in each plenum. Each outlet air temperature grid (section 2.5.4 of this appendix) and airflow measuring apparatus are located downstream of the inlet(s) to the common duct. For multiple-circuit (or multi-circuit) systems for which each indoor coil outlet is measured separately and its outlet plenum is not connected to a common duct connecting multiple outlet plenums, the outlet air temperature grid and airflow measuring apparatus must be installed at each outlet plenum.

c. For small-duct, high-velocity systems, install an outlet plenum that has a diameter that is equal to or less than the value listed in Table 2. The limit depends only on the Cooling full-load air volume rate (see section 3.1.4.1.1 of this appendix) and is effective regardless of the flange dimensions on the outlet of the unit (or an air supply plenum adapter accessory, if installed in accordance with the manufacturer's installation instructions).

d. Add a static pressure tap to each face of the (each) outlet plenum, if rectangular, or at four evenly distributed locations along the

circumference of an oval or round plenum. Create a manifold that connects the four static pressure taps. Figure 9 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3) shows allowed options for the manifold configuration. The cross-sectional dimensions of plenum shall be equal to the dimensions of the indoor unit outlet. See Figures 7a, 7b, and 7c of ANSI/ASHRAE 37–2009 for the minimum length of the (each) outlet plenum and the locations for adding the static pressure taps for ducted blower coil indoor units and single-package systems. See Figure 8 of ANSI/ASHRAE 37–2009 for coil-only indoor units.

TABLE 2—SIZE OF OUTLET PLENUM FOR SMALL-DUCT HIGH-VELOCITY INDOOR UNITS

Cooling full-load air volume rate (scfm)	Maximum diameter* of outlet plenum (inches)
≤500	6
501 to 700	7
701 to 900	8
901 to 1100	9
1101 to 1400	10
1401 to 1750	11

*If the outlet plenum is rectangular, calculate its equivalent diameter using $(4A/P)$, where A is the cross-sectional area and P is the perimeter of the rectangular plenum, and compare it to the listed maximum diameter.

2.4.2 Inlet Plenum for the Indoor Unit

Install an inlet plenum when testing a coil-only indoor unit, a ducted blower coil indoor unit, or a single-package system. See Figures 7b and 7c of ANSI/ASHRAE 37–2009 for cross-sectional dimensions, the minimum length of the inlet plenum, and the locations of the static-pressure taps for ducted blower coil indoor units and single-package systems. See Figure 8 of ANSI/ASHRAE 37–2009 for coil-only indoor units. The inlet plenum duct size shall equal the size of the inlet opening of the air-handling (blower coil) unit or furnace. For a ducted blower coil indoor unit the set up may omit the inlet plenum if an inlet airflow prevention device is installed with a straight internally unobstructed duct on its outlet end with a minimum length equal to 1.5 times the square root of the cross-sectional area of the indoor unit inlet. See section 2.5.1.2 of this appendix for requirements for the locations of static pressure taps built into the inlet airflow prevention device. For all of these arrangements, make a manifold that connects the four static-pressure taps using one of the three configurations specified in section 2.4.1.d of this appendix. Never use an inlet plenum when testing non-ducted indoor units.

2.5 Indoor Coil Air Property Measurements and Airflow Prevention Devices

Follow instructions for indoor coil air property measurements as described in section 2.14 of this appendix, unless otherwise instructed in this section.

a. Measure the dry-bulb temperature and water vapor content of the air entering and

leaving the indoor coil. If needed, use an air sampling device to divert air to a sensor(s) that measures the water vapor content of the air. See section 5.3 of ANSI/ASHRAE 41.1–2013 (incorporated by reference, see § 430.3) for guidance on constructing an air sampling device. No part of the air sampling device or the tubing transferring the sampled air to the sensor shall be within two inches of the test chamber floor, and the transfer tubing shall be insulated. The sampling device may also be used for measurement of dry bulb temperature by transferring the sampled air to a remotely located sensor(s). The air sampling device and the remotely located temperature sensor(s) may be used to determine the entering air dry bulb temperature during any test. The air sampling device and the remotely located sensor(s) may be used to determine the leaving air dry bulb temperature for all tests except:

- (1) Cyclic tests; and
- (2) Frost accumulation tests.

b. Install grids of temperature sensors to measure dry bulb temperatures of both the entering and leaving airstreams of the indoor unit. These grids of dry bulb temperature sensors may be used to measure average dry bulb temperature entering and leaving the indoor unit in all cases (as an alternative to the dry bulb sensor measuring the sampled air). The leaving airstream grid is required for measurement of average dry bulb temperature leaving the indoor unit for the two special cases noted above. The grids are also required to measure the air temperature distribution of the entering and leaving airstreams as described in sections 3.1.8 and 3.1.9 of this appendix. Two such grids may be applied as a thermopile, to directly obtain the average temperature difference rather than directly measuring both entering and leaving average temperatures.

c. Use of airflow prevention devices. Use an inlet and outlet air damper box, or use an inlet upturned duct and an outlet air damper box when conducting one or both of the cyclic tests listed in sections 3.2 and 3.6 of this appendix on ducted systems. If not conducting any cyclic tests, an outlet air damper box is required when testing ducted and non-ducted heat pumps that cycle off the indoor blower during defrost cycles and there is no other means for preventing natural or forced convection through the indoor unit when the indoor blower is off. Never use an inlet damper box or an inlet upturned duct when testing non-ducted indoor units. An inlet upturned duct is a length of ductwork installed upstream from the inlet such that the indoor duct inlet opening, facing upwards, is sufficiently high to prevent natural convection transfer out of the duct. If an inlet upturned duct is used, install a dry bulb temperature sensor near the inlet opening of the indoor duct at a centerline location not higher than the lowest elevation of the duct edges at the inlet, and ensure that any pair of 5-minute averages of the dry bulb temperature at this location, measured at least every minute during the compressor OFF period of the cyclic test, do not differ by more than 1.0 °F.

2.5.1 Test Set-Up on the Inlet Side of the Indoor Coil: For Cases Where the Inlet Airflow Prevention Device Is Installed

a. Install an airflow prevention device as specified in section 2.5.1.1 or 2.5.1.2 of this appendix, whichever applies.

b. For an inlet damper box, locate the grid of entering air dry-bulb temperature sensors, if used, and the air sampling device, or the sensor used to measure the water vapor content of the inlet air, at a location immediately upstream of the damper box inlet. For an inlet upturned duct, locate the grid of entering air dry-bulb temperature sensors, if used, and the air sampling device, or the sensor used to measure the water vapor content of the inlet air, at a location at least one foot downstream from the beginning of the insulated portion of the duct but before the static pressure measurement.

2.5.1.1 If the Section 2.4.2 Inlet Plenum Is Installed

Construct the airflow prevention device having a cross-sectional flow area equal to or greater than the flow area of the inlet plenum. Install the airflow prevention device upstream of the inlet plenum and construct ductwork connecting it to the inlet plenum. If needed, use an adaptor plate or a transition duct section to connect the airflow prevention device with the inlet plenum. Insulate the ductwork and inlet plenum with thermal insulation that has a nominal overall resistance (R-value) of at least 19 hr • ft² • °F/Btu.

2.5.1.2 If the Section 2.4.2 Inlet Plenum Is Not Installed

Construct the airflow prevention device having a cross-sectional flow area equal to or greater than the flow area of the air inlet of the indoor unit. Install the airflow prevention device immediately upstream of the inlet of the indoor unit. If needed, use an adaptor plate or a short transition duct section to connect the airflow prevention device with the unit's air inlet. Add static pressure taps at the center of each face of a rectangular airflow prevention device, or at four evenly distributed locations along the circumference of an oval or round airflow prevention device. Locate the pressure taps at a distance from the indoor unit inlet equal to 0.5 times the square root of the cross sectional area of the indoor unit inlet. This location must be between the damper and the inlet of the indoor unit, if a damper is used. Make a manifold that connects the four static pressure taps using one of the configurations shown in Figure 9 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3). Insulate the ductwork with thermal insulation that has a nominal overall resistance (R-value) of at least 19 hr • ft² • °F/Btu.

2.5.2 Test Set-Up on the Inlet Side of the Indoor Unit: For Cases Where No Airflow Prevention Device Is Installed

If using the section 2.4.2 inlet plenum and a grid of dry bulb temperature sensors, mount the grid at a location upstream of the static pressure taps described in section 2.4.2 of this appendix, preferably at the entrance plane of the inlet plenum. If the section 2.4.2 inlet plenum is not used (*i.e.* for non-ducted

units) locate a grid approximately 6 inches upstream of the indoor unit inlet. In the case of a system having multiple non-ducted indoor units, do this for each indoor unit. Position an air sampling device, or the sensor used to measure the water vapor content of the inlet air, immediately upstream of the (each) entering air dry-bulb temperature sensor grid. If a grid of sensors is not used, position the entering air sampling device (or the sensor used to measure the water vapor content of the inlet air) as if the grid were present.

2.5.3 Indoor Coil Static Pressure Difference Measurement

Fabricate pressure taps meeting all requirements described in section 6.5.2 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3) and illustrated in Figure 2A of AMCA 210–2007 (incorporated by reference, see § 430.3), however, if adhering strictly to the description in section 6.5.2 of ANSI/ASHRAE 37–2009, the minimum pressure tap length of 2.5 times the inner diameter of Figure 2A of AMCA 210–2007 is waived. Use a differential pressure measuring instrument that is accurate to within ±0.01 inches of water and has a resolution of at least 0.01 inches of water to measure the static pressure difference between the indoor coil air inlet and outlet. Connect one side of the differential pressure instrument to the manifolded pressure taps installed in the outlet plenum. Connect the other side of the instrument to the manifolded pressure taps located in either the inlet plenum or incorporated within the airflow prevention device. For non-ducted indoor units that are tested with multiple outlet plenums, measure the static pressure within each outlet plenum relative to the surrounding atmosphere.

2.5.4 Test Set-Up on the Outlet Side of the Indoor Coil

a. Install an interconnecting duct between the outlet plenum described in section 2.4.1 of this appendix and the airflow measuring apparatus described below in section 2.6 of this appendix. The cross-sectional flow area of the interconnecting duct must be equal to or greater than the flow area of the outlet plenum or the common duct used when testing non-ducted units having multiple indoor coils. If needed, use adaptor plates or transition duct sections to allow the connections. To minimize leakage, tape joints within the interconnecting duct (and the outlet plenum). Construct or insulate the entire flow section with thermal insulation having a nominal overall resistance (R-value) of at least 19 hr • ft² • °F/Btu.

b. Install a grid(s) of dry-bulb temperature sensors inside the interconnecting duct. Also, install an air sampling device, or the sensor(s) used to measure the water vapor content of the outlet air, inside the interconnecting duct. Locate the dry-bulb temperature grid(s) upstream of the air sampling device (or the in-duct sensor(s)) used to measure the water vapor content of the outlet air). Turn off the sampler fan motor during the cyclic tests. Air leaving an indoor unit that is sampled by an air sampling device for remote water-vapor-content measurement must be returned to the interconnecting duct at a location:

- (1) Downstream of the air sampling device;
- (2) On the same side of the outlet air damper as the air sampling device; and
- (3) Upstream of the section 2.6 airflow measuring apparatus.

2.5.4.1 Outlet Air Damper Box Placement and Requirements

If using an outlet air damper box (see section 2.5 of this appendix), the leakage rate from the combination of the outlet plenum, the closed damper, and the duct section that connects these two components must not exceed 20 cubic feet per minute when a negative pressure of 1 inch of water column is maintained at the plenum's inlet.

2.5.4.2 Procedures To Minimize Temperature Maldistribution

Use these procedures if necessary to correct temperature maldistributions. Install a mixing device(s) upstream of the outlet air, dry-bulb temperature grid (but downstream of the outlet plenum static pressure taps). Use a perforated screen located between the mixing device and the dry-bulb temperature grid, with a maximum open area of 40 percent. One or both items should help to meet the maximum outlet air temperature distribution specified in section 3.1.8 of this appendix. Mixing devices are described in sections 5.3.2 and 5.3.3 of ANSI/ASHRAE 41.1–2013 and section 5.2.2 of ASHRAE 41.2–1987 (RA 1992) (incorporated by reference, see § 430.3).

2.5.4.3 Minimizing Air Leakage

For small-duct, high-velocity systems, install an air damper near the end of the interconnecting duct, just prior to the transition to the airflow measuring apparatus of section 2.6 of this appendix. To minimize air leakage, adjust this damper such that the pressure in the receiving chamber of the airflow measuring apparatus is no more than 0.5 inch of water higher than the surrounding test room ambient. If applicable, in lieu of installing a separate damper, use the outlet air damper box of sections 2.5 and 2.5.4.1 of this appendix if it allows variable positioning. Also apply these steps to any conventional indoor blower unit that creates a static pressure within the receiving chamber of the airflow measuring apparatus that exceeds the test room ambient pressure by more than 0.5 inches of water column.

2.5.5 Dry Bulb Temperature Measurement

a. Measure dry bulb temperatures as specified in sections 4, 5.3, 6, and 7 of ANSI/ASHRAE 41.1–2013 (incorporated by reference, see § 430.3).

b. Distribute the sensors of a dry-bulb temperature grid over the entire flow area. The required minimum is 9 sensors per grid.

2.5.6 Water Vapor Content Measurement

Determine water vapor content by measuring dry-bulb temperature combined with the air wet-bulb temperature, dew point temperature, or relative humidity. If used, construct and apply wet-bulb temperature sensors as specified in sections 4, 5, 6, 7.2, 7.3, and 7.4 of ASHRAE 41.6–2014 (incorporated by reference, see § 430.3). The temperature sensor (wick removed) must be accurate to within ± 0.2 °F. If used, apply dew point hygrometers as specified in

sections 4, 5, 6, 7.1, and 7.4 of ASHRAE 41.6–2014 (incorporated by reference, see § 430.3). The dew point hygrometers must be accurate to within ± 0.4 °F when operated at conditions that result in the evaluation of dew points above 35 °F. If used, a relative humidity (RH) meter must be accurate to within $\pm 0.7\%$ RH. Other means to determine the psychrometric state of air may be used as long as the measurement accuracy is equivalent to or better than the accuracy achieved from using a wet-bulb temperature sensor that meets the above specifications.

2.5.7 Air Damper Box Performance Requirements

If used (see section 2.5 of this appendix), the air damper box(es) must be capable of being completely opened or completely closed within 10 seconds for each action.

2.6 Airflow Measuring Apparatus

a. Fabricate and operate an airflow measuring apparatus as specified in section 6.2 and 6.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3). Place the static pressure taps and position the diffusion baffle (settling means) relative to the chamber inlet as indicated in Figure 12 of AMCA 210–2007 and/or Figure 14 of ASHRAE 41.2–1987 (RA 1992) (incorporated by reference, see § 430.3). When measuring the static pressure difference across nozzles and/or velocity pressure at nozzle throats using electronic pressure transducers and a data acquisition system, if high frequency fluctuations cause measurement variations to exceed the test tolerance limits specified in section 9.2 and Table 2 of ANSI/ASHRAE 37–2009, dampen the measurement system such that the time constant associated with response to a step change in measurement (time for the response to change 63% of the way from the initial output to the final output) is no longer than five seconds.

b. Connect the airflow measuring apparatus to the interconnecting duct section described in section 2.5.4 of this appendix. See sections 6.1.1, 6.1.2, and 6.1.4, and Figures 1, 2, and 4 of ANSI/ASHRAE 37–2009; and Figures D1, D2, and D4 of AHRI 210/240–2008 (incorporated by reference, see § 430.3) for illustrative examples of how the test apparatus may be applied within a complete laboratory set-up. Instead of following one of these examples, an alternative set-up may be used to handle the air leaving the airflow measuring apparatus and to supply properly conditioned air to the test unit's inlet. The alternative set-up, however, must not interfere with the prescribed means for measuring airflow rate, inlet and outlet air temperatures, inlet and outlet water vapor contents, and external static pressures, nor create abnormal conditions surrounding the test unit. (Note: Do not use an enclosure as described in section 6.1.3 of ANSI/ASHRAE 37–2009 when testing triple-split units.)

2.7 Electrical Voltage Supply

Perform all tests at the voltage specified in section 6.1.3.2 of AHRI 210/240–2008 (incorporated by reference, see § 430.3) for "Standard Rating Tests." If either the indoor or the outdoor unit has a 208V or 200V nameplate voltage and the other unit has a 230V nameplate rating, select the voltage

supply on the outdoor unit for testing. Otherwise, supply each unit with its own nameplate voltage. Measure the supply voltage at the terminals on the test unit using a volt meter that provides a reading that is accurate to within ± 1.0 percent of the measured quantity.

2.8 Electrical Power and Energy Measurements

a. Use an integrating power (watt-hour) measuring system to determine the electrical energy or average electrical power supplied to all components of the air conditioner or heat pump (including auxiliary components such as controls, transformers, crankcase heater, integral condensate pump on non-ducted indoor units, etc.). The watt-hour measuring system must give readings that are accurate to within ± 0.5 percent. For cyclic tests, this accuracy is required during both the ON and OFF cycles. Use either two different scales on the same watt-hour meter or two separate watt-hour meters. Activate the scale or meter having the lower power rating within 15 seconds after beginning an OFF cycle. Activate the scale or meter having the higher power rating within 15 seconds prior to beginning an ON cycle. For ducted blower coil systems, the ON cycle lasts from compressor ON to indoor blower OFF. For ducted coil-only systems, the ON cycle lasts from compressor ON to compressor OFF. For non-ducted units, the ON cycle lasts from indoor blower ON to indoor blower OFF. When testing air conditioners and heat pumps having a variable-speed compressor, avoid using an induction watt/watt-hour meter.

b. When performing section 3.5 and/or 3.8 cyclic tests on non-ducted units, provide instrumentation to determine the average electrical power consumption of the indoor blower motor to within ± 1.0 percent. If required according to sections 3.3, 3.4, 3.7, 3.9.1 of this appendix, and/or 3.10 of this appendix, this same instrumentation requirement (to determine the average electrical power consumption of the indoor blower motor to within ± 1.0 percent) applies when testing air conditioners and heat pumps having a variable-speed constant-air-volume-rate indoor blower or a variable-speed, variable-air-volume-rate indoor blower.

2.9 Time Measurements

Make elapsed time measurements using an instrument that yields readings accurate to within ± 0.2 percent.

2.10 Test Apparatus for the Secondary Space Conditioning Capacity Measurement

For all tests, use the indoor air enthalpy method to measure the unit's capacity. This method uses the test set-up specified in sections 2.4 to 2.6 of this appendix. In addition, for all steady-state tests, conduct a second, independent measurement of capacity as described in section 3.1.1 of this appendix. For split systems, use one of the following secondary measurement methods: Outdoor air enthalpy method, compressor calibration method, or refrigerant enthalpy method. For single-package units, use either the outdoor air enthalpy method or the compressor calibration method as the secondary measurement.

2.10.1 Outdoor Air Enthalpy Method

a. To make a secondary measurement of indoor space conditioning capacity using the outdoor air enthalpy method, do the following:

- (1) Measure the electrical power consumption of the test unit;
- (2) Measure the air-side capacity at the outdoor coil; and
- (3) Apply a heat balance on the refrigerant cycle.

b. The test apparatus required for the outdoor air enthalpy method is a subset of the apparatus used for the indoor air enthalpy method. Required apparatus includes the following:

- (1) On the outlet side, an outlet plenum containing static pressure taps (sections 2.4, 2.4.1, and 2.5.3 of this appendix),
- (2) An airflow measuring apparatus (section 2.6 of this appendix),
- (3) A duct section that connects these two components and itself contains the instrumentation for measuring the dry-bulb temperature and water vapor content of the air leaving the outdoor coil (sections 2.5.4, 2.5.5, and 2.5.6 of this appendix), and
- (4) On the inlet side, a sampling device and temperature grid (section 2.11.b of this appendix).

c. During the preliminary tests described in sections 3.11.1 and 3.11.1.1 of this appendix, measure the evaporator and condenser temperatures or pressures. On both the outdoor coil and the indoor coil, solder a thermocouple onto a return bend located at or near the midpoint of each coil or at points not affected by vapor superheat or liquid subcooling. Alternatively, if the test unit is not sensitive to the refrigerant charge, install pressure gages to the access valves or to ports created from tapping into the suction and discharge lines according to sections 7.4.2 and 8.2.5 of ASHRAE 37–2009. Use this alternative approach when testing a unit charged with a zeotropic refrigerant having a temperature glide in excess of 1 °F at the specified test conditions.

2.10.2 Compressor Calibration Method

Measure refrigerant pressures and temperatures to determine the evaporator superheat and the enthalpy of the refrigerant that enters and exits the indoor coil. Determine refrigerant flow rate or, when the superheat of the refrigerant leaving the evaporator is less than 5 °F, total capacity from separate calibration tests conducted under identical operating conditions. When using this method, install instrumentation and measure refrigerant properties according to section 7.4.2 and 8.2.5 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3). If removing the refrigerant before applying refrigerant lines and subsequently recharging, use the steps in 7.4.2 of ANSI/ASHRAE 37–2009 in addition to the methods of section 2.2.5 of this appendix to confirm the refrigerant charge. Use refrigerant temperature and pressure measuring instruments that meet the specifications given in sections 5.1.1 and 5.2 of ANSI/ASHRAE 37–2009.

2.10.3 Refrigerant Enthalpy Method

For this method, calculate space conditioning capacity by determining the

refrigerant enthalpy change for the indoor coil and directly measuring the refrigerant flow rate. Use section 7.5.2 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3) for the requirements for this method, including the additional instrumentation requirements, and information on placing the flow meter and a sight glass. Use refrigerant temperature, pressure, and flow measuring instruments that meet the specifications given in sections 5.1.1, 5.2, and 5.5.1 of ANSI/ASHRAE 37–2009. Refrigerant flow measurement device(s), if used, must be either elevated at least two feet from the test chamber floor or placed upon insulating material having a total thermal resistance of at least R–12 and extending at least one foot laterally beyond each side of the device(s)' exposed surfaces.

2.11 Measurement of Test Room Ambient Conditions

Follow instructions for setting up air sampling device and aspirating psychrometer as described in section 2.14 of this appendix, unless otherwise instructed in this section.

a. If using a test set-up where air is ducted directly from the conditioning apparatus to the indoor coil inlet (see Figure 2, Loop Air-Enthalpy Test Method Arrangement, of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3)), add instrumentation to permit measurement of the indoor test room dry-bulb temperature.

b. On the outdoor side, use one of the following two approaches, except that approach (1) is required for all evaporatively-cooled units and units that transfer condensate to the outdoor unit for evaporation using condenser heat.

- (1) Use sampling tree air collection on all air-inlet surfaces of the outdoor unit.
- (2) Use sampling tree air collection on one or more faces of the outdoor unit and demonstrate air temperature uniformity as follows. Install a grid of evenly-distributed thermocouples on each air-permitting face on the inlet of the outdoor unit. Install the thermocouples on the air sampling device, locate them individually or attach them to a wire structure. If not installed on the air sampling device, install the thermocouple grid 6 to 24 inches from the unit. The thermocouples shall be evenly spaced across the coil inlet surface and be installed to avoid sampling of discharge air or blockage of air recirculation. The grid of thermocouples must provide at least 16 measuring points per face or one measurement per square foot of inlet face area, whichever is less. This grid must be constructed and used as per section 5.3 of ANSI/ASHRAE 41.1–2013 (incorporated by reference, see § 430.3). The maximum difference between the readings of any two pairs of these individual thermocouples located at any of the faces of the inlet of the outdoor unit, must not exceed 2.0 °F, otherwise approach (1) must be used.

The air sampling devices shall be located at the geometric center of each side; the branches may be oriented either parallel or perpendicular to the longer edges of the air inlet area. The air sampling devices in the outdoor air inlet location shall be sized such that they cover at least 75% of the face area of the side of the coil that they are measuring.

Air distribution at the test facility point of supply to the unit shall be reviewed and may require remediation prior to the beginning of testing. Mixing fans can be used to ensure adequate air distribution in the test room. If used, mixing fans shall be oriented such that they are pointed away from the air intake so that the mixing fan exhaust does not affect the outdoor coil air volume rate. Particular attention should be given to prevent the mixing fans from affecting (enhancing or limiting) recirculation of condenser fan exhaust air back through the unit. Any fan used to enhance test room air mixing shall not cause air velocities in the vicinity of the test unit to exceed 500 feet per minute.

The air sampling device may be larger than the face area of the side being measured, however care shall be taken to prevent discharge air from being sampled. If an air sampling device dimension extends beyond the inlet area of the unit, holes shall be blocked in the air sampling device to prevent sampling of discharge air. Holes can be blocked to reduce the region of coverage of the intake holes both in the direction of the trunk axis or perpendicular to the trunk axis. For intake hole region reduction in the direction of the trunk axis, block holes of one or more adjacent pairs of branches (the branches of a pair connect opposite each other at the same trunk location) at either the outlet end or the closed end of the trunk. For intake hole region reduction perpendicular to the trunk axis, block off the same number of holes on each branch on both sides of the trunk.

A maximum of four (4) air sampling devices shall be connected to each aspirating psychrometer. In order to proportionately divide the flow stream for multiple air sampling devices for a given aspirating psychrometer, the tubing or conduit conveying sampled air to the psychrometer shall be of equivalent lengths for each air sampling device. Preferentially, the air sampling device should be hard connected to the aspirating psychrometer, but if space constraints do not allow this, the assembly shall have a means of allowing a flexible tube to connect the air sampling device to the aspirating psychrometer. The tubing or conduit shall be insulated and routed to prevent heat transfer to the air stream. Any surface of the air conveying tubing in contact with surrounding air at a different temperature than the sampled air shall be insulated with thermal insulation with a nominal thermal resistance (R-value) of at least 19 hr · ft² · °F/Btu. Alternatively the conduit may have lower thermal resistance if additional sensor(s) are used to measure dry bulb temperature at the outlet of each air sampling device. No part of the air sampling device or the tubing conducting the sampled air to the sensors shall be within two inches of the test chamber floor.

Pairs of measurements (e.g., dry bulb temperature and wet bulb temperature) used to determine water vapor content of sampled air shall be measured in the same location.

2.12 Measurement of Indoor Blower Speed

When required, measure fan speed using a revolution counter, tachometer, or stroboscope that gives readings accurate to within ±1.0 percent.

2.13 Measurement of Barometric Pressure

Determine the average barometric pressure during each test. Use an instrument that meets the requirements specified in section 5.2 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3).

2.14 Air Sampling Device and Aspirating Psychrometer Requirements

Air temperature measurements shall be made in accordance with ANSI/ASHRAE 41.1–2013, unless otherwise instructed in this section.

2.14.1 Air Sampling Device Requirements

The air sampling device is intended to draw in a sample of the air at the critical locations of a unit under test. It shall be constructed of stainless steel, plastic or other suitable, durable materials. It shall have a main flow trunk tube with a series of branch tubes connected to the trunk tube. Holes shall be on the side of the sampler facing the upstream direction of the air source. Other sizes and rectangular shapes can be used, and shall be scaled accordingly with the following guidelines:

- (1) Minimum hole density of 6 holes per square foot of area to be sampled
- (2) Sampler branch tube pitch (spacing) of 6 ± 3 in
- (3) Manifold trunk to branch diameter ratio having a minimum of 3:1 ratio
- (4) Hole pitch (spacing) shall be equally distributed over the branch (1/2 pitch from the closed end to the nearest hole)
- (5) Maximum individual hole to branch diameter ratio of 1:2 (1:3 preferred)

The minimum average velocity through the air sampling device holes shall be 2.5 ft/s as determined by evaluating the sum of the open area of the holes as compared to the flow area in the aspirating psychrometer.

2.14.2 Aspirating Psychrometer

The psychrometer consists of a flow section and a fan to draw air through the flow section and measures an average value of the sampled air stream. At a minimum, the flow section shall have a means for measuring the dry bulb temperature (typically, a resistance temperature device (RTD) and a means for measuring the humidity (RTD with wetted sock, chilled mirror hygrometer, or relative humidity sensor). The aspirating psychrometer shall include a fan that either can be adjusted manually or automatically to maintain required velocity across the sensors.

The psychrometer shall be made from suitable material which may be plastic (such as polycarbonate), aluminum or other metallic materials. All psychrometers for a given system being tested, shall be constructed of the same material. Psychrometers shall be designed such that radiant heat from the motor (for driving the fan that draws sampled air through the psychrometer) does not affect sensor measurements. For aspirating psychrometers, velocity across the wet bulb sensor shall be 1000 ± 200 ft/min. For all other psychrometers, velocity shall be as specified by the sensor manufacturer.

3. Testing Procedures

3.1 General Requirements

If, during the testing process, an equipment set-up adjustment is made that would have altered the performance of the unit during any already completed test, then repeat all tests affected by the adjustment. For cyclic tests, instead of maintaining an air volume rate, for each airflow nozzle, maintain the static pressure difference or velocity pressure during an ON period at the same pressure difference or velocity pressure as measured during the steady-state test conducted at the same test conditions.

Use the testing procedures in this section to collect the data used for calculating:

- (1) Performance metrics for central air conditioners and heat pumps during the cooling season;
- (2) Performance metrics for heat pumps during the heating season; and
- (3) Power consumption metric(s) for central air conditioners and heat pumps during the off mode season(s).

3.1.1 Primary and Secondary Test Methods

For all tests, use the indoor air enthalpy method test apparatus to determine the unit's space conditioning capacity. The procedure and data collected, however, differ slightly depending upon whether the test is a steady-state test, a cyclic test, or a frost accumulation test. The following sections described these differences. For all steady-state tests (*i.e.*, the A, A₂, A₁, B, B₂, B₁, C, C₁, EV, F₁, G₁, H₀, H₁, H₁₂, H₁₁, H_{1N}, H₃, H₃₂, and H₃₁ Tests), in addition, use one of the acceptable secondary methods specified in section 2.10 of this appendix to determine indoor space conditioning capacity. Calculate this secondary check of capacity according to section 3.11 of this appendix. The two capacity measurements must agree to within 6 percent to constitute a valid test. For this capacity comparison, use the indoor air enthalpy method capacity that is calculated in section 7.3 of ANSI/ASHRAE 37–2009 (and, if testing a coil-only system, compare capacities before making the after-test fan heat adjustments described in section 3.3, 3.4, 3.7, and 3.10 of this appendix). However, include the appropriate section 3.3 to 3.5 and 3.7 to 3.10 fan heat adjustments within the indoor air enthalpy method capacities used for the section 4 seasonal calculations of this appendix.

3.1.2 Manufacturer-Provided Equipment Overrides

Where needed, the manufacturer must provide a means for overriding the controls of the test unit so that the compressor(s) operates at the specified speed or capacity and the indoor blower operates at the specified speed or delivers the specified air volume rate.

3.1.3 Airflow Through the Outdoor Coil

For all tests, meet the requirements given in section 6.1.3.4 of AHRI 210/240–2008 (incorporated by reference, see § 430.3) when obtaining the airflow through the outdoor coil.

3.1.3.1 Double-Ducted

For products intended to be installed with the outdoor airflow ducted, the unit shall be

installed with outdoor coil ductwork installed per manufacturer installation instructions and shall operate between 0.10 and 0.15 in H₂O external static pressure. External static pressure measurements shall be made in accordance with ANSI/ASHRAE 37–2009 section 6.4 and 6.5.

3.1.4 Airflow Through the Indoor Coil

Airflow setting(s) shall be determined before testing begins. Unless otherwise specified within this or its subsections, no changes shall be made to the airflow setting(s) after initiation of testing.

3.1.4.1 Cooling Full-Load Air Volume Rate

3.1.4.1.1 Cooling Full-Load Air Volume Rate for Ducted Units

Identify the certified cooling full-load air volume rate and certified instructions for setting fan speed or controls. If there is no certified Cooling full-load air volume rate, use a value equal to the certified cooling capacity of the unit times 400 scfm per 12,000 Btu/h. If there are no instructions for setting fan speed or controls, use the as-shipped settings. Use the following procedure to confirm and, if necessary, adjust the Cooling full-load air volume rate and the fan speed or control settings to meet each test procedure requirement:

a. For all ducted blower coil systems, except those having a constant-air-volume-rate indoor blower:

Step (1) Operate the unit under conditions specified for the A (for single-stage units) or A₂ test using the certified fan speed or controls settings, and adjust the exhaust fan of the airflow measuring apparatus to achieve the certified Cooling full-load air volume rate;

Step (2) Measure the external static pressure;

Step (3) If this external static pressure is equal to or greater than the applicable minimum external static pressure cited in Table 3, the pressure requirement is satisfied; proceed to step 7 of this section. If this external static pressure is not equal to or greater than the applicable minimum external static pressure cited in Table 3, proceed to step 4 of this section;

Step (4) Increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until either

(i) The applicable Table 3 minimum is equaled or

(ii) The measured air volume rate equals 90 percent or less of the Cooling full-load air volume rate, whichever occurs first;

Step (5) If the conditions of step 4 (i) of this section occur first, the pressure requirement is satisfied; proceed to step 7 of this section. If the conditions of step 4 (ii) of this section occur first, proceed to step 6 of this section;

Step (6) Make an incremental change to the setup of the indoor blower (*e.g.*, next highest fan motor pin setting, next highest fan motor speed) and repeat the evaluation process beginning above, at step 1 of this section. If the indoor blower setup cannot be further changed, increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until the applicable Table 3 minimum is equaled; proceed to step 7 of this section;

Step (7) The airflow constraints have been satisfied. Use the measured air volume rate as the Cooling full-load air volume rate. Use the final fan speed or control settings for all tests that use the Cooling full-load air volume rate.

b. For ducted blower coil systems with a constant-air-volume indoor blower. For all tests that specify the Cooling full-load air volume rate, obtain an external static pressure as close to (but not less than) the applicable Table 3 value that does not cause automatic shutdown of the indoor blower or air volume rate variation Q_{var} , defined as follows, greater than 10 percent.

$$Q_{var} = \left[\frac{Q_{max} - Q_{min}}{\left(\frac{Q_{max} + Q_{min}}{2} \right)} \right] * 100$$

where:

Q_{max} = maximum measured airflow value
 Q_{min} = minimum measured airflow value
 Q_{var} = airflow variance, percent

Additional test steps as described in section 3.3.(e) of this appendix are required if the measured external static

pressure exceeds the target value by more than 0.03 inches of water.

c. For coil-only indoor units. For the A or A₂ Test, (exclusively), the pressure drop across the indoor coil assembly must not exceed 0.30 inches of water. If this pressure drop is exceeded, reduce the air volume rate until the measured pressure drop equals the specified maximum. Use this reduced air volume rate for all tests that require the Cooling full-load air volume rate.

TABLE 3—MINIMUM EXTERNAL STATIC PRESSURE FOR DUCTED BLOWER COIL SYSTEMS

Rated cooling ¹ or heating ² capacity (Btu/h)	Minimum external resistance ³ (inches of water)	
	Small-duct, high-velocity systems ^{4,5}	All other systems
Up Thru 28,800	1.10	0.10
29,000 to 42,500	1.15	0.15
43,000 and Above	1.20	0.20

¹ For air conditioners and air-conditioning heat pumps, the value certified by the manufacturer for the unit's cooling capacity when operated at the A or A₂ Test conditions.

² For heating-only heat pumps, the value certified by the manufacturer for the unit's heating capacity when operated at the H1 or H1₂ Test conditions.

³ For ducted units tested without an air filter installed, increase the applicable tabular value by 0.08 inches of water.

⁴ See section 1.2 of this appendix, Definitions, to determine if the equipment qualifies as a small-duct, high-velocity system.

⁵ If a closed-loop, air-enthalpy test apparatus is used on the indoor side, limit the resistance to airflow on the inlet side of the blower coil indoor unit to a maximum value of 0.1 inch of water. Impose the balance of the airflow resistance on the outlet side of the indoor blower.

d. For ducted systems having multiple indoor blowers within a single indoor section, obtain the full-load air volume rate with all indoor blowers operating unless prevented by the controls of the unit. In such cases, turn on the maximum number of indoor blowers permitted by the unit's controls. Where more than one option exists for meeting this "on" indoor blower requirement, which indoor blower(s) are turned on must match that specified in the certification report. Conduct section 3.1.4.1.1 setup steps for each indoor blower separately. If two or more indoor blowers are connected to a common duct as per section 2.4.1 of this appendix, temporarily divert their air volume to the test room when confirming or adjusting the setup configuration of individual indoor blowers. The allocation of the system's full-load air volume rate assigned to each "on" indoor blower must match that specified by the manufacturer in the certification report.

3.1.4.1.2. Cooling Full-Load Air Volume Rate for Non-ducted Units

For non-ducted units, the Cooling full-load air volume rate is the air volume rate that results during each test when the unit is operated at an external static pressure of zero inches of water.

3.1.4.2 Cooling Minimum Air Volume Rate

Identify the certified cooling minimum air volume rate and certified instructions for setting fan speed or controls. If there is no certified cooling minimum air volume rate, use the final indoor blower control settings as determined when setting the cooling full-load air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling full load air volume obtained in section 3.1.4.1 of this appendix. Otherwise, calculate the target external static pressure and follow instructions a, b, c, d, or e below. The target external static pressure, ΔP_{st_i} , for any test "i" with a specified air volume rate not equal to the Cooling full-load air volume rate is determined as follows:

$$\Delta P_{st_i} = \Delta P_{st_{full}} \left[\frac{Q_i}{Q_{full}} \right]^2$$

where:

ΔP_{st_i} = target minimum external static pressure for test i;
 $\Delta P_{st_{full}}$ = minimum external static pressure for test A or A₂ (Table 3);
 Q_i = air volume rate for test i; and
 Q_{full} = Cooling full-load air volume rate as measured after setting and/or adjustment

as described in section 3.1.4.1.1 of this appendix.

a. For a ducted blower coil system without a constant-air-volume indoor blower, adjust for external static pressure as follows:

Step (1) Operate the unit under conditions specified for the B1 test using the certified fan speed or controls settings, and adjust the exhaust fan of the airflow measuring apparatus to achieve the certified cooling minimum air volume rate;

Step (2) Measure the external static pressure;

Step (3) If this pressure is equal to or greater than the minimum external static pressure computed above, the pressure requirement is satisfied; proceed to step 7 of this section. If this pressure is not equal to or greater than the minimum external static pressure computed above, proceed to step 4 of this section;

Step (4) Increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until either

(i) The pressure is equal to the minimum external static pressure computed above or

(ii) The measured air volume rate equals 90 percent or less of the cooling minimum air volume rate, whichever occurs first;

Step (5) If the conditions of step 4 (i) of this section occur first, the pressure requirement is satisfied; proceed to step 7 of this section. If the conditions of step 4 (ii) of this section occur first, proceed to step 6 of this section;

Step (6) Make an incremental change to the setup of the indoor blower (*e.g.*, next highest fan motor pin setting, next highest fan motor speed) and repeat the evaluation process beginning above, at step 1 of this section. If the indoor blower setup cannot be further changed, increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until it equals the minimum external static pressure computed above; proceed to step 7 of this section;

Step (7) The airflow constraints have been satisfied. Use the measured air volume rate as the cooling minimum air volume rate. Use the final fan speed or control settings for all tests that use the cooling minimum air volume rate.

b. For ducted units with constant-air-volume indoor blowers, conduct all tests that specify the cooling minimum air volume rate—(*i.e.*, the A₁, B₁, C₁, F₁, and G₁ Tests)—at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation $Q_{V,ar}$, defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than the target minimum external static pressure. Additional test steps as described in section 3.3(e) of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For ducted two-capacity coil-only systems, the cooling minimum air volume rate is the higher of (1) the rate specified by the installation instructions included with the unit by the manufacturer or (2) 75 percent of the cooling full-load air volume rate. During the laboratory tests on a coil-only (fanless) system, obtain this cooling minimum air volume rate regardless of the pressure drop across the indoor coil assembly.

d. For non-ducted units, the cooling minimum air volume rate is the air volume rate that results during each test when the unit operates at an external static pressure of zero inches of water and at the indoor blower setting used at low compressor capacity (two-capacity system) or minimum compressor speed (variable-speed system). For units having a single-speed compressor and a variable-speed variable-air-volume-rate indoor blower, use the lowest fan setting allowed for cooling.

e. For ducted systems having multiple indoor blowers within a single indoor

section, operate the indoor blowers such that the lowest air volume rate allowed by the unit's controls is obtained when operating the lone single-speed compressor or when operating at low compressor capacity while meeting the requirements of section 2.2.3.b of this appendix for the minimum number of blowers that must be turned off. Using the target external static pressure and the certified air volume rates, follow the procedures described in section 3.1.4.2.a of this appendix if the indoor blowers are not constant-air-volume indoor blowers or as described in section 3.1.4.2.b of this appendix if the indoor blowers are constant-air-volume indoor blowers. The sum of the individual "on" indoor blowers' air volume rates is the cooling minimum air volume rate for the system.

3.1.4.3 Cooling Intermediate Air Volume Rate

Identify the certified cooling intermediate air volume rate and certified instructions for setting fan speed or controls. If there is no certified cooling intermediate air volume rate, use the final indoor blower control settings as determined when setting the cooling full load air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling full load air volume obtained in section 3.1.4.1 of this appendix. Otherwise, calculate target minimum external static pressure as described in section 3.1.4.2 of this appendix, and set the air volume rate as follows.

a. For a ducted blower coil system without a constant-air-volume indoor blower, adjust for external static pressure as described in section 3.1.4.2.a of this appendix for cooling minimum air volume rate.

b. For a ducted blower coil system with a constant-air-volume indoor blower, conduct the E_V Test at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation $Q_{V,ar}$, defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than the target minimum external static pressure. Additional test steps as described in section 3.3(e) of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For non-ducted units, the cooling intermediate air volume rate is the air volume rate that results when the unit operates at an external static pressure of zero inches of water and at the fan

speed selected by the controls of the unit for the E_V Test conditions.

3.1.4.4 Heating Full-Load Air Volume Rate

3.1.4.4.1 Ducted Heat Pumps Where the Heating and Cooling Full-Load Air Volume Rates Are the Same

a. Use the Cooling full-load air volume rate as the heating full-load air volume rate for:

(1) Ducted blower coil system heat pumps that do not have a constant-air-volume indoor blower, and that operate at the same airflow-control setting during both the A (or A₂) and the H₁ (or H_{1,2}) Tests;

(2) Ducted blower coil system heat pumps with constant-air-flow indoor blowers that provide the same air flow for the A (or A₂) and the H₁ (or H_{1,2}) Tests; and

(3) Ducted heat pumps that are tested with a coil-only indoor unit (except two-capacity northern heat pumps that are tested only at low capacity cooling—see section 3.1.4.4.2 of this appendix).

b. For heat pumps that meet the above criteria "1" and "3," no minimum requirements apply to the measured external or internal, respectively, static pressure. Use the final indoor blower control settings as determined when setting the Cooling full-load air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling full-load air volume obtained in section 3.1.4.1 of this appendix. For heat pumps that meet the above criterion "2," test at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation $Q_{V,ar}$, defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than, the same Table 3 minimum external static pressure as was specified for the A (or A₂) cooling mode test. Additional test steps as described in section 3.9.1(c) of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

3.1.4.4.2 Ducted Heat Pumps Where the Heating and Cooling Full-Load Air Volume Rates Are Different Due to Changes in Indoor Blower Operation, *i.e.* Speed Adjustment by the System Controls

Identify the certified heating full-load air volume rate and certified instructions for setting fan speed or controls. If there is no certified heating full-load air volume rate, use the final indoor blower control settings as

determined when setting the cooling full-load air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling full load air volume obtained in section 3.1.4.1 of this appendix. Otherwise, calculate target minimum external static pressure as described in section 3.1.4.2 of this appendix and set the air volume rate as follows.

a. For ducted blower coil system heat pumps that do not have a constant-air-volume indoor blower, adjust for external static pressure as described in section 3.1.4.2.a of this appendix for cooling minimum air volume rate.

b. For ducted heat pumps tested with constant-air-volume indoor blowers installed, conduct all tests that specify the heating full-load air volume rate at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{var} , defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than the target minimum external static pressure. Additional test steps as described in section 3.9.1(c) of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. When testing ducted, two-capacity blower coil system northern heat pumps (see section 1.2 of this appendix, Definitions), use the appropriate approach of the above two cases. For coil-only system northern heat pumps, the heating full-load air volume rate is the lesser of the rate specified by the manufacturer in the installation instructions included with the unit or 133 percent of the cooling full-load air volume rate. For this latter case, obtain the heating full-load air volume rate regardless of the pressure drop across the indoor coil assembly.

d. For ducted systems having multiple indoor blowers within a single indoor section, obtain the heating full-load air volume rate using the same "on" indoor blowers as used for the Cooling full-load air volume rate. Using the target external static pressure and the certified air volume rates, follow the procedures as described in section 3.1.4.4.2.a of this appendix if the indoor blowers are not constant-air-volume indoor blowers or as described in section 3.1.4.4.2.b of this appendix if the indoor blowers are constant-air-volume indoor blowers. The sum of the individual "on" indoor blowers' air volume rates is the heating full load air volume rate for the system.

3.1.4.4.3 Ducted Heating-Only Heat Pumps

Identify the certified heating full-load air volume rate and certified instructions for setting fan speed or controls. If there is no certified heating full-load air volume rate, use a value equal to the certified heating capacity of the unit times 400 scfm per 12,000 Btu/h. If there are no instructions for setting fan speed or controls, use the as-shipped settings.

a. For all ducted heating-only blower coil system heat pumps, except those having a constant-air-volume-rate indoor blower. Conduct the following steps only during the first test, the H1 or H1₂ est:

Step (1) Adjust the exhaust fan of the airflow measuring apparatus to achieve the certified heating full-load air volume rate.

Step (2) Measure the external static pressure.

Step (3) If this pressure is equal to or greater than the Table 3 minimum external static pressure that applies given the heating-only heat pump's rated heating capacity, the pressure requirement is satisfied; proceed to step 7 of this section. If this pressure is not equal to or greater than the applicable Table 3 minimum external static pressure, proceed to step 4 of this section;

Step (4) Increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until either (i) the pressure is equal to the applicable Table 3 minimum external static pressure or (ii) the measured air volume rate equals 90 percent or less of the heating full-load air volume rate, whichever occurs first;

Step (5) If the conditions of step 4 (i) of this section occur first, the pressure requirement is satisfied; proceed to step 7 of this section. If the conditions of step 4 (ii) of this section occur first, proceed to step 6 of this section;

Step (6) Make an incremental change to the setup of the indoor blower (*e.g.*, next highest fan motor pin setting, next highest fan motor speed) and repeat the evaluation process beginning above, at step 1 of this section. If the indoor blower setup cannot be further changed, increase the external static pressure by adjusting the exhaust fan of the airflow measuring apparatus until it equals the applicable Table 3 minimum external static pressure; proceed to step 7 of this section;

Step (7) The airflow constraints have been satisfied. Use the measured air volume rate as the heating full-load air volume rate. Use the final fan speed or control settings for all tests that use the heating full-load air volume rate.

b. For ducted heating-only blower coil system heat pumps having a constant-air-volume-rate indoor blower. For all tests that specify the heating full-load air volume rate, obtain an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{var} , defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than, the applicable Table 3 minimum. Additional test steps as described in section 3.9.1(c) of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For ducted heating-only coil-only system heat pumps in the H1 or H1₂ Test, (exclusively), the pressure drop across the indoor coil assembly must not exceed 0.30 inches of water. If this pressure drop is exceeded, reduce the air volume rate until the measured pressure drop equals the specified maximum. Use this reduced air volume rate for all tests that require the heating full-load air volume rate.

3.1.4.4.4 Non-Ducted Heat Pumps, Including Non-Ducted Heating-Only Heat Pumps

For non-ducted heat pumps, the heating full-load air volume rate is the air volume rate that results during each test when the unit operates at an external static pressure of zero inches of water.

3.1.4.4.5 Heating Minimum Air Volume Rate

3.1.4.4.5.1 Ducted Heat Pumps Where the Heating and Cooling Minimum Air Volume Rates Are the Same

a. Use the cooling minimum air volume rate as the heating minimum air volume rate for:

- (1) Ducted blower coil system heat pumps that do not have a constant-air-volume indoor blower, and that operates at the same airflow-control setting during both the A₁ and the H1₁ tests;
- (2) Ducted blower coil system heat pumps with constant-air-flow indoor blowers installed that provide the same air flow for the A₁ and the H1₁ Tests; and

(3) Ducted coil-only system heat pumps.

b. For heat pumps that meet the above criteria "1" and "3," no minimum requirements apply to the measured external or internal, respectively, static pressure. Use the final indoor blower control settings as determined when setting the cooling minimum air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if

necessary to reset to the cooling minimum air volume rate obtained in section 3.1.4.2 of this appendix. For heat pumps that meet the above criterion “2,” test at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{var} , defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than, the same target minimum external static pressure as was specified for the A_1 cooling mode test. Additional test steps as described in section 3.9.1(c) of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

3.1.4.5.2. Ducted Heat Pumps Where the Heating and Cooling Minimum Air Volume Rates Are Different Due to Changes in Indoor Blower Operation, *i.e.*, Speed Adjustment by the System Controls

Identify the certified heating minimum air volume rate and certified instructions for setting fan speed or controls. If there is no certified heating minimum air volume rate, use the final indoor blower control settings as determined when setting the cooling minimum air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling minimum air volume rate obtained in section 3.1.4.2 of this appendix. Otherwise, calculate the target minimum external static pressure as described in section 3.1.4.2 of this appendix.

a. For ducted blower coil system heat pumps that do not have a constant-air-volume indoor blower, adjust for external static pressure as described in section 3.1.4.2.a of this appendix for cooling minimum air volume rate.

b. For ducted heat pumps tested with constant-air-volume indoor blowers installed, conduct all tests that specify the heating minimum air volume rate—(*i.e.*, the H_{01} , H_{11} , H_{21} , and H_{31} Tests)—at an external static pressure that does not cause an automatic shutdown of the indoor blower while being as close to, but not less than the air volume rate variation Q_{var} , defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than the target minimum external static pressure. Additional test steps as described in section 3.9.1.c of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For ducted two-capacity blower coil system northern heat pumps, use the

appropriate approach of the above two cases.

d. For ducted two-capacity coil-only system heat pumps, use the cooling minimum air volume rate as the heating minimum air volume rate. For ducted two-capacity coil-only system northern heat pumps, use the cooling full-load air volume rate as the heating minimum air volume rate. For ducted two-capacity heating-only coil-only system heat pumps, the heating minimum air volume rate is the higher of the rate specified by the manufacturer in the test setup instructions included with the unit or 75 percent of the heating full-load air volume rate. During the laboratory tests on a coil-only system, obtain the heating minimum air volume rate without regard to the pressure drop across the indoor coil assembly.

e. For non-ducted heat pumps, the heating minimum air volume rate is the air volume rate that results during each test when the unit operates at an external static pressure of zero inches of water and at the indoor blower setting used at low compressor capacity (two-capacity system) or minimum compressor speed (variable-speed system). For units having a single-speed compressor and a variable-speed, variable-air-volume indoor blower, use the lowest fan setting allowed for heating.

f. For ducted systems with multiple indoor blowers within a single indoor section, obtain the heating minimum air volume rate using the same “on” indoor blowers as used for the cooling minimum air volume rate. Using the target external static pressure and the certified air volume rates, follow the procedures as described in section 3.1.4.5.2.a of this appendix if the indoor blowers are not constant-air-volume indoor blowers or as described in section 3.1.4.5.2.b of this appendix if the indoor blowers are constant-air-volume indoor blowers. The sum of the individual “on” indoor blowers’ air volume rates is the heating full-load air volume rate for the system.

3.1.4.6 Heating Intermediate Air Volume Rate

Identify the certified heating intermediate air volume rate and certified instructions for setting fan speed or controls. If there is no certified heating intermediate air volume rate, use the final indoor blower control settings as determined when setting the heating full-load air volume rate, and readjust the exhaust fan of the airflow measuring apparatus if necessary to reset to the cooling full load air volume rate obtained in section 3.1.4.2 of this appendix. Calculate the target minimum

external static pressure as described in section 3.1.4.2 of this appendix.

a. For ducted blower coil system heat pumps that do not have a constant-air-volume indoor blower, adjust for external static pressure as described in section 3.1.4.2.a of this appendix for cooling minimum air volume rate.

b. For ducted heat pumps tested with constant-air-volume indoor blowers installed, conduct the H_{2v} Test at an external static pressure that does not cause an automatic shutdown of the indoor blower or air volume rate variation Q_{var} , defined in section 3.1.4.1.1.b of this appendix, greater than 10 percent, while being as close to, but not less than the target minimum external static pressure. Additional test steps as described in section 3.9.1(c) of this appendix are required if the measured external static pressure exceeds the target value by more than 0.03 inches of water.

c. For non-ducted heat pumps, the heating intermediate air volume rate is the air volume rate that results when the heat pump operates at an external static pressure of zero inches of water and at the fan speed selected by the controls of the unit for the H_{2v} Test conditions.

3.1.4.7 Heating Nominal Air Volume Rate

The manufacturer must specify the heating nominal air volume rate and the instructions for setting fan speed or controls. Calculate target minimum external static pressure as described in section 3.1.4.2 of this appendix. Make adjustments as described in section 3.1.4.6 of this appendix for heating intermediate air volume rate so that the target minimum external static pressure is met or exceeded.

3.1.5 Indoor Test Room Requirement When the Air Surrounding the Indoor Unit Is Not Supplied From the Same Source as the Air Entering the Indoor Unit

If using a test set-up where air is ducted directly from the air conditioning apparatus to the indoor coil inlet (see Figure 2, Loop Air-Enthalpy Test Method Arrangement, of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3)), maintain the dry bulb temperature within the test room within ± 5.0 °F of the applicable sections 3.2 and 3.6 dry bulb temperature test condition for the air entering the indoor unit. Dew point shall be within 2 °F of the required inlet conditions.

3.1.6 Air Volume Rate Calculations

For all steady-state tests and for frost accumulation (H_2 , H_{21} , H_{22} , H_{2v}) tests,

calculate the air volume rate through the indoor coil as specified in sections 7.7.2.1 and 7.7.2.2 of ANSI/ASHRAE

37–2009. When using the outdoor air enthalpy method, follow sections 7.7.2.1 and 7.7.2.2 of ANSI/ASHRAE 37–2009

to calculate the air volume rate through the outdoor coil. To express air volume rates in terms of standard air, use:

$$\text{Equation 3-1} \quad \bar{V}_s = \frac{\bar{V}_{mx}}{0.075 \frac{\text{lbm da}}{\text{ft}^3} * v'_n * [1 + W_n]} = \frac{\bar{V}_{mx}}{0.075 \frac{\text{lbm da}}{\text{ft}^3} * v_n}$$

Where:

\bar{V}_s = air volume rate of standard (dry) air, (ft³/min)_{da}

\bar{V}_{mx} = air volume rate of the air-water vapor mixture, (ft³/min)_{mx}

v'_n = specific volume of air-water vapor mixture at the nozzle, ft³ per lbm of the air-water vapor mixture

W_n = humidity ratio at the nozzle, lbm of water vapor per lbm of dry air

0.075 = the density associated with standard (dry) air, (lbm/ft³)

v_n = specific volume of the dry air portion of the mixture evaluated at the dry-bulb temperature, vapor content, and barometric pressure existing at the nozzle, ft³ per lbm of dry air.

NOTE: In the first printing of ANSI/ASHRAE 37–2009, the second IP equation for

$$Q_{mi} \text{ should read, } Q_{mi} = 1097CA_n \sqrt{P_v v'_n}$$

3.1.7 Test Sequence

Manufacturers may optionally operate the equipment under test for a “break-in” period, not to exceed 20 hours, prior to conducting the test method specified in this section. A manufacturer who elects to use this optional compressor break-in period in its certification testing should record this information (including the duration) in the test data underlying the certified ratings that are required to be maintained under 10 CFR 429.71. When testing a ducted unit (except if a heating-only heat pump), conduct the A or A₂ Test first to establish the cooling full-load air volume rate. For ducted heat pumps where the heating and cooling full-load air volume rates are different, make the first heating mode test one that requires the heating full-load air volume rate. For ducted heating-only heat pumps, conduct the H1 or H₁₂ Test first to establish the heating full-load air volume rate. When conducting a cyclic test, always conduct it immediately after the steady-state test that requires the same test conditions. For variable-speed systems, the first test using the cooling minimum air volume rate should precede the E_v Test, and the first test using the heating minimum air volume rate must precede the H_{2v} Test. The test laboratory makes all other decisions on the test sequence.

3.1.8 Requirement for the Air Temperature Distribution Leaving the Indoor Coil

For at least the first cooling mode test and the first heating mode test, monitor the temperature distribution of the air

leaving the indoor coil using the grid of individual sensors described in sections 2.5 and 2.5.4 of this appendix. For the 30-minute data collection interval used to determine capacity, the maximum spread among the outlet dry bulb temperatures from any data sampling must not exceed 1.5 °F. Install the mixing devices described in section 2.5.4.2 of this appendix to minimize the temperature spread.

3.1.9 Requirement for the Air Temperature Distribution Entering the Outdoor Coil

Monitor the temperatures of the air entering the outdoor coil using the grid of temperature sensors described in section 2.11 of this appendix. For the 30-minute data collection interval used to determine capacity, the maximum difference between dry bulb temperatures measured at any of these locations must not exceed 1.5 °F.

3.1.10 Control of Auxiliary Resistive Heating Elements

Except as noted, disable heat pump resistance elements used for heating indoor air at all times, including during defrost cycles and if they are normally regulated by a heat comfort controller. For heat pumps equipped with a heat comfort controller, enable the heat pump resistance elements only during the below-described, short test. For single-speed heat pumps covered under section 3.6.1 of this appendix, the short test follows the H1 or, if conducted, the H1C Test. For two-capacity heat pumps and heat pumps covered under section 3.6.2 of this appendix, the short test

follows the H₁₂ Test. Set the heat comfort controller to provide the maximum supply air temperature. With the heat pump operating and while maintaining the heating full-load air volume rate, measure the temperature of the air leaving the indoor-side beginning 5 minutes after activating the heat comfort controller. Sample the outlet dry-bulb temperature at regular intervals that span 5 minutes or less. Collect data for 10 minutes, obtaining at least 3 samples. Calculate the average outlet temperature over the 10-minute interval, T_{cc}.

3.2 Cooling Mode Tests for Different Types of Air Conditioners and Heat Pumps

3.2.1 Tests for a System Having a Single-Speed Compressor and Fixed Cooling Air Volume Rate

This set of tests is for single-speed-compressor units that do not have a cooling minimum air volume rate or a cooling intermediate air volume rate that is different than the cooling full load air volume rate. Conduct two steady-state wet coil tests, the A and B Tests. Use the two optional dry-coil tests, the steady-state C Test and the cyclic D Test, to determine the cooling mode cyclic degradation coefficient, C_{D^c}. A default value for C_{D^c} may be used in lieu of conducting the cyclic test. The default value of C_{D^c} is 0.20. If testing outdoor units of central air conditioners or heat pumps that are not sold with indoor units, assign C_{D^c} the default value of 0.25. Table 4 specifies test conditions for these four tests.

TABLE 4—COOLING MODE TEST CONDITIONS FOR UNITS HAVING A SINGLE-SPEED COMPRESSOR AND A FIXED COOLING AIR VOLUME RATE

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Cooling air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
A Test—required (steady, wet coil)	80	67	95	1 75	Cooling full-load. ²
B Test—required (steady, wet coil)	80	67	82	1 65	Cooling full-load. ²
C Test—optional (steady, dry coil)	80	(³)	82	Cooling full-load. ²
D Test—optional (cyclic, dry coil)	80	(³)	82	(4)

¹ The specified test condition only applies if the unit rejects condensate to the outdoor coil.

² Defined in section 3.1.4.1 of this appendix.

³ The entering air must have a low enough moisture content so no condensate forms on the indoor coil. (It is recommended that an indoor wet-bulb temperature of 57 °F or less be used.)

⁴ Maintain the airflow nozzles static pressure difference or velocity pressure during the ON period at the same pressure difference or velocity pressure as measured during the C Test.

3.2.2 Tests for a Unit Having a Single-Speed Compressor Where the Indoor Section Uses a Single Variable-Speed Variable-Air-Volume Rate Indoor Blower or Multiple Indoor Blowers

3.2.2.1 Indoor Blower Capacity Modulation That Correlates With the Outdoor Dry Bulb Temperature or Systems With a Single Indoor Coil but Multiple Indoor Blowers

Conduct four steady-state wet coil tests: The A₂, A₁, B₂, and B₁ tests. Use

the two optional dry-coil tests, the steady-state C₁ test and the cyclic D₁ test, to determine the cooling mode cyclic degradation coefficient, C_D^c. A default value for C_D^c may be used in lieu of conducting the cyclic test. The default value of C_D^c is 0.20.

3.2.2.2 Indoor Blower Capacity Modulation Based on Adjusting the Sensible to Total (S/T) Cooling Capacity Ratio

The testing requirements are the same as specified in section 3.2.1 of this appendix and Table 4. Use a cooling full-load air volume rate that represents a normal installation. If performed, conduct the steady-state C Test and the cyclic D Test with the unit operating in the same S/T capacity control mode as used for the B Test.

TABLE 5—COOLING MODE TEST CONDITIONS FOR UNITS WITH A SINGLE-SPEED COMPRESSOR THAT MEET THE SECTION 3.2.2.1 INDOOR UNIT REQUIREMENTS

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Cooling air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
A ₂ Test—required (steady, wet coil)	80	67	95	1 75	Cooling full-load. ²
A ₁ Test—required (steady, wet coil)	80	67	95	1 75	Cooling minimum. ³
B ₂ Test—required (steady, wet coil)	80	67	82	1 65	Cooling full-load. ²
B ₁ Test—required (steady, wet coil)	80	67	82	1 65	Cooling minimum. ³
C ₁ Test ⁴ —optional (steady, dry coil)	80	(⁴)	82	Cooling minimum. ³
D ₁ Test ⁴ —optional (cyclic, dry coil)	80	(⁴)	82	(5)

¹ The specified test condition only applies if the unit rejects condensate to the outdoor coil.

² Defined in section 3.1.4.1 of this appendix.

³ Defined in section 3.1.4.2 of this appendix.

⁴ The entering air must have a low enough moisture content so no condensate forms on the indoor coil. (It is recommended that an indoor wet-bulb temperature of 57 °F or less be used.)

⁵ Maintain the airflow nozzles static pressure difference or velocity pressure during the ON period at the same pressure difference or velocity pressure as measured during the C₁ Test.

3.2.3 Tests for a Unit Having a Two-Capacity Compressor (See Section 1.2 of This Appendix, Definitions)

a. Conduct four steady-state wet coil tests: the A₂, B₂, B₁, and F₁ Tests. Use the two optional dry-coil tests, the steady-state C₁ Test and the cyclic D₁ Test, to determine the cooling-mode cyclic-degradation coefficient, C_D^c. A default value for C_D^c may be used in lieu of conducting the cyclic test. The default value of C_D^c is 0.20. Table 6 specifies test conditions for these six tests.

b. For units having a variable speed indoor blower that is modulated to adjust the sensible to total (S/T) cooling capacity ratio, use cooling full-load and cooling minimum air volume rates that represent a normal installation. Additionally, if conducting the dry-coil tests, operate the unit in the same S/T capacity control mode as used for the B₁ Test.

c. Test two-capacity, northern heat pumps (see section 1.2 of this appendix, Definitions) in the same way as a single speed heat pump with the unit operating exclusively at low compressor

capacity (see section 3.2.1 of this appendix and Table 4).

d. If a two-capacity air conditioner or heat pump locks out low-capacity operation at higher outdoor temperatures, then use the two dry-coil tests, the steady-state C₂ Test and the cyclic D₂ Test, to determine the cooling-mode cyclic-degradation coefficient that only applies to on/off cycling from high capacity, C_D^c(k = 2). The default C_D^c(k = 2) is the same value as determined or assigned for the low-capacity cyclic-degradation coefficient, C_D^c [or equivalently, C_D^c(k = 1)].

TABLE 6—COOLING MODE TEST CONDITIONS FOR UNITS HAVING A TWO-CAPACITY COMPRESSOR

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor capacity	Cooling air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
A ₂ Test—required (steady, wet coil).	80	67	95	1 75	High	Cooling Full-Load. ²
B ₂ Test—required (steady, wet coil).	80	67	82	1 65	High	Cooling Full-Load. ²
B ₁ Test—required (steady, wet coil).	80	67	82	1 65	Low	Cooling Minimum. ³
C ₂ Test—optional (steady, dry-coil).	80	(⁴)	82	High	Cooling Full-Load. ²
D ₂ Test—optional (cyclic, dry-coil).	80	(⁴)	82	High	(⁵)
C ₁ Test—optional (steady, dry-coil).	80	(⁴)	82	Low	Cooling Minimum. ³
D ₁ Test—optional (cyclic, dry-coil).	80	(⁴)	82	Low	(⁶)
F ₁ Test—required (steady, wet coil).	80	67	67	1 53.5	Low	Cooling Minimum. ³

¹ The specified test condition only applies if the unit rejects condensate to the outdoor coil.

² Defined in section 3.1.4.1 of this appendix.

³ Defined in section 3.1.4.2 of this appendix.

⁴ The entering air must have a low enough moisture content so no condensate forms on the indoor coil. DOE recommends using an indoor air wet-bulb temperature of 57 °F or less.

⁵ Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the C₂ Test.

⁶ Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the C₁ Test.

3.2.4 Tests for a Unit Having a Variable-Speed Compressor

a. Conduct five steady-state wet coil tests: The A₂, E_v, B₂, B₁, and F₁ Tests. Use the two optional dry-coil tests, the steady-state G₁ Test and the cyclic I₁ Test, to determine the cooling mode

cyclic degradation coefficient, C_D^c. A default value for C_D^c may be used in lieu of conducting the cyclic test. The default value of C_D^c is 0.25. Table 7 specifies test conditions for these seven tests. The compressor shall operate at the same cooling full speed, measured by RPM or power input frequency (Hz),

for both the A₂ and B₂ tests. The compressor shall operate at the same cooling minimum speed, measured by RPM or power input frequency (Hz), for the B₁, F₁, G₁, and I₁ tests. Determine the cooling intermediate compressor speed cited in Table 7 using:

Cooling intermediate speed

$$= \text{Cooling minimum speed} + \frac{\text{Cooling full speed} - \text{Cooling minimum speed}}{3}$$

where a tolerance of plus 5 percent or the next higher inverter frequency step from that calculated is allowed.

b. For units that modulate the indoor blower speed to adjust the sensible to total (S/T) cooling capacity ratio, use cooling full-load, cooling intermediate, and cooling minimum air volume rates that represent a normal installation. Additionally, if conducting the dry-coil tests, operate the unit in the same S/T capacity control mode as used for the F₁ Test.

c. For multiple-split air conditioners and heat pumps (except where noted), the following procedures supersede the above requirements: For all Table 7 tests specified for a minimum compressor speed, at least one indoor unit must be turned off. The manufacturer shall designate the particular indoor unit(s) that is turned off. The manufacturer must also specify the compressor speed used for the Table 7 E_v Test, a cooling-mode intermediate compressor speed

that falls within ¼ and ¾ of the difference between the full and minimum cooling-mode speeds. The manufacturer should prescribe an intermediate speed that is expected to yield the highest EER for the given E_v Test conditions and bracketed compressor speed range. The manufacturer can designate that one or more indoor units are turned off for the E_v Test.

TABLE 7—COOLING MODE TEST CONDITION FOR UNITS HAVING A VARIABLE-SPEED COMPRESSOR

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor speed	Cooling air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
A ₂ Test—required (steady, wet coil).	80	67	95	1 75	Cooling Full	Cooling Full-Load. ²
B ₂ Test—required (steady, wet coil).	80	67	82	1 65	Cooling Full	Cooling Full-Load. ²
E _v Test—required (steady, wet coil).	80	67	87	1 69	Cooling Intermediate	Cooling Intermediate. ³
B ₁ Test—required (steady, wet coil).	80	67	82	1 65	Cooling Minimum	Cooling Minimum. ⁴
F ₁ Test—required (steady, wet coil).	80	67	67	1 53.5	Cooling Minimum	Cooling Minimum. ⁴
G ₁ Test ⁵ —optional (steady, dry-coil).	80	(⁶)	67	Cooling Minimum	Cooling Minimum. ⁴
I ₁ Test ⁵ —optional (cyclic, dry-coil).	80	(⁶)	67	Cooling Minimum	(⁶)

¹ The specified test condition only applies if the unit rejects condensate to the outdoor coil.

² Defined in section 3.1.4.1 of this appendix.

³ Defined in section 3.1.4.3 of this appendix.

⁴ Defined in section 3.1.4.2 of this appendix.

⁵ The entering air must have a low enough moisture content so no condensate forms on the indoor coil. DOE recommends using an indoor air wet bulb temperature of 57 °F or less.

⁶ Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure difference or velocity pressure as measured during the G₁ Test.

3.2.5 Cooling Mode Tests for Northern Heat Pumps With Triple-Capacity Compressors

Test triple-capacity, northern heat pumps for the cooling mode in the same way as specified in section 3.2.3 of this appendix for units having a two-capacity compressor.

3.2.6 Tests for an Air Conditioner or Heat Pump Having a Single Indoor Unit Having Multiple Indoor Blowers and Offering Two Stages of Compressor Modulation

Conduct the cooling mode tests specified in section 3.2.3 of this appendix.

3.3 Test Procedures for Steady-State Wet Coil Cooling Mode Tests (the A, A₂, A₁, B, B₂, B₁, E_v, and F₁ Tests)

a. For the pretest interval, operate the test room reconditioning apparatus and the unit to be tested until maintaining equilibrium conditions for at least 30 minutes at the specified section 3.2 test conditions. Use the exhaust fan of the airflow measuring apparatus and, if installed, the indoor blower of the test unit to obtain and then maintain the indoor air volume rate and/or external static pressure specified for the particular test. Continuously record (see section 1.2 of this appendix, Definitions):

- (1) The dry-bulb temperature of the air entering the indoor coil,
- (2) The water vapor content of the air entering the indoor coil,

(3) The dry-bulb temperature of the air entering the outdoor coil, and

(4) For the section 2.2.4 of this appendix cases where its control is required, the water vapor content of the air entering the outdoor coil.

Refer to section 3.11 of this appendix for additional requirements that depend on the selected secondary test method.

b. After satisfying the pretest equilibrium requirements, make the measurements specified in Table 3 of ANSI/ASHRAE 37–2009 for the indoor air enthalpy method and the user-selected secondary method. Make said Table 3 measurements at equal intervals that span 5 minutes or less. Continue data sampling until reaching a 30-minute period (e.g., seven consecutive 5-minute samples) where the test tolerances specified in Table 8 are satisfied. For those continuously recorded parameters, use the entire data set from the 30-minute interval to evaluate Table 8 compliance. Determine the average electrical power consumption of the air conditioner or heat pump over the same 30-minute interval.

c. Calculate indoor-side total cooling capacity and sensible cooling capacity as specified in sections 7.3.3.1 and 7.3.3.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3). To calculate capacity, use the averages of the measurements (e.g. inlet and outlet dry bulb and wet bulb temperatures measured at the psychrometers) that are continuously recorded for the same 30-minute

interval used as described above to evaluate compliance with test tolerances. Do not adjust the parameters used in calculating capacity for the permitted variations in test conditions. Evaluate air enthalpies based on the measured barometric pressure. Use the values of the specific heat of air given in section 7.3.3.1 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3) for calculation of the sensible cooling capacities. Assign the average total space cooling capacity, average sensible cooling capacity, and electrical power consumption over the 30-minute data collection interval to the variables $\dot{Q}_c^k(T)$, $\dot{Q}_{sc}^k(T)$ and $\dot{E}_c^k(T)$, respectively. For these three variables, replace the “T” with the nominal outdoor temperature at which the test was conducted. The superscript k is used only when testing multi-capacity units. Use the superscript k = 2 to denote a test with the unit operating at high capacity or full speed, k = 1 to denote low capacity or minimum speed, and k = v to denote the intermediate speed.

d. For coil-only system tests, decrease $\dot{Q}_c^k(T)$ by

$$\frac{1250 \text{ Btu/h}}{1000 \text{ scfm}} * \bar{V}_s$$

where \bar{V}_s is the average measured indoor air volume rate expressed in units of cubic feet per minute of standard air (scfm).

and increase $\dot{E}_c^k(T)$ by,

$$\frac{365 \text{ W}}{1000 \text{ scfm}} * \bar{V}_s$$

TABLE 8—TEST OPERATING AND TEST CONDITION TOLERANCES FOR SECTION 3.3 STEADY-STATE WET COIL COOLING MODE TESTS AND SECTION 3.4 DRY COIL COOLING MODE TESTS

	Test operating tolerance ¹	Test condition tolerance ¹
Indoor dry-bulb, °F:		
Entering temperature	2.0	0.5
Leaving temperature	2.0
Indoor wet-bulb, °F:		
Entering temperature	1.0	² 0.3
Leaving temperature	² 1.0
Outdoor dry-bulb, °F:		
Entering temperature	2.0	0.5
Leaving temperature	³ 2.0
Outdoor wet-bulb, °F:		
Entering temperature	1.0	⁴ 0.3
Leaving temperature	³ 1.0
External resistance to airflow, inches of water	0.12	⁵ 0.02
Electrical voltage, % of rdg	2.0	1.5
Nozzle pressure drop, % of rdg	8.0

¹ See section 1.2 of this appendix, Definitions.

² Only applies during wet coil tests; does not apply during steady-state, dry coil cooling mode tests.

³ Only applies when using the outdoor air enthalpy method.

⁴ Only applies during wet coil cooling mode tests where the unit rejects condensate to the outdoor coil.

⁵ Only applies when testing non-ducted units.

e. For air conditioners and heat pumps having a constant-air-volume-rate indoor blower, the five additional steps listed below are required if the average of the measured external static pressures exceeds the applicable sections 3.1.4 minimum (or target) external static pressure (ΔP_{min}) by 0.03 inches of water or more.

(1) Measure the average power consumption of the indoor blower

motor ($\dot{E}_{fan,1}$) and record the corresponding external static pressure (ΔP_1) during or immediately following the 30-minute interval used for determining capacity.

(2) After completing the 30-minute interval and while maintaining the same test conditions, adjust the exhaust fan of the airflow measuring apparatus until the external static pressure increases to approximately $\Delta P_1 + (\Delta P_1 - \Delta P_{min})$.

(3) After re-establishing steady readings of the fan motor power and external static pressure, determine average values for the indoor blower power ($\dot{E}_{fan,2}$) and the external static pressure (ΔP_2) by making measurements over a 5-minute interval.

(4) Approximate the average power consumption of the indoor blower motor at ΔP_{min} using linear extrapolation:

$$\dot{E}_{fan,min} = \frac{\dot{E}_{fan,2} - \dot{E}_{fan,1}}{\Delta P_2 - \Delta P_1} (\Delta P_{min} - \Delta P_1) + \dot{E}_{fan,1}$$

(5) Increase the total space cooling capacity, $\dot{Q}_c^k(T)$, by the quantity $(\dot{E}_{fan,1} - \dot{E}_{fan,min})$, when expressed on a Btu/h basis. Decrease the total electrical power, $\dot{E}_c^k(T)$, by the same fan power difference, now expressed in watts.

3.4 Test Procedures for the Steady-State Dry-Coil Cooling-Mode Tests (the C, C₁, C₂, and G₁ Tests)

a. Except for the modifications noted in this section, conduct the steady-state

dry coil cooling mode tests as specified in section 3.3 of this appendix for wet coil tests. Prior to recording data during the steady-state dry coil test, operate the unit at least one hour after achieving dry coil conditions. Drain the drain pan and plug the drain opening. Thereafter, the drain pan should remain completely dry.

b. Denote the resulting total space cooling capacity and electrical power derived from the test as $\dot{Q}_{ss,dry}$ and $\dot{E}_{ss,dry}$.

With regard to a section 3.3 deviation, do not adjust $\dot{Q}_{ss,dry}$ for duct losses (*i.e.*, do not apply section 7.3.3.3 of ANSI/ASHRAE 37–2009). In preparing for the section 3.5 cyclic tests of this appendix, record the average indoor-side air volume rate, \bar{V} , specific heat of the air, $C_{p,a}$ (expressed on dry air basis), specific volume of the air at the nozzles, v'_n , humidity ratio at the nozzles, W_n , and either pressure difference or velocity pressure for the flow nozzles.

For units having a variable-speed indoor blower (that provides either a constant or variable air volume rate) that will or may be tested during the cyclic dry coil cooling mode test with the indoor blower turned off (see section 3.5 of this appendix), include the electrical power used by the indoor blower motor among the recorded parameters from the 30-minute test.

c. If the temperature sensors used to provide the primary measurement of the indoor-side dry bulb temperature difference during the steady-state dry-coil test and the subsequent cyclic dry-coil test are different, include measurements of the latter sensors among the regularly sampled data. Beginning at the start of the 30-minute data collection period, measure and compute the indoor-side air dry-bulb temperature difference using both sets of instrumentation, ΔT (Set SS) and ΔT (Set CYC), for each equally spaced data sample. If using a consistent data sampling rate that is less than 1 minute, calculate and record minutely averages for the two temperature differences. If using a consistent sampling rate of one minute or more, calculate and record the two temperature differences from each data sample. After having recorded the seventh ($i = 7$) set of temperature differences, calculate the following ratio using the first seven sets of values:

$$F_{CD} = \frac{1}{7} \sum_{i=6}^i \frac{\Delta T(\text{Set SS})}{\Delta T(\text{Set CYC})}$$

Each time a subsequent set of temperature differences is recorded (if sampling more frequently than every 5 minutes), calculate F_{CD} using the most recent seven sets of values. Continue these calculations until the 30-minute period is completed or until a value for F_{CD} is calculated that falls outside the allowable range of 0.94–1.06. If the latter occurs, immediately suspend the test and identify the cause for the disparity in the two temperature difference measurements. Recalibration of one or both sets of instrumentation may be required. If all the values for F_{CD} are within the allowable range, save the final value of the ratio from the 30-minute test as F_{CD}^* . If the temperature sensors used to provide the primary measurement of the indoor-side dry bulb temperature difference during the steady-state dry-coil test and the subsequent cyclic dry-coil test are the same, set $F_{CD}^* = 1$.

3.5 Test Procedures for the Cyclic Dry-Coil Cooling-Mode Tests (the D, D₁, D₂, and I₁ Tests)

After completing the steady-state dry-coil test, remove the outdoor air enthalpy method test apparatus, if connected, and begin manual OFF/ON cycling of the unit's compressor. The test set-up should otherwise be identical to the set-up used during the steady-state dry coil test. When testing heat pumps, leave the reversing valve during the compressor OFF cycles in the same position as used for the compressor ON cycles, unless automatically changed by the controls of the unit. For units having a variable-speed indoor blower, the manufacturer has the option of electing at the outset whether to conduct the cyclic test with the indoor blower enabled or disabled. Always revert to testing with the indoor blower disabled if cyclic testing with the fan enabled is unsuccessful.

a. For all cyclic tests, the measured capacity must be adjusted for the thermal mass stored in devices and connections located between measured points. Follow the procedure outlined in section 7.4.3.4.5 of ASHRAE 116–2010 (incorporated by reference, see § 430.3) to ensure any required measurements are taken.

b. For units having a single-speed or two-capacity compressor, cycle the compressor OFF for 24 minutes and then ON for 6 minutes ($\Delta\tau_{\text{cyc,dry}} = 0.5$ hours). For units having a variable-speed compressor, cycle the compressor OFF for 48 minutes and then ON for 12 minutes ($\Delta\tau_{\text{cyc,dry}} = 1.0$ hours). Repeat the OFF/ON compressor cycling pattern until the test is completed. Allow the controls of the unit to regulate cycling of the outdoor fan. If an upturned duct is used, measure the dry-bulb temperature at the inlet of the device at least once every minute and ensure that its test operating tolerance is within 1.0 °F for each compressor OFF period.

c. Sections 3.5.1 and 3.5.2 of this appendix specify airflow requirements through the indoor coil of ducted and non-ducted indoor units, respectively. In all cases, use the exhaust fan of the airflow measuring apparatus (covered under section 2.6 of this appendix) along with the indoor blower of the unit, if installed and operating, to approximate a step response in the indoor coil airflow. Regulate the exhaust fan to quickly obtain and then maintain the flow nozzle static pressure difference or velocity pressure at the same value as was measured during the steady-state dry coil test. The pressure difference or velocity pressure should be within 2 percent of the value from

the steady-state dry coil test within 15 seconds after airflow initiation. For units having a variable-speed indoor blower that ramps when cycling on and/or off, use the exhaust fan of the airflow measuring apparatus to impose a step response that begins at the initiation of ramp up and ends at the termination of ramp down.

d. For units having a variable-speed indoor blower, conduct the cyclic dry coil test using the pull-thru approach described below if any of the following occur when testing with the fan operating:

- (1) The test unit automatically cycles off;
- (2) Its blower motor reverses; or
- (3) The unit operates for more than 30 seconds at an external static pressure that is 0.1 inches of water or more higher than the value measured during the prior steady-state test.

For the pull-thru approach, disable the indoor blower and use the exhaust fan of the airflow measuring apparatus to generate the specified flow nozzles static pressure difference or velocity pressure. If the exhaust fan cannot deliver the required pressure difference because of resistance created by the unpowered indoor blower, temporarily remove the indoor blower.

e. Conduct three complete compressor OFF/ON cycles with the test tolerances given in Table 9 satisfied. Calculate the degradation coefficient C_D for each complete cycle. If all three C_D values are within 0.02 of the average C_D then stability has been achieved, and the highest C_D value of these three shall be used. If stability has not been achieved, conduct additional cycles, up to a maximum of eight cycles total, until stability has been achieved between three consecutive cycles. Once stability has been achieved, use the highest C_D value of the three consecutive cycles that establish stability. If stability has not been achieved after eight cycles, use the highest C_D from cycle one through cycle eight, or the default C_D , whichever is lower.

f. With regard to the Table 9 parameters, continuously record the dry-bulb temperature of the air entering the indoor and outdoor coils during periods when air flows through the respective coils. Sample the water vapor content of the indoor coil inlet air at least every 2 minutes during periods when air flows through the coil. Record external static pressure and the air volume rate indicator (either nozzle pressure difference or velocity pressure) at least every minute during the interval that air flows through the indoor coil. (These regular measurements of the airflow rate indicator are in addition to

the required measurement at 15 seconds after flow initiation.) Sample the electrical voltage at least every 2 minutes beginning 30 seconds after compressor start-up. Continue until the compressor, the outdoor fan, and the indoor blower (if it is installed and operating) cycle off.

g. For ducted units, continuously record the dry-bulb temperature of the air entering (as noted above) and leaving the indoor coil. Or if using a thermopile, continuously record the difference

between these two temperatures during the interval that air flows through the indoor coil. For non-ducted units, make the same dry-bulb temperature measurements beginning when the compressor cycles on and ending when indoor coil airflow ceases.

h. Integrate the electrical power over complete cycles of length $\Delta\tau_{cyc,dry}$. For ducted blower coil systems tested with the unit's indoor blower operating for the cycling test, integrate electrical power from indoor blower OFF to

indoor blower OFF. For all other ducted units and for non-ducted units, integrate electrical power from compressor OFF to compressor OFF. (Some cyclic tests will use the same data collection intervals to determine the electrical energy and the total space cooling. For other units, terminate data collection used to determine the electrical energy before terminating data collection used to determine total space cooling.)

TABLE 9—TEST OPERATING AND TEST CONDITION TOLERANCES FOR CYCLIC DRY COIL COOLING MODE TESTS

	Test operating tolerance ¹	Test condition tolerance ¹
Indoor entering dry-bulb temperature, ² °F	2.0	0.5
Indoor entering wet-bulb temperature, °F		(³)
Outdoor entering dry-bulb temperature, ² °F	2.0	0.5
External resistance to airflow, ² inches of water	0.12	
Airflow nozzle pressure difference or velocity pressure, ² % of reading	8.0	⁴ 2.0
Electrical voltage ⁵ , % of rdg.	2.0	1.5

¹ See section 1.2 of this appendix, Definitions.

² Applies during the interval that air flows through the indoor (outdoor) coil except for the first 30 seconds after flow initiation. For units having a variable-speed indoor blower that ramps, the tolerances listed for the external resistance to airflow apply from 30 seconds after achieving full speed until ramp down begins.

³ Shall at no time exceed a wet-bulb temperature that results in condensate forming on the indoor coil.

⁴ The test condition shall be the average nozzle pressure difference or velocity pressure measured during the steady-state dry coil test.

⁵ Applies during the interval when at least one of the following—the compressor, the outdoor fan, or, if applicable, the indoor blower—are operating except for the first 30 seconds after compressor start-up.

If the Table 9 tolerances are satisfied over the complete cycle, record the

measured electrical energy consumption as $e_{cyc,dry}$ and express it in units of watt-

hours. Calculate the total space cooling delivered, $q_{cyc,dry}$, in units of Btu using,

$$q_{cyc,dry} = \frac{60 \cdot \bar{V} \cdot C_{p,a} \cdot \Gamma}{[v'_n \cdot (1 + W_n)]} = \frac{60 \cdot \bar{V} \cdot C_{p,a} \cdot \Gamma}{v_n} \quad \text{and} \quad \Gamma = F_{CD}^* \int_{\tau_1}^{\tau_2} [T_{a1}(\tau) - T_{a2}(\tau)] \delta\tau, \text{ hr} \cdot \text{°F}$$

Where,

\bar{V} , $C_{p,a}$, v'_n (or v_n), W_n , and F_{CD}^* are the values recorded during the section 3.4 dry coil steady-state test and

$T_{a1}(\tau)$ = dry bulb temperature of the air entering the indoor coil at time τ , °F.

$T_{a2}(\tau)$ = dry bulb temperature of the air leaving the indoor coil at time τ , °F.

τ_1 = for ducted units, the elapsed time when airflow is initiated through the indoor coil; for non-ducted units, the elapsed time when the compressor is cycled on, hr.

τ_2 = the elapsed time when indoor coil airflow ceases, hr.

Adjust the total space cooling delivered, $q_{cyc,dry}$, according to calculation method outlined in section

7.4.3.4.5 of ASHRAE 116–2010 (incorporated by reference, see § 430.3).

3.5.1 Procedures When Testing Ducted Systems

The automatic controls that are normally installed with the test unit must govern the OFF/ON cycling of the air moving equipment on the indoor side (exhaust fan of the airflow measuring apparatus and, if installed, the indoor blower of the test unit). For example, for ducted coil-only systems rated based on using a fan time delay relay, control the indoor coil airflow according to the rated ON and/or OFF delays provided by the relay. For ducted units having a variable-speed indoor

blower that has been disabled (and possibly removed), start and stop the indoor airflow at the same instances as if the fan were enabled. For all other ducted coil-only systems, cycle the indoor coil airflow in unison with the cycling of the compressor. If air damper boxes are used, close them on the inlet and outlet side during the OFF period. Airflow through the indoor coil should stop within 3 seconds after the automatic controls of the test unit (act to) de-energize the indoor blower. For ducted coil-only systems (excluding the special case where a variable-speed fan is temporarily removed), increase $e_{cyc,dry}$ by the quantity,

$$\text{Equation 3.5-2. } \frac{365 W}{1000 \text{ scfm}} * \bar{V}_s * [\tau_2 - \tau_1]$$

and decrease $q_{cyc,dry}$ by,

$$\text{Equation 3.5-3. } \frac{1250 \text{ Btu/h}}{1000 \text{ scfm}} * \bar{V}_s * [\tau_2 - \tau_1]$$

where \bar{V}_s is the average indoor air volume rate from the section 3.4 dry coil steady-state test and is expressed in units of cubic feet per minute of standard air (scfm). For units having a variable-speed indoor blower that is disabled during the cyclic test, increase $e_{cyc,dry}$ and decrease $q_{cyc,dry}$ based on:

a. The product of $[\tau_2 - \tau_1]$ and the indoor blower power measured during or following the dry coil steady-state test; or,

b. The following algorithm if the indoor blower ramps its speed when cycling.

(1) Measure the electrical power consumed by the variable-speed indoor blower at a minimum of three operating conditions: At the speed/air volume rate/external static pressure that was measured during the steady-state test, at operating conditions associated with the midpoint of the ramp-up interval, and at conditions associated with the midpoint of the ramp-down interval. For these measurements, the tolerances on the airflow volume or the external static pressure are the same as required for the section 3.4 steady-state test.

(2) For each case, determine the fan power from measurements made over a minimum of 5 minutes.

(3) Approximate the electrical energy consumption of the indoor blower if it had operated during the cyclic test using all three power measurements. Assume a linear profile during the ramp intervals. The manufacturer must provide the durations of the ramp-up and ramp-down intervals. If the test setup instructions included with the unit by the manufacturer specifies a ramp interval that exceeds 45 seconds, use a 45-second ramp interval nonetheless when estimating the fan energy.

3.5.2 Procedures When Testing Non-Ducted Indoor Units

Do not use airflow prevention devices when conducting cyclic tests on non-

ducted indoor units. Until the last OFF/ON compressor cycle, airflow through the indoor coil must cycle off and on in unison with the compressor. For the last OFF/ON compressor cycle—the one used to determine $e_{cyc,dry}$ and $q_{cyc,dry}$ —use the exhaust fan of the airflow measuring apparatus and the indoor blower of the test unit to have indoor airflow start 3 minutes prior to compressor cut-on and end three minutes after compressor cutoff.

Subtract the electrical energy used by the indoor blower during the 3 minutes prior to compressor cut-on from the integrated electrical energy, $e_{cyc,dry}$. Add the electrical energy used by the indoor blower during the 3 minutes after compressor cutoff to the integrated cooling capacity, $q_{cyc,dry}$. For the case where the non-ducted indoor unit uses a variable-speed indoor blower which is disabled during the cyclic test, correct $e_{cyc,dry}$ and $q_{cyc,dry}$ using the same approach as prescribed in section 3.5.1 of this appendix for ducted units having a disabled variable-speed indoor blower.

3.5.3 Cooling-Mode Cyclic-Degradation Coefficient Calculation

Use the two dry-coil tests to determine the cooling-mode cyclic-degradation coefficient, C_D^c . Append “(k = 2)” to the coefficient if it corresponds to a two-capacity unit cycling at high capacity. The default value for two-capacity units cycling at high capacity, however, is the low-capacity coefficient, *i.e.*, $C_D^c(k = 2) = C_D^c$. Evaluate C_D^c using the above results and those from the section 3.4 dry-coil steady-state test.

$$C_D^c = \frac{1 - \frac{EER_{cyc,dry}}{EER_{ss,dry}}}{1 - CLF}$$

where:

$$EER_{cyc,dry} = \frac{q_{cyc,dry}}{e_{cyc,dry}}$$

the average energy efficiency ratio during the cyclic dry coil cooling mode test, Btu/W·h

$$EER_{ss,dry} = \frac{\dot{Q}_{ss,dry}}{\dot{E}_{ss,dry}}$$

the average energy efficiency ratio during the steady-state dry coil cooling mode test, Btu/W·h

$$CLF = \frac{q_{cyc,dry}}{Q_{ss,dry} * \Delta\tau_{cyc,dry}}$$

the cooling load factor dimensionless

Round the calculated value for C_D^c to the nearest 0.01. If C_D^c is negative, then set it equal to zero.

3.6 Heating Mode Tests for Different Types of Heat Pumps, Including Heating-Only Heat Pumps

3.6.1 Tests for a Heat Pump Having a Single-Speed Compressor and Fixed Heating Air Volume Rate

This set of tests is for single-speed-compressor heat pumps that do not have a heating minimum air volume rate or a heating intermediate air volume rate that is different than the heating full load air volume rate. Conduct the optional high temperature cyclic (H1C) test to determine the heating mode cyclic-degradation coefficient, C_D^h . A default value for C_D^h may be used in lieu of conducting the cyclic test. The default value of C_D^h is 0.25. Test conditions for the four tests are specified in Table 10.

TABLE 10—HEATING MODE TEST CONDITIONS FOR UNITS HAVING A SINGLE-SPEED COMPRESSOR AND A FIXED-SPEED INDOOR BLOWER, A CONSTANT AIR VOLUME RATE INDOOR BLOWER, OR NO INDOOR BLOWER

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
H1 Test (required, steady)	70	60 (max)	47	43	Heating Full-load. ¹
H1C Test (optional, cyclic)	70	60 (max)	47	43	(?).
H2 Test (required)	70	60 (max)	35	33	Heating Full-load. ¹
H3 Test (required, steady)	70	60 (max)	17	15	Heating Full-load. ¹

¹ Defined in section 3.1.4.4 of this appendix.

² Maintain the airflow nozzles static pressure difference or velocity pressure during the ON period at the same pressure difference or velocity pressure as measured during the H1 Test.

3.6.2 Tests for a heat pump having a single-speed compressor and a single indoor unit having either (1) a variable speed, variable-air-rate indoor blower whose capacity modulation correlates with outdoor dry bulb temperature or (2) multiple indoor blowers. Conduct five tests: Two high temperature tests (H1₂ and H1₁), one frost accumulation

test (H2₂), and two low temperature tests (H3₂ and H3₁). Conducting an additional frost accumulation test (H2₁) is optional. Conduct the optional high temperature cyclic (H1C₁) test to determine the heating mode cyclic-degradation coefficient, C_D^h. A default value for C_D^h may be used in lieu of conducting the cyclic. The default value

of C_D^h is 0.25. Test conditions for the seven tests are specified in Table 11. If the optional H2₁ test is not performed, use the following equations to approximate the capacity and electrical power of the heat pump at the H2₁ test conditions:

$$\dot{Q}_h^{k=1}(35) = QR_h^{k=2}(35) * \{ \dot{Q}_h^{k=1}(17) + 0.6 * [\dot{Q}_h^{k=1}(47) - \dot{Q}_h^{k=1}(17)] \}$$

$$\dot{E}_h^{k=1}(35) = PR_h^{k=2}(35) * \{ \dot{E}_h^{k=1}(17) + 0.6 * [\dot{E}_h^{k=1}(47) - \dot{E}_h^{k=1}(17)] \}$$

where:

$$\dot{Q}_h^{k=2}(35) = \frac{\dot{Q}_h^{k=2}(35)}{\dot{Q}_h^{k=2}(17) + 0.6 * [\dot{Q}_h^{k=2}(47) - \dot{Q}_h^{k=2}(17)]}$$

$$PR_h^{k=2}(35) = \frac{\dot{E}_h^{k=2}(35)}{\dot{E}_h^{k=2}(17) + 0.6 * [\dot{E}_h^{k=2}(47) - \dot{E}_h^{k=2}(17)]}$$

The quantities $\dot{Q}_h^{k=2}(47)$, $\dot{E}_h^{k=2}(47)$, $\dot{Q}_h^{k=1}(47)$, and $\dot{E}_h^{k=1}(47)$ are determined from the H1₂ and H1₁ tests and evaluated as specified in section 3.7 of this appendix; the quantities $\dot{Q}_h^{k=2}(35)$

and $\dot{E}_h^{k=2}(35)$ are determined from the H2₂ test and evaluated as specified in section 3.9 of this appendix; and the quantities $\dot{Q}_h^{k=2}(17)$, $\dot{E}_h^{k=2}(17)$, $\dot{Q}_h^{k=1}(17)$, and $\dot{E}_h^{k=1}(17)$, are determined

from the H3₂ and H3₁ tests and evaluated as specified in section 3.10 of this appendix.

TABLE 11—HEATING MODE TEST CONDITIONS FOR UNITS WITH A SINGLE-SPEED COMPRESSOR THAT MEET THE SECTION 3.6.2 INDOOR UNIT REQUIREMENTS

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
H1 ₂ Test (required, steady)	70	60 (max)	47	43	Heating Full-load. ¹
H1 ₁ Test (required, steady)	70	60 (max)	47	43	Heating Minimum. ²
H1C ₁ Test (optional, cyclic)	70	60 (max)	47	43	(³)
H2 ₂ Test (required)	70	60 (max)	35	33	Heating Full-load. ¹
H2 ₁ Test (optional)	70	60 (max)	35	33	Heating Minimum. ²
H3 ₂ Test (required, steady)	70	60 (max)	17	15	Heating Full-load. ¹

TABLE 11—HEATING MODE TEST CONDITIONS FOR UNITS WITH A SINGLE-SPEED COMPRESSOR THAT MEET THE SECTION 3.6.2 INDOOR UNIT REQUIREMENTS—Continued

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb	
H3 ₁ Test (required, steady)	70	60 ^(max)	17	15	Heating Minimum. ²

¹ Defined in section 3.1.4.4 of this appendix.

² Defined in section 3.1.4.5 of this appendix.

³ Maintain the airflow nozzles static pressure difference or velocity pressure during the ON period at the same pressure difference or velocity pressure as measured during the H1₁ test.

3.6.3 Tests for a Heat Pump Having a Two-Capacity Compressor (see Section 1.2 of This Appendix, Definitions), Including Two-Capacity, Northern Heat Pumps (see Section 1.2 of This Appendix, Definitions)

a. Conduct one maximum temperature test (H0₁), two high temperature tests (H1₂ and H1₁), one frost accumulation

test (H2₂), and one low temperature test (H3₂). Conduct an additional frost accumulation test (H2₁) and low temperature test (H3₁) if both of the following conditions exist:

(1) Knowledge of the heat pump's capacity and electrical power at low compressor capacity for outdoor temperatures of 37 °F and less is needed to complete the section 4.2.3 of this

appendix seasonal performance calculations; and

(2) The heat pump's controls allow low-capacity operation at outdoor temperatures of 37 °F and less.

If the above two conditions are met, an alternative to conducting the H2₁ frost accumulation is to use the following equations to approximate the capacity and electrical power:

$$\dot{Q}_h^{k=1}(35) = 0.90 * \{ \dot{Q}_h^{k=1}(17) + 0.6 * [\dot{Q}_h^{k=1}(47) - \dot{Q}_h^{k=1}(17)] \}$$

$$\dot{E}_h^{k=1}(35) = 0.985 * \{ \dot{E}_h^{k=1}(17) + 0.6 * [\dot{E}_h^{k=1}(47) - \dot{E}_h^{k=1}(17)] \}$$

Determine the quantities $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ from the H1₁ test and evaluate them according to section 3.7 of this appendix. Determine the quantities $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17)$ from the H3₁ test and evaluate them according to section 3.10 of this appendix.

b. Conduct the optional high temperature cyclic test (H1C₁) to determine the heating mode cyclic-degradation coefficient, C_D^h. A default value for C_D^h may be used in lieu of conducting the cyclic. The default value of C_D^h is 0.25. If a two-capacity heat pump locks out low capacity operation at lower outdoor temperatures, conduct

the high temperature cyclic test (H1C₂) to determine the high-capacity heating mode cyclic-degradation coefficient, C_D^h (k=2). The default C_D^h (k=2) is the same value as determined or assigned for the low-capacity cyclic-degradation coefficient, C_D^h [or equivalently, C_D^h (k=1)]. Table 12 specifies test conditions for these nine tests.

TABLE 12—HEATING MODE TEST CONDITIONS FOR UNITS HAVING A TWO-CAPACITY COMPRESSOR

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor capacity	Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
H0 ₁ Test (required, steady).	70	60 ^(max)	62	56.5	Low	Heating Minimum. ¹
H1 ₂ Test (required, steady).	70	60 ^(max)	47	43	High	Heating Full-Load. ²
H1C ₂ Test (optional, ⁷ cyclic).	70	60 ^(max)	47	43	High	(³)
H1 ₁ Test (required)	70	60 ^(max)	47	43	Low	Heating Minimum. ¹
H1C ₁ Test (optional, cyclic).	70	60 ^(max)	47	43	Low	(⁴)
H2 ₂ Test (required)	70	60 ^(max)	35	33	High	Heating Full-Load. ²
H2 ₁ Test ^{5 6} (required)	70	60 ^(max)	35	33	Low	Heating Minimum. ¹
H3 ₂ Test (required, steady).	70	60 ^(max)	17	15	High	Heating Full-Load. ²
H3 ₁ Test ⁵ (required, steady).	70	60 ^(max)	17	15	Low	Heating Minimum. ¹

¹ Defined in section 3.1.4.5 of this appendix.

² Defined in section 3.1.4.4 of this appendix.

³ Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the H1₂ test.

⁴ Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the H1₁ test.

⁵ Required only if the heat pump's performance when operating at low compressor capacity and outdoor temperatures less than 37 °F is needed to complete the section 4.2.3 HSPF calculations.

⁶ If table note #5 applies, the section 3.6.3 equations for $\dot{Q}_h^{k=1}$ (35) and $\dot{E}_h^{k=1}$ (17) may be used in lieu of conducting the H2₁ test.

⁷ Required only if the heat pump locks out low capacity operation at lower outdoor temperatures.

3.6.4 Tests for a Heat Pump Having a Variable-Speed Compressor

a. Conduct one maximum temperature test (H0₁), two high temperature tests (H1₂ and H1₁), one frost accumulation test (H2_v), and one low temperature test (H3₂). Conducting one or both of the following tests is optional: An additional high temperature test (H1_N) and an additional frost accumulation

test (H2₂). Conduct the optional maximum temperature cyclic (H0C₁) test to determine the heating mode cyclic-degradation coefficient, C_D^h. A default value for C_D^h may be used in lieu of conducting the cyclic. The default value of C_D^h is 0.25. Test conditions for the eight tests are specified in Table 13. The compressor shall operate at the same heating full speed, measured by RPM or power

input frequency (Hz), for the H1₂, H2₂, and H3₂ tests. The compressor shall operate at the same heating minimum speed, measured by RPM or power input frequency (Hz), for the H0₁, H0C₁, and H1₁ tests. Determine the heating intermediate compressor speed cited in Table 13 using the heating mode full and minimum compressors speeds and: Heating intermediate speed

$$= \text{Heating minimum speed} + \frac{\text{Heating full speed} - \text{Heating minimum speed}}{3}$$

Where a tolerance of plus 5 percent or the next higher inverter frequency step from that calculated is allowed.

If the H2₂ test is not done, use the following equations to approximate the

capacity and electrical power at the H2₂ test conditions:

$$\dot{Q}_h^{k=2}(35) = 0.90 * \{ \dot{Q}_h^{k=2}(17) + 0.6 * [\dot{Q}_h^{k=2}(47) - \dot{Q}_h^{k=2}(17)] \}$$

$$\dot{E}_h^{k=2}(35) = 0.985 * \{ \dot{E}_h^{k=2}(17) + 0.6 * [\dot{E}_h^{k=2}(47) - \dot{E}_h^{k=2}(17)] \}$$

b. Determine the quantities $\dot{Q}_h^{k=2}(47)$ and from $\dot{E}_h^{k=2}(47)$ from the H1₂ test and evaluate them according to section 3.7 of this appendix. Determine the quantities $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the H3₂ test and evaluate them according to section 3.10 of this

appendix. For heat pumps where the heating mode full compressor speed exceeds its cooling mode full compressor speed, conduct the H1_N test if the manufacturer requests it. If the H1_N test is done, operate the heat pump's compressor at the same speed as

the speed used for the cooling mode A₂ test. Refer to the last sentence of section 4.2 of this appendix to see how the results of the H1_N test may be used in calculating the heating seasonal performance factor.

TABLE 13—HEATING MODE TEST CONDITIONS FOR UNITS HAVING A VARIABLE-SPEED COMPRESSOR

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor speed	Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
H0 ₁ test (required, steady)	70	60(max)	62	56.5	Heating Minimum	Heating Minimum. ¹
H0C ₁ test (optional, cyclic)	70	60(max)	62	56.5	Heating Minimum	(?)
H1 ₂ test (required, steady)	70	60(max)	47	43	Heating Full	Heating Full-Load. ³
H1 ₁ test (required, steady)	70	60(max)	47	43	Heating Minimum	Heating Minimum. ¹
H1 _N test (optional, steady)	70	60(max)	47	43	Cooling Full	Heating Nominal. ⁴
H2 ₂ test (optional)	70	60(max)	35	33	Heating Full	Heating Full-Load. ³
H2 _v test (required)	70	60(max)	35	33	Heating Intermediate	Heating Intermediate. ⁵
H3 ₂ test (required, steady)	70	60(max)	17	15	Heating Full	Heating Full-Load. ³

¹ Defined in section 3.1.4.5 of this appendix.

² Maintain the airflow nozzle(s) static pressure difference or velocity pressure during an ON period at the same pressure or velocity as measured during the H0₁ test.

³ Defined in section 3.1.4.4 of this appendix.

⁴ Defined in section 3.1.4.7 of this appendix.

⁵ Defined in section 3.1.4.6 of this appendix.

c. For multiple-split heat pumps (only), the following procedures supersede the above requirements. For all Table 13 tests specified for a

minimum compressor speed, at least one indoor unit must be turned off. The manufacturer shall designate the particular indoor unit(s) that is turned

off. The manufacturer must also specify the compressor speed used for the Table 13 H2_v test, a heating mode intermediate compressor speed that falls

within $\frac{1}{4}$ and $\frac{3}{4}$ of the difference between the full and minimum heating mode speeds. The manufacturer should prescribe an intermediate speed that is expected to yield the highest COP for the given H2_v test conditions and bracketed compressor speed range. The manufacturer can designate that one or more specific indoor units are turned off for the H2_v test.

3.6.5 Additional Test for a Heat Pump Having a Heat Comfort Controller

Test any heat pump that has a heat comfort controller (see section 1.2 of this appendix, Definitions) according to section 3.6.1, 3.6.2, or 3.6.3, whichever applies, with the heat comfort controller disabled. Additionally, conduct the

abbreviated test described in section 3.1.10 of this appendix with the heat comfort controller active to determine the system's maximum supply air temperature. (Note: Heat pumps having a variable speed compressor and a heat comfort controller are not covered in the test procedure at this time.)

3.6.6 Heating Mode Tests for Northern Heat Pumps With Triple-Capacity Compressors

Test triple-capacity, northern heat pumps for the heating mode as follows:

a. Conduct one maximum-temperature test (H0₁), two high-temperature tests (H1₂ and H1₁), one frost accumulation test (H2₂), two low-temperature tests (H3₂, H3₃), and one

minimum-temperature test (H4₃). Conduct an additional frost accumulation test (H2₁) and low-temperature test (H3₁) if both of the following conditions exist: (1) Knowledge of the heat pump's capacity and electrical power at low compressor capacity for outdoor temperatures of 37 °F and less is needed to complete the section 4.2.6 seasonal performance calculations; and (2) the heat pump's controls allow low-capacity operation at outdoor temperatures of 37 °F and less. If the above two conditions are met, an alternative to conducting the H2₁ frost accumulation test to determine $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ is to use the following equations to approximate this capacity and electrical power:

$$\dot{Q}_h^{k=1}(35) = 0.90 * \{ \dot{Q}_h^{k=1}(17) + 0.6 * [\dot{Q}_h^{k=1}(47) - \dot{Q}_h^{k=1}(17)] \}$$

$$\dot{E}_h^{k=1}(35) = 0.985 * \{ \dot{E}_h^{k=1}(17) + 0.6 * [\dot{E}_h^{k=1}(47) - \dot{E}_h^{k=1}(17)] \}$$

In evaluating the above equations, determine the quantities $\dot{Q}_h^{k=1}(47)$ from the H1₁ test and evaluate them according to section 3.7 of this appendix. Determine the quantities $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17)$ from the H3₁ test and evaluate them according to section 3.10 of this appendix. Use the paired values of $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ derived

from conducting the H2₁ frost accumulation test and evaluated as specified in section 3.9.1 of this appendix or use the paired values calculated using the above default equations, whichever contribute to a higher Region IV HSPF based on the DHR_{min}.

b. Conducting a frost accumulation test (H2₃) with the heat pump operating at its booster capacity is optional. If this optional test is not conducted, determine $\dot{Q}_h^{k=3}(35)$ and $\dot{E}_h^{k=3}(35)$ using the following equations to approximate this capacity and electrical power:

$$\dot{Q}_h^{k=3}(35) = QR_h^{k=2}(35) * \{ \dot{Q}_h^{k=3}(17) + 1.20 * [\dot{Q}_h^{k=3}(17) - \dot{Q}_h^{k=3}(2)] \}$$

$$\dot{E}_h^{k=3}(35) = PR_h^{k=2}(35) * \{ \dot{E}_h^{k=3}(17) + 1.20 * [\dot{E}_h^{k=3}(17) - \dot{E}_h^{k=3}(2)] \}$$

Where:

$$QR_h^{k=2}(35) = \frac{\dot{Q}_h^{k=2}(35)}{\dot{Q}_h^{k=2}(17) + 0.6 * [\dot{Q}_h^{k=2}(47) - \dot{Q}_h^{k=2}(17)]}$$

$$PR_h^{k=2}(35) = \frac{\dot{E}_h^{k=2}(35)}{\dot{E}_h^{k=2}(17) + 0.6 * [\dot{E}_h^{k=2}(47) - \dot{E}_h^{k=2}(17)]}$$

Determine the quantities $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the H1₂ test and evaluate them according to section 3.7 of this appendix. Determine the quantities $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ from the H2₂ test and evaluate them according to section 3.9.1 of this

appendix. Determine the quantities $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the H3₂ test, determine the quantities $\dot{Q}_h^{k=3}(17)$ and $\dot{E}_h^{k=3}(17)$ from the H3₃ test, and determine the quantities $\dot{Q}_h^{k=3}(2)$ and $\dot{E}_h^{k=3}(2)$ from the H4₃ test. Evaluate all six quantities according to section 3.10

of this appendix. Use the paired values of $\dot{Q}_h^{k=3}(35)$ and $\dot{E}_h^{k=3}(35)$ derived from conducting the H2₃ frost accumulation test and calculated as specified in section 3.9.1 of this appendix or use the paired values calculated using the above default equations, whichever contribute

to a higher Region IV HSPF based on the DHRmin.
 c. Conduct the optional high-temperature cyclic test (H1C₁) to determine the heating mode cyclic-degradation coefficient, C_D^h. A default value for C_D^h may be used in lieu of conducting the cyclic. The default value of C_D^h is 0.25. If a triple-capacity heat pump locks out low capacity operation at lower outdoor temperatures, conduct

the high-temperature cyclic test (H1C₂) to determine the high-capacity heating mode cyclic-degradation coefficient, C_D^h (k = 2). The default C_D^h (k = 2) is the same value as determined or assigned for the low-capacity cyclic-degradation coefficient, C_D^h [or equivalently, C_D^h (k = 1)]. Finally, if a triple-capacity heat pump locks out both low and high capacity operation at the lowest outdoor temperatures, conduct

the low-temperature cyclic test (H3C₃) to determine the booster-capacity heating mode cyclic-degradation coefficient, C_D^h (k = 3). The default C_D^h (k = 3) is the same value as determined or assigned for the high-capacity cyclic-degradation coefficient, C_D^h [or equivalently, C_D^h (k = 2)]. Table 14 specifies test conditions for all 13 tests.

TABLE 14—HEATING MODE TEST CONDITIONS FOR UNITS WITH A TRIPLE-CAPACITY COMPRESSOR

Test description	Air entering indoor unit temperature (°F)		Air entering outdoor unit temperature (°F)		Compressor capacity	Heating air volume rate
	Dry bulb	Wet bulb	Dry bulb	Wet bulb		
H0 ₁ Test (required, steady).	70	60 ^(max)	62	56.5	Low	Heating Minimum. ¹
H1 ₂ Test (required, steady).	70	60 ^(max)	47	43	High	Heating Full-Load. ²
H1C ₂ Test (optional ⁸ , cyclic).	70	60 ^(max)	47	43	High	(³)
H1 ₁ Test (required)	70	60 ^(max)	47	43	Low	Heating Minimum. ¹
H1C ₁ Test (optional, cyclic).	70	60 ^(max)	47	43	Low	(⁴)
H2 ₃ Test (optional, steady).	70	60 ^(max)	35	33	Booster	Heating Full-Load. ²
H2 ₂ Test (required)	70	60 ^(max)	35	33	High	Heating Full-Load. ²
H2 ₁ Test (required)	70	60 ^(max)	35	33	Low	Heating Minimum. ¹
H3 ₃ Test (required, steady).	70	60 ^(max)	17	15	Booster	Heating Full-Load. ²
H3C ₃ Test ^{5,6} (optional, cyclic).	70	60 ^(max)	17	15	Booster	(⁷)
H3 ₂ Test (required, steady).	70	60 ^(max)	17	15	High	Heating Full-Load. ²
H3 ₁ Test ⁵ (required, steady).	70	60 ^(max)	17	15	Low	Heating Minimum. ¹
H4 ₃ Test (required, steady).	70	60 ^(max)	2	1	Booster	Heating Full-Load. ²

¹ Defined in section 3.1.4.5 of this appendix.

² Defined in section 3.1.4.4 of this appendix.

³ Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the H1₂ test.

⁴ Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the H1₁ test.

⁵ Required only if the heat pump's performance when operating at low compressor capacity and outdoor temperatures less than 37 °F is needed to complete the section 4.2.6 HSPF calculations.

⁶ If table note ⁵ applies, the section 3.6.6 equations for Q̇_{h,k=1}(35) and Ė_{h,k=1}(17) may be used in lieu of conducting the H2₁ test.

⁷ Maintain the airflow nozzle(s) static pressure difference or velocity pressure during the ON period at the same pressure or velocity as measured during the H3₃ test.

⁸ Required only if the heat pump locks out low capacity operation at lower outdoor temperatures.

3.6.7 Tests for a Heat Pump Having a Single Indoor Unit Having Multiple Indoor Blowers and Offering Two Stages of Compressor Modulation

Conduct the heating mode tests specified in section 3.6.3 of this appendix.

3.7 Test Procedures for Steady-State Maximum Temperature and High Temperature Heating Mode Tests (the H0₁, H1, H1₂, H1₁, and H1_N Tests)

a. For the pretest interval, operate the test room reconditioning apparatus and the heat pump until equilibrium conditions are maintained for at least 30

minutes at the specified section 3.6 test conditions. Use the exhaust fan of the airflow measuring apparatus and, if installed, the indoor blower of the heat pump to obtain and then maintain the indoor air volume rate and/or the external static pressure specified for the particular test. Continuously record the dry-bulb temperature of the air entering the indoor coil, and the dry-bulb temperature and water vapor content of the air entering the outdoor coil. Refer to section 3.11 of this appendix for additional requirements that depend on the selected secondary test method. After satisfying the pretest equilibrium requirements, make the measurements

specified in Table 3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3) for the indoor air enthalpy method and the user-selected secondary method. Make said Table 3 measurements at equal intervals that span 5 minutes or less. Continue data sampling until a 30-minute period (e.g., seven consecutive 5-minute samples) is reached where the test tolerances specified in Table 15 are satisfied. For those continuously recorded parameters, use the entire data set for the 30-minute interval when evaluating Table 15 compliance. Determine the average electrical power consumption of

the heat pump over the same 30-minute interval.

TABLE 15—TEST OPERATING AND TEST CONDITION TOLERANCES FOR SECTION 3.7 AND SECTION 3.10 STEADY-STATE HEATING MODE TESTS

	Test operating tolerance ¹	Test condition tolerance ¹
Indoor dry-bulb, °F:		
Entering temperature	2.0	0.5
Leaving temperature	2.0	
Indoor wet-bulb, °F:		
Entering temperature	1.0	
Leaving temperature	1.0	
Outdoor dry-bulb, °F:		
Entering temperature	2.0	0.5
Leaving temperature	² 2.0	
Outdoor wet-bulb, °F:		
Entering temperature	1.0	0.3
Leaving temperature	² 1.0	
External resistance to airflow, inches of water	0.12	³ 0.02
Electrical voltage, % of rdg	2.0	1.5
Nozzle pressure drop, % of rdg	8.0	

¹ See section 1.2 of this appendix, Definitions.
² Only applies when the Outdoor Air Enthalpy Method is used.
³ Only applies when testing non-ducted units.

b. Calculate indoor-side total heating capacity as specified in sections 7.3.4.1 and 7.3.4.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3). To calculate capacity, use the averages of the measurements (e.g. inlet and outlet dry bulb temperatures measured at the psychrometers) that are continuously recorded for the same 30-minute interval used as described above to evaluate compliance with test tolerances. Do not adjust the parameters used in calculating capacity for the permitted variations in test conditions. Assign the average space heating capacity and electrical power over the 30-minute data collection interval to the variables \dot{Q}_h^k and $\dot{E}_h^k(T)$ respectively. The “T” and superscripted “k” are the same as described in section 3.3 of this appendix. Additionally, for the heating mode, use the superscript to denote results from the optional H1_N test, if conducted.

c. For coil-only system heat pumps, increase $\dot{Q}_h^k(T)$ by

$$\frac{1250 \text{ BTU/h}}{1000 \text{ scfm}} * \bar{V}_s$$

and increase $\dot{E}_h^k(T)$ by,

$$\frac{365 \text{ W}}{1000 \text{ scfm}} * \bar{V}_s$$

where \bar{V}_s is the average measured indoor air volume rate expressed in units of cubic feet per minute of standard air (scfm). During the 30-minute data

collection interval of a high temperature test, pay attention to preventing a defrost cycle. Prior to this time, allow the heat pump to perform a defrost cycle if automatically initiated by its own controls. As in all cases, wait for the heat pump’s defrost controls to automatically terminate the defrost cycle. Heat pumps that undergo a defrost should operate in the heating mode for at least 10 minutes after defrost termination prior to beginning the 30-minute data collection interval. For some heat pumps, frost may accumulate on the outdoor coil during a high temperature test. If the indoor coil leaving air temperature or the difference between the leaving and entering air temperatures decreases by more than 1.5 °F over the 30-minute data collection interval, then do not use the collected data to determine capacity. Instead, initiate a defrost cycle. Begin collecting data no sooner than 10 minutes after defrost termination. Collect 30 minutes of new data during which the Table 15 test tolerances are satisfied. In this case, use only the results from the second 30-minute data collection interval to evaluate $\dot{Q}_h^k(47)$ and $\dot{E}_h^k(47)$.

d. If conducting the cyclic heating mode test, which is described in section 3.8 of this appendix, record the average indoor-side air volume rate, \bar{V} , specific heat of the air, $C_{p,a}$ (expressed on dry air basis), specific volume of the air at the nozzles, v_n' (or v_n), humidity ratio at the nozzles, W_n , and either pressure difference or velocity pressure for the flow nozzles. If either or both of the

below criteria apply, determine the average, steady-state, electrical power consumption of the indoor blower motor ($\dot{E}_{fan,1}$):

(1) The section 3.8 cyclic test will be conducted and the heat pump has a variable-speed indoor blower that is expected to be disabled during the cyclic test; or

(2) The heat pump has a (variable-speed) constant-air volume-rate indoor blower and during the steady-state test the average external static pressure (ΔP_1) exceeds the applicable section 3.1.4.4 minimum (or targeted) external static pressure (ΔP_{min}) by 0.03 inches of water or more.

Determine $\dot{E}_{fan,1}$ by making measurements during the 30-minute data collection interval, or immediately following the test and prior to changing the test conditions. When the above “2” criteria applies, conduct the following four steps after determining $\dot{E}_{fan,1}$ (which corresponds to ΔP_1):

(i) While maintaining the same test conditions, adjust the exhaust fan of the airflow measuring apparatus until the external static pressure increases to approximately $\Delta P_1 + (\Delta P_1 - \Delta P_{min})$.

(ii) After re-establishing steady readings for fan motor power and external static pressure, determine average values for the indoor blower power ($\dot{E}_{fan,2}$) and the external static pressure (ΔP_2) by making measurements over a 5-minute interval.

(iii) Approximate the average power consumption of the indoor blower motor if the 30-minute test had been conducted at ΔP_{min} using linear extrapolation:

$$\dot{E}_{fan,min} = \frac{\dot{E}_{fan,2} - \dot{E}_{fan,1}}{\Delta P_2 - \Delta P_1} (\Delta P_{min} - \Delta P_1) + \dot{E}_{fan,1}$$

(iv) Decrease the total space heating capacity, $\dot{Q}_h^k(T)$, by the quantity $(\dot{E}_{fan,1} - \dot{E}_{fan,min})$, when expressed on a Btu/h basis. Decrease the total electrical power, $\dot{E}_h^k(T)$ by the same fan power difference, now expressed in watts.

e. If the temperature sensors used to provide the primary measurement of the indoor-side dry bulb temperature difference during the steady-state dry-coil test and the subsequent cyclic dry-coil test are different, include measurements of the latter sensors among the regularly sampled data. Beginning at the start of the 30-minute data collection period, measure and compute the indoor-side air dry-bulb temperature difference using both sets of instrumentation, ΔT (Set SS) and ΔT (Set CYC), for each equally spaced data sample. If using a consistent data sampling rate that is less than 1 minute, calculate and record minutely averages for the two temperature differences. If using a consistent sampling rate of one minute or more, calculate and record the two temperature differences from each data sample. After having recorded the seventh ($i = 7$) set of temperature differences, calculate the following ratio using the first seven sets of values:

$$F_{CD} = \frac{1}{7} \sum_{i=6}^i \frac{\Delta T(\text{Set SS})}{\Delta T(\text{Set CYC})}$$

Each time a subsequent set of temperature differences is recorded (if sampling more frequently than every 5 minutes), calculate F_{CD} using the most recent seven sets of values. Continue these calculations until the 30-minute period is completed or until a value for F_{CD} is calculated that falls outside the allowable range of 0.94–1.06. If the latter occurs, immediately suspend the test and identify the cause for the disparity in the two temperature difference measurements. Recalibration of one or both sets of instrumentation may be required. If all the values for F_{CD} are within the allowable range, save the final value of the ratio from the 30-minute test as F_{CD}^* . If the temperature sensors used to provide the primary measurement of the indoor-side dry bulb temperature difference during the steady-state dry-coil test and the subsequent cyclic dry-coil test are the same, set $F_{CD}^* = 1$.

3.8 Test Procedures for the Cyclic Heating Mode Tests (the H0C₁, H1C, H1C₁ and H1C₂ Tests)

a. Except as noted below, conduct the cyclic heating mode test as specified in

section 3.5 of this appendix. As adapted to the heating mode, replace section 3.5 references to “the steady-state dry coil test” with “the heating mode steady-state test conducted at the same test conditions as the cyclic heating mode test.” Use the test tolerances in Table 16 rather than Table 9. Record the outdoor coil entering wet-bulb temperature according to the requirements given in section 3.5 of this appendix for the outdoor coil entering dry-bulb temperature. Drop the subscript “dry” used in variables cited in section 3.5 of this appendix when referring to quantities from the cyclic heating mode test. The default C_D value for heating is 0.25. If available, use electric resistance heaters (see section 2.1 of this appendix) to minimize the variation in the inlet air temperature. Determine the total space heating delivered during the cyclic heating test, q_{cyc} , as specified in section 3.5 of this appendix except for making the following changes:

(1) When evaluating Equation 3.5–1, use the values of \bar{V} , $C_{p,a}$, v_n' , (or v_n), and W_n that were recorded during the section 3.7 steady-state test conducted at the same test conditions.

(2) Calculate Γ using, $\Gamma = F_{CD}^* \int_{\tau_1}^{\tau_2} [T_{a1}(\tau) - T_{a2}(\tau)] \delta\tau$, $hr \times ^\circ F$,

where F_{CD}^* is the value recorded during the section 3.7 steady-state test conducted at the same test condition.

b. For ducted coil-only system heat pumps (excluding the special case where a variable-speed fan is temporarily removed), increase q_{cyc} by the amount calculated using Equation 3.5–3. Additionally, increase e_{cyc} by the amount calculated using Equation 3.5–2. In making these calculations, use the average indoor air volume rate (\bar{V}_s) determined from the section 3.7 steady-state heating mode test conducted at the same test conditions.

c. For non-ducted heat pumps, subtract the electrical energy used by the indoor blower during the 3 minutes after compressor cutoff from the non-ducted heat pump’s integrated heating capacity, q_{cyc} .

d. If a heat pump defrost cycle is manually or automatically initiated immediately prior to or during the OFF/ON cycling, operate the heat pump continuously until 10 minutes after defrost termination. After that, begin cycling the heat pump immediately or delay until the specified test conditions have been re-established. Pay attention to preventing defrosts after beginning the cycling process. For heat pumps that cycle off the indoor blower during a defrost cycle, make no effort here to restrict the air movement through the indoor coil while the fan is off. Resume the OFF/ON cycling while conducting a minimum of two complete compressor OFF/ON cycles before determining q_{cyc} and e_{cyc} .

3.8.1 Heating Mode Cyclic-Degradation Coefficient Calculation

Use the results from the required cyclic test and the required steady-state test that were conducted at the same test conditions to determine the heating mode cyclic-degradation coefficient C_D^h . Add “(k = 2)” to the coefficient if it corresponds to a two-capacity unit cycling at high capacity. For the below calculation of the heating mode cyclic degradation coefficient, do not include the duct loss correction from section 7.3.3.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3) in determining $\dot{Q}_h^k(T_{cyc})$ (or q_{cyc}). The default value for two-capacity units cycling at high capacity, however, is the low-capacity coefficient, *i.e.*, $C_D^h(k = 2) = C_D^h$. The tested C_D^h is calculated as follows:

$$C_D^h = \frac{1 - \frac{COP_{cyc}}{COP_{ss}(T_{cyc})}}{1 - HLF}$$

where:

$$COP_{cyc} = \frac{q_{cyc}}{3.413 \frac{Btu/h}{W} * e_{cyc}}$$

the average coefficient of performance during the cyclic heating mode test, dimensionless.

$$COP_{ss}(T_{cyc}) = \frac{\dot{Q}_h^k(T_{cyc})}{3.413 \frac{Btu/h}{W} * \dot{E}_h^k(T_{cyc})}$$

the average coefficient of performance during the steady-state heating mode test conducted at the same test conditions—*i.e.*, same outdoor dry bulb temperature, T_{cyc} , and speed/capacity, k , if applicable—as specified for the cyclic heating mode test, dimensionless.

$$HLF = \frac{q_{cyc}}{\dot{Q}_h^k(T_{cyc}) * \Delta\tau_{cyc}}$$

the heating load factor, dimensionless.

T_{cyc} = the nominal outdoor temperature at which the cyclic heating mode test is conducted, 62 or 47 °F.

$\Delta\tau_{cyc}$ = the duration of the OFF/ON intervals; 0.5 hours when testing a heat pump having a single-speed or two-capacity compressor and 1.0 hour when testing a heat pump having a variable-speed compressor.

Round the calculated value for C_D^h to the nearest 0.01. If C_D^h is negative, then set it equal to zero.

TABLE 16—TEST OPERATING AND TEST CONDITION TOLERANCES FOR CYCLIC HEATING MODE TESTS

	Test operating tolerance ¹	Test condition tolerance ¹
Indoor entering dry-bulb temperature, ² °F	2.0	0.5
Indoor entering wet-bulb temperature, ² °F	1.0	
Outdoor entering dry-bulb temperature, ² °F	2.0	0.5
Outdoor entering wet-bulb temperature, ² °F	2.0	1.0
External resistance to air-flow, ² inches of water	0.12	
Airflow nozzle pressure difference or velocity pressure, ^{2%} of reading	2.0	±2.0
Electrical voltage, ^{4%} of rdg	8.0	1.5

¹ See section 1.2 of this appendix, Definitions.

² Applies during the interval that air flows through the indoor (outdoor) coil except for the first 30 seconds after flow initiation. For units having a variable-speed indoor blower that ramps, the tolerances listed for the external resistance to airflow shall apply from 30 seconds after achieving full speed until ramp down begins.

³ The test condition shall be the average nozzle pressure difference or velocity pressure measured during the steady-state test conducted at the same test conditions.

⁴ Applies during the interval that at least one of the following—the compressor, the outdoor fan, or, if applicable, the indoor blower—are operating, except for the first 30 seconds after compressor start-up.

3.9 Test Procedures for Frost Accumulation Heating Mode Tests (the H2, H2₂, H2_v, and H2₁ Tests)

a. Confirm that the defrost controls of the heat pump are set as specified in section 2.2.1 of this appendix. Operate the test room reconditioning apparatus and the heat pump for at least 30 minutes at the specified section 3.6 test conditions before starting the “preliminary” test period. The preliminary test period must immediately precede the “official” test

period, which is the heating and defrost interval over which data are collected for evaluating average space heating capacity and average electrical power consumption.

b. For heat pumps containing defrost controls which are likely to cause defrosts at intervals less than one hour, the preliminary test period starts at the termination of an automatic defrost cycle and ends at the termination of the next occurring automatic defrost cycle. For heat pumps containing defrost

controls which are likely to cause defrosts at intervals exceeding one hour, the preliminary test period must consist of a heating interval lasting at least one hour followed by a defrost cycle that is either manually or automatically initiated. In all cases, the heat pump’s own controls must govern when a defrost cycle terminates.

c. The official test period begins when the preliminary test period ends, at defrost termination. The official test period ends at the termination of the

next occurring automatic defrost cycle. When testing a heat pump that uses a time-adaptive defrost control system (see section 1.2 of this appendix, Definitions), however, manually initiate the defrost cycle that ends the official test period at the instant indicated by instructions provided by the manufacturer. If the heat pump has not undergone a defrost after 6 hours, immediately conclude the test and use the results from the full 6-hour period to calculate the average space heating capacity and average electrical power consumption.

For heat pumps that turn the indoor blower off during the defrost cycle, take steps to cease forced airflow through the indoor coil and block the outlet duct whenever the heat pump's controls cycle off the indoor blower. If it is installed, use the outlet damper box described in section 2.5.4.1 of this appendix to affect the blocked outlet duct.

d. Defrost termination occurs when the controls of the heat pump actuate the first change in converting from defrost operation to normal heating operation. Defrost initiation occurs when the controls of the heat pump first

alter its normal heating operation in order to eliminate possible accumulations of frost on the outdoor coil.

e. To constitute a valid frost accumulation test, satisfy the test tolerances specified in Table 17 during both the preliminary and official test periods. As noted in Table 17, test operating tolerances are specified for two sub-intervals: (1) When heating, except for the first 10 minutes after the termination of a defrost cycle (sub-interval H, as described in Table 17) and (2) when defrosting, plus these same first 10 minutes after defrost termination (sub-interval D, as described in Table 17). Evaluate compliance with Table 17 test condition tolerances and the majority of the test operating tolerances using the averages from measurements recorded only during sub-interval H. Continuously record the dry bulb temperature of the air entering the indoor coil, and the dry bulb temperature and water vapor content of the air entering the outdoor coil. Sample the remaining parameters listed in Table 17 at equal intervals that span 5 minutes or less.

f. For the official test period, collect and use the following data to calculate average space heating capacity and electrical power. During heating and defrosting intervals when the controls of the heat pump have the indoor blower on, continuously record the dry-bulb temperature of the air entering (as noted above) and leaving the indoor coil. If using a thermopile, continuously record the difference between the leaving and entering dry-bulb temperatures during the interval(s) that air flows through the indoor coil. For coil-only system heat pumps, determine the corresponding cumulative time (in hours) of indoor coil airflow, $\Delta\tau_a$. Sample measurements used in calculating the air volume rate (refer to sections 7.7.2.1 and 7.7.2.2 of ANSI/ASHRAE 37-2009) at equal intervals that span 10 minutes or less. (Note: In the first printing of ANSI/ASHRAE 37-2009, the second IP equation for Q_{mi} should read:) Record the electrical energy consumed, expressed in watt-hours, from defrost termination to defrost termination, $e_{DEF}^k(35)$, as well as the corresponding elapsed time in hours, $\Delta\tau_{FR}$.

TABLE 17—TEST OPERATING AND TEST CONDITION TOLERANCES FOR FROST ACCUMULATION HEATING MODE TESTS

	Test operating tolerance ¹		Test condition tolerance ¹
	Sub-interval H ²	Sub-interval D ³	Sub-interval H ²
Indoor entering dry-bulb temperature, °F	2.0	4.0	0.5
Indoor entering wet-bulb temperature, °F	1.0		
Outdoor entering dry-bulb temperature, °F	2.0	10.0	1.0
Outdoor entering wet-bulb temperature, °F	1.5		0.5
External resistance to airflow, inches of water	0.12		⁵ 0.02
Electrical voltage, % of rdg	2.0		1.5

1 See section 1.2 of this appendix, Definitions.

2 Applies when the heat pump is in the heating mode, except for the first 10 minutes after termination of a defrost cycle.

3 Applies during a defrost cycle and during the first 10 minutes after the termination of a defrost cycle when the heat pump is operating in the heating mode.

4 For heat pumps that turn off the indoor blower during the defrost cycle, the noted tolerance only applies during the 10 minute interval that follows defrost termination.

5 Only applies when testing non-ducted heat pumps.

3.9.1 Average Space Heating Capacity and Electrical Power Calculations

a. Evaluate average space heating capacity, $\dot{Q}_h^k(35)$, when expressed in units of Btu per hour, using:

$$\dot{Q}_h^k(35) = \frac{60 * \bar{V} * C_{p,a} * \Gamma}{\Delta\tau_{FR} [v_n' * (1 + W_n)]} = \frac{60 * \bar{V} * C_{p,a} * \Gamma}{\Delta\tau_{FR} v_n}$$

Where,

\bar{V} = the average indoor air volume rate measured during sub-interval H, cfm.

$C_{p,a} = 0.24 + 0.444 * W_n$, the constant pressure specific heat of the air-water vapor

mixture that flows through the indoor coil and is expressed on a dry air basis, Btu/lbm_{da} · °F.

v_n' = specific volume of the air-water vapor mixture at the nozzle, ft³/lbm_{mx}.

W_n = humidity ratio of the air-water vapor mixture at the nozzle, lbm of water vapor per lbm of dry air.

$\Delta\tau_{FR} = \tau_2 - \tau_1$, the elapsed time from defrost termination to defrost termination, hr.

$$\Gamma = \int_{\tau_1}^{\tau_2} [T_{a2}(\tau) - T_{a1}(\tau)] d\tau, \text{ hr} * ^\circ F$$

$T_{a1}(\tau)$ = dry bulb temperature of the air entering the indoor coil at elapsed time τ , $^\circ F$; only recorded when indoor coil airflow occurs; assigned the value of zero during periods (if any) where the indoor blower cycles off.

$T_{a2}(\tau)$ = dry bulb temperature of the air leaving the indoor coil at elapsed time τ , $^\circ F$; only recorded when indoor coil airflow occurs; assigned the value of zero during periods (if any) where the indoor blower cycles off.

τ_1 = the elapsed time when the defrost termination occurs that begins the official test period, hr.

τ_2 = the elapsed time when the next automatically occurring defrost termination occurs, thus ending the official test period, hr.

v_n = specific volume of the dry air portion of the mixture evaluated at the dry-bulb temperature, vapor content, and barometric pressure existing at the nozzle, ft^3 per lbm of dry air.

To account for the effect of duct losses between the outlet of the indoor unit and the section 2.5.4 dry-bulb temperature grid, adjust $\dot{Q}_h^k(35)$ in accordance with section 7.3.4.3 of

ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3).

b. Evaluate average electrical power, $\dot{E}_h^k(35)$, when expressed in units of watts, using:

$$\dot{E}_h^k(35) = \frac{e_{def}(35)}{\Delta\tau_{FR}}$$

For coil-only system heat pumps, increase $\dot{Q}_h^k(35)$ by,

$$\frac{1250 \text{ Btu/h}}{1000 \text{ scfm}} * \bar{V}_s * \frac{\Delta\tau_a}{\Delta\tau_{FR}}$$

and increase $\dot{E}_h^k(35)$ by,

$$\frac{365 \text{ W}}{1000 \text{ scfm}} * \bar{V}_s * \frac{\Delta\tau_a}{\Delta\tau_{FR}}$$

where \bar{V}_s is the average indoor air volume rate measured during the frost accumulation heating mode test and is expressed in units of cubic feet per minute of standard air (scfm).

c. For heat pumps having a constant-air-volume-rate indoor blower, the five additional steps listed below are required if the average of the external static pressures measured during sub-interval H exceeds the applicable section 3.1.4.4, 3.1.4.5, or 3.1.4.6 minimum (or targeted) external static pressure (ΔP_{min}) by 0.03 inches of water or more:

(1) Measure the average power consumption of the indoor blower motor ($\dot{E}_{fan,1}$) and record the corresponding external static pressure (ΔP_1) during or immediately following the frost accumulation heating mode test. Make the measurement at a time when the heat pump is heating, except for the first 10 minutes after the termination of a defrost cycle.

(2) After the frost accumulation heating mode test is completed and while maintaining the same test conditions, adjust the exhaust fan of the airflow measuring apparatus until the

external static pressure increases to approximately $\Delta P_1 + (\Delta P_1 - \Delta P_{min})$.

(3) After re-establishing steady readings for the fan motor power and external static pressure, determine average values for the indoor blower power ($\dot{E}_{fan,2}$) and the external static pressure (ΔP_2) by making measurements over a 5-minute interval.

(4) Approximate the average power consumption of the indoor blower motor had the frost accumulation heating mode test been conducted at ΔP_{min} using linear extrapolation:

$$\dot{E}_{fan,min} = \frac{\dot{E}_{fan,2} - \dot{E}_{fan,1}}{\Delta P_2 - \Delta P_1} (\Delta P_{min} - \Delta P_1) + \dot{E}_{fan,1}$$

(5) Decrease the total heating capacity, $\dot{Q}_h^k(35)$, by the quantity $[(\dot{E}_{fan,1} - \dot{E}_{fan,min}) \cdot (\Delta\tau_a/\Delta\tau_{FR})]$, when expressed on a

Btu/h basis. Decrease the total electrical power, $\dot{E}_h^k(35)$, by the same quantity, now expressed in watts.

3.9.2 Demand Defrost Credit

a. Assign the demand defrost credit, F_{def} , that is used in section 4.2 of this

appendix to the value of 1 in all cases except for heat pumps having a

demand-defrost control system (see section 1.2 of this appendix,

Definitions). For such qualifying heat pumps, evaluate F_{def} using,

$$F_{def} = 1 + 0.03 * \left[1 - \frac{\Delta\tau_{def} - 1.5}{\Delta\tau_{max} - 1.5} \right]$$

where:

$\Delta\tau_{def}$ = the time between defrost terminations (in hours) or 1.5, whichever is greater. A value of 6 must be assigned to $\Delta\tau_{def}$ if this limit is reached during a frost accumulation test and the heat pump has not completed a defrost cycle.

$\Delta\tau_{max}$ = maximum time between defrosts as allowed by the controls (in hours) or 12, whichever is less, as provided in the certification report.

b. For two-capacity heat pumps and for section 3.6.2 units, evaluate the above equation using the $\Delta\tau_{def}$ that applies based on the frost accumulation test conducted at high capacity and/or at the heating full-load air volume rate. For variable-speed heat pumps, evaluate $\Delta\tau_{def}$ based on the required frost accumulation test conducted at the intermediate compressor speed.

3.10 Test Procedures for Steady-State Low Temperature Heating Mode Tests (the H3, H3₂, and H3₁ tests).

Except for the modifications noted in this section, conduct the low temperature heating mode test using the same approach as specified in section 3.7 of this appendix for the maximum and high temperature tests. After satisfying the section 3.7 requirements for the pretest interval but before beginning to collect data to determine $Q_h^k(17)$ and $E_h^k(17)$, conduct a defrost cycle. This defrost cycle may be manually or automatically initiated. The defrost sequence must be terminated by the action of the heat pump's defrost controls. Begin the 30-minute data collection interval described in section 3.7 of this appendix, from which $Q_h^k(17)$ and $E_h^k(17)$ are determined, no sooner than 10 minutes after defrost termination. Defrosts should be prevented over the 30-minute data collection interval.

3.11 Additional Requirements for the Secondary Test Methods

3.11.1 If Using the Outdoor Air Enthalpy Method as the Secondary Test Method

During the "official" test, the outdoor air-side test apparatus described in section 2.10.1 of this appendix is connected to the outdoor unit. To help compensate for any effect that the addition of this test apparatus may have on the unit's performance, conduct a

"preliminary" test where the outdoor air-side test apparatus is disconnected. Conduct a preliminary test prior to the first section 3.2 of this appendix steady-state cooling mode test and prior to the first section 3.6 of this appendix steady-state heating mode test. No other preliminary tests are required so long as the unit operates the outdoor fan during all cooling mode steady-state tests at the same speed and all heating mode steady-state tests at the same speed. If using more than one outdoor fan speed for the cooling mode steady-state tests, however, conduct a preliminary test prior to each cooling mode test where a different fan speed is first used. This same requirement applies for the heating mode tests.

3.11.1.1 Preliminary Test

3.11.1.1.1 If a Preliminary Test Precedes the Official Test

a. The test conditions for the preliminary test are the same as specified for the official test. Connect the indoor air-side test apparatus to the indoor coil; disconnect the outdoor air-side test apparatus. Allow the test room reconditioning apparatus and the unit being tested to operate for at least one hour. After attaining equilibrium conditions, measure the following quantities at equal intervals that span 5 minutes or less:

(1) The section 2.10.1 of this appendix evaporator and condenser temperatures or pressures;

(2) Parameters required according to the indoor air enthalpy method.

Continue these measurements until a 30-minute period (*e.g.*, seven consecutive 5-minute samples) is obtained where the Table 8 or Table 15, whichever applies, test tolerances are satisfied.

b. After collecting 30 minutes of steady-state data, reconnect the outdoor air-side test apparatus to the unit. Adjust the exhaust fan of the outdoor airflow measuring apparatus until averages for the evaporator and condenser temperatures, or the saturated temperatures corresponding to the measured pressures, agree within ± 0.5 °F of the averages achieved when the outdoor air-side test apparatus was disconnected. Calculate the averages for the reconnected case using five or more

consecutive readings taken at one minute intervals. Make these consecutive readings after re-establishing equilibrium conditions and before initiating the official test.

3.11.1.1.2 If a Preliminary Test Does Not Precede the Official Test

Connect the outdoor-side test apparatus to the unit. Adjust the exhaust fan of the outdoor airflow measuring apparatus to achieve the same external static pressure as measured during the prior preliminary test conducted with the unit operating in the same cooling or heating mode at the same outdoor fan speed.

3.11.1.1 Official Test

a. Continue (preliminary test was conducted) or begin (no preliminary test) the official test by making measurements for both the indoor and outdoor air enthalpy methods at equal intervals that span 5 minutes or less. Discontinue these measurements only after obtaining a 30-minute period where the specified test condition and test operating tolerances are satisfied. To constitute a valid official test:

(1) Achieve the energy balance specified in section 3.1.1 of this appendix; and,

(2) For cases where a preliminary test is conducted, the capacities determined using the indoor air enthalpy method from the official and preliminary test periods must agree within 2.0 percent.

b. For space cooling tests, calculate capacity from the outdoor air-enthalpy measurements as specified in sections 7.3.3.2 and 7.3.3.3 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3). Calculate heating capacity based on outdoor air-enthalpy measurements as specified in sections 7.3.4.2 and 7.3.3.4.3 of the same ASHRAE Standard. Adjust the outdoor-side capacity according to section 7.3.3.4 of ANSI/ASHRAE 37–2009 to account for line losses when testing split systems. Use the outdoor unit fan power as measured during the official test and not the value measured during the preliminary test, as described in section 8.6.2 of ANSI/ASHRAE 37–2009, when calculating the capacity.

3.11.2 If Using the Compressor Calibration Method as the Secondary Test Method

a. Conduct separate calibration tests using a calorimeter to determine the refrigerant flow rate. Or for cases where the superheat of the refrigerant leaving the evaporator is less than 5 °F, use the calorimeter to measure total capacity rather than refrigerant flow rate.

Conduct these calibration tests at the same test conditions as specified for the tests in this appendix. Operate the unit for at least one hour or until obtaining equilibrium conditions before collecting data that will be used in determining the average refrigerant flow rate or total capacity. Sample the data at equal intervals that span 5 minutes or less. Determine average flow rate or average capacity from data sampled over a 30-minute period where the Table 8 (cooling) or the Table 15 (heating) tolerances are satisfied. Otherwise, conduct the calibration tests according to sections 5, 6, 7, and 8 of ASHRAE 23.1–2010 (incorporated by reference, see § 430.3); sections 5, 6, 7, 8, 9, and 11 of ASHRAE 41.9–2011 (incorporated by reference, see § 430.3); and section 7.4 of ANSI/ASHRAE 37–2009 (incorporated by reference, see § 430.3).

b. Calculate space cooling and space heating capacities using the compressor calibration method measurements as specified in section 7.4.5 and 7.4.6 respectively, of ANSI/ASHRAE 37–2009.

3.11.3 If Using the Refrigerant-Enthalpy Method as the Secondary Test Method

Conduct this secondary method according to section 7.5 of ANSI/ASHRAE 37–2009. Calculate space cooling and heating capacities using the refrigerant-enthalpy method measurements as specified in sections 7.5.4 and 7.5.5, respectively, of the same ASHRAE Standard.

3.12 Rounding of Space Conditioning Capacities for Reporting Purposes

a. When reporting rated capacities, round them off as specified in § 430.23 (for a single unit) and in 10 CFR 429.16 (for a sample).

b. For the capacities used to perform the calculations in section 4 of this appendix, however, round only to the nearest integer.

3.13 Laboratory Testing To Determine Off Mode Average Power Ratings

Voltage tolerances: As a percentage of reading, test operating tolerance shall be 2.0 percent and test condition tolerance shall be 1.5 percent (see section 1.2 of

this appendix for definitions of these tolerances).

Conduct one of the following tests: If the central air conditioner or heat pump lacks a compressor crankcase heater, perform the test in section 3.13.1 of this appendix; if the central air conditioner or heat pump has a compressor crankcase heater that lacks controls and is not self-regulating, perform the test in section 3.13.1 of this appendix; if the central air conditioner or heat pump has a crankcase heater with a fixed power input controlled with a thermostat that measures ambient temperature and whose sensing element temperature is not affected by the heater, perform the test in section 3.13.1 of this appendix; if the central air conditioner or heat pump has a compressor crankcase heater equipped with self-regulating control or with controls for which the sensing element temperature is affected by the heater, perform the test in section 3.13.2 of this appendix.

3.13.1 This Test Determines the off Mode Average Power Rating for Central Air Conditioners and Heat Pumps That Lack a Compressor Crankcase Heater, or Have a Compressor Crankcase Heating System That Can Be Tested Without Control of Ambient Temperature During the Test. This Test Has No Ambient Condition Requirements

a. Test Sample Set-up and Power Measurement: For coil-only systems, provide a furnace or modular blower that is compatible with the system to serve as an interface with the thermostat (if used for the test) and to provide low-voltage control circuit power. Make all control circuit connections between the furnace (or modular blower) and the outdoor unit as specified by the manufacturer's installation instructions. Measure power supplied to both the furnace or modular blower and power supplied to the outdoor unit. Alternatively, provide a compatible transformer to supply low-voltage control circuit power, as described in section 2.2.d of this appendix. Measure transformer power, either supplied to the primary winding or supplied by the secondary winding of the transformer, and power supplied to the outdoor unit. For blower coil and single-package systems, make all control circuit connections between components as specified by the manufacturer's installation instructions, and provide power and measure power supplied to all system components.

b. Configure Controls: Configure the controls of the central air conditioner or heat pump so that it operates as if connected to a building thermostat that is set to the OFF position. Use a

compatible building thermostat if necessary to achieve this configuration. For a thermostat-controlled crankcase heater with a fixed power input, bypass the crankcase heater thermostat if necessary to energize the heater.

c. Measure P_{2x} : If the unit has a crankcase heater time delay, make sure that time delay function is disabled or wait until delay time has passed. Determine the average power from non-zero value data measured over a 5-minute interval of the non-operating central air conditioner or heat pump and designate the average power as P_{2x} , the heating season total off mode power.

d. Measure P_{2x} for coil-only split systems and for blower coil split systems for which a furnace or a modular blower is the designated air mover: Disconnect all low-voltage wiring for the *outdoor* components and *outdoor* controls from the low-voltage transformer. Determine the average power from non-zero value data measured over a 5-minute interval of the power supplied to the (remaining) low-voltage components of the central air conditioner or heat pump, or low-voltage power, P_{2x} . This power measurement does not include line power supplied to the outdoor unit. It is the line power supplied to the air mover, or, if a compatible transformer is used instead of an air mover, it is the line power supplied to the transformer primary coil. If a compatible transformer is used instead of an air mover and power output of the low-voltage secondary circuit is measured, P_x is zero.

e. Calculate P_2 : Set the number of compressors equal to the unit's number of single-stage compressors plus 1.75 times the unit's number of compressors that are not single-stage.

For single-package systems and blower coil split systems for which the designated air mover is not a furnace or modular blower, divide the heating season total off mode power (P_{2x}) by the number of compressors to calculate P_2 , the heating season per-compressor off mode power. Round P_2 to the nearest watt. The expression for calculating P_2 is as follows:

$$P_2 = \frac{P_{2x}}{\text{number of compressors}}$$

For coil-only split systems and blower coil split systems for which a furnace or a modular blower is the designated air mover, subtract the low-voltage power (P_x) from the heating season total off mode power (P_{2x}) and divide by the number of compressors to calculate P_2 , the heating season per-compressor off mode power. Round P_2 to the nearest

watt. The expression for calculating $P2$ is as follows:

$$P2 = \frac{P2_x - P_x}{\text{number of compressors}}$$

f. Shoulder-season per-compressor off mode power, $P1$: If the system does not have a crankcase heater, has a crankcase heater without controls that is not self-regulating, or has a value for the crankcase heater turn-on temperature (as certified in the DOE Compliance Certification Database) that is higher than 71 °F, $P1$ is equal to $P2$.

Otherwise, de-energize the crankcase heater (by removing the thermostat bypass or otherwise disconnecting only the power supply to the crankcase heater) and repeat the measurement as described in section 3.13.1.c of this appendix. Designate the measured average power as $P1_x$, the shoulder season total off mode power.

Determine the number of compressors as described in section 3.13.1.e of this appendix.

For single-package systems and blower coil systems for which the designated air mover is not a furnace or modular blower, divide the shoulder season total off mode power ($P1_x$) by the number of compressors to calculate $P1$, the shoulder season per-compressor off mode power. Round $P1$ to the nearest watt. The expression for calculating $P1$ is as follows:

$$P1 = \frac{P1_x}{\text{number of compressors}}$$

For coil-only split systems and blower coil split systems for which a furnace or a modular blower is the designated air mover, subtract the low-voltage power (P_x) from the shoulder season total off mode power ($P1_x$) and divide by the number of compressors to calculate $P1$, the shoulder season per-compressor off mode power. Round $P1$ to the nearest watt. The expression for calculating $P1$ is as follows:

$$P1 = \frac{P1_x - P_x}{\text{number of compressors}}$$

3.13.2 This test determines the off mode average power rating for central air conditioners and heat pumps for which ambient temperature can affect the measurement of crankcase heater power.

a. Test Sample Set-up and Power Measurement: Set up the test and measurement as described in section 3.13.1.a of this appendix.

b. Configure Controls: Position a temperature sensor to measure the outdoor dry-bulb temperature in the air

between 2 and 6 inches from the crankcase heater control temperature sensor or, if no such temperature sensor exists, position it in the air between 2 and 6 inches from the crankcase heater. Utilize the temperature measurements from this sensor for this portion of the test procedure. Configure the controls of the central air conditioner or heat pump so that it operates as if connected to a building thermostat that is set to the OFF position. Use a compatible building thermostat if necessary to achieve this configuration.

Conduct the test after completion of the B, B₁, or B₂ test. Alternatively, start the test when the outdoor dry-bulb temperature is at 82 °F and the temperature of the compressor shell (or temperature of each compressor's shell if there is more than one compressor) is at least 81 °F. Then adjust the outdoor temperature at a rate of change of no more than 20 °F per hour and achieve an outdoor dry-bulb temperature of 72 °F. Maintain this temperature within +/− 2 °F while making the power measurement, as described in section 3.13.2.c of this appendix.

c. Measure $P1_x$: If the unit has a crankcase heater time delay, make sure that time delay function is disabled or wait until delay time has passed. Determine the average power from non-zero value data measured over a 5-minute interval of the non-operating central air conditioner or heat pump and designate the average power as $P1_x$, the shoulder season total off mode power. For units with crankcase heaters which operate during this part of the test and whose controls cycle or vary crankcase heater power over time, the test period shall consist of three complete crankcase heater cycles or 18 hours, whichever comes first. Designate the average power over the test period as $P1_x$, the shoulder season total off mode power.

d. Reduce outdoor temperature: Approach the target outdoor dry-bulb temperature by adjusting the outdoor temperature at a rate of change of no more than 20 °F per hour. This target temperature is five degrees Fahrenheit less than the temperature specified by the manufacturer in the DOE Compliance Certification Database at which the crankcase heater turns on. Maintain the target temperature within +/− 2 °F while making the power measurement, as described in section 3.13.2.e of this appendix.

e. Measure $P2_x$: If the unit has a crankcase heater time delay, make sure that time delay function is disabled or wait until delay time has passed. Determine the average non-zero power of the non-operating central air

conditioner or heat pump over a 5-minute interval and designate it as $P2_x$, the heating season total off mode power. For units with crankcase heaters whose controls cycle or vary crankcase heater power over time, the test period shall consist of three complete crankcase heater cycles or 18 hours, whichever comes first. Designate the average power over the test period as $P2_x$, the heating season total off mode power.

f. Measure P_x for coil-only split systems and for blower coil split systems for which a furnace or modular blower is the designated air mover: Disconnect all low-voltage wiring for the outdoor components and outdoor controls from the low-voltage transformer. Determine the average power from non-zero value data measured over a 5-minute interval of the power supplied to the (remaining) low-voltage components of the central air conditioner or heat pump, or low-voltage power, P_x . This power measurement does not include line power supplied to the outdoor unit. It is the line power supplied to the air mover, or, if a compatible transformer is used instead of an air mover, it is the line power supplied to the transformer primary coil. If a compatible transformer is used instead of an air mover and power output of the low-voltage secondary circuit is measured, P_x is zero.

g. Calculate $P1$:

Set the number of compressors equal to the unit's number of single-stage compressors plus 1.75 times the unit's number of compressors that are not single-stage.

For single-package systems and blower coil split systems for which the air mover is not a furnace or modular blower, divide the shoulder season total off mode power ($P1_x$) by the number of compressors to calculate $P1$, the shoulder season per-compressor off mode power. Round to the nearest watt. The expression for calculating $P1$ is as follows:

$$P1 = \frac{P1_x}{\text{number of compressors}}$$

For coil-only split systems and blower coil split systems for which a furnace or a modular blower is the designated air mover, subtract the low-voltage power (P_x) from the shoulder season total off mode power ($P1_x$) and divide by the number of compressors to calculate $P1$, the shoulder season per-compressor off mode power. Round to the nearest watt. The expression for calculating $P1$ is as follows:

$$P1 = \frac{P1_x - P_x}{\text{number of compressors}}$$

h. Calculate $P2$:

Determine the number of compressors as described in section 3.13.2.g of this appendix.

For single-package systems and blower coil split systems for which the air mover is not a furnace, divide the heating season total off mode power ($P1_x$) by the number of compressors to calculate $P2$, the heating season per-compressor off mode power. Round to the nearest watt. The expression for calculating $P2$ is as follows:

$$P2 = \frac{P2_x}{\text{number of compressors}}$$

For coil-only split systems and blower coil split systems for which a furnace or a modular blower is the designated air mover, subtract the low-voltage power (P_x) from the heating season total off mode power ($P2_x$) and divide by the number of compressors to calculate $P2$, the heating season per-compressor off mode power. Round to the nearest watt. The expression for calculating $P2$ is as follows:

$$P2 = \frac{P2_x - P_x}{\text{number of compressors}}$$

4. Calculations of Seasonal Performance Descriptors

4.1 Seasonal Energy Efficiency Ratio (SEER) Calculations. SEER must be calculated as follows:

For equipment covered under sections 4.1.2, 4.1.3, and 4.1.4 of this appendix, evaluate the seasonal energy efficiency ratio,

$$\text{Equation 4.1-1 } SEER = \frac{\sum_{j=1}^8 q_c(T_j)}{\sum_{j=1}^8 e_c(T_j)} = \frac{\sum_{j=1}^8 \frac{q_c(T_j)}{N}}{\sum_{j=1}^8 \frac{e_c(T_j)}{N}}$$

where:

$\frac{q_c(T_j)}{N}$ = the ratio of the total space cooling provided during periods of the space cooling

season when the outdoor temperature fell within the range represented by bin temperature

T_j to the total number of hours in the cooling season (N), Btu/h.

$\frac{e_c(T_j)}{N}$ = the electrical energy consumed by the test unit during periods of the space cooling

season when the outdoor temperature fell within the range represented by bin temperature

T_j to the total number of hours in the cooling season (N), W.

T_j = the outdoor bin temperature, °F. Outdoor temperatures are grouped or “binned.” Use

bins of 5 °F with the 8 cooling season bin temperatures being 67, 72, 77, 82, 87, 92, 97,

and 102 °F.

j = the bin number. For cooling season calculations, j ranges from 1 to 8.

Additionally, for sections 4.1.2, 4.1.3, and 4.1.4 of this appendix, use a building cooling load, $BL(T_j)$. When referenced, evaluate $BL(T_j)$ for cooling using,

$$\text{Equation 4.1-2 } BL(T_j) = \frac{(T_j - 65)}{95 - 65} * \frac{\dot{Q}_c^{k=2}(95)}{1.1}$$

Where:

$\dot{Q}_c^{k=2}(95)$ = the space cooling capacity determined from the A_2 test and

calculated as specified in section 3.3 of this appendix, Btu/h.
1.1 = sizing factor, dimensionless.

The temperatures 95 °F and 65 °F in the building load equation represent the selected outdoor design temperature

and the zero-load base temperature, respectively.

4.1.1 SEER Calculations for a Blower Coil System Having a Single-Speed Compressor and Either a Fixed-Speed Indoor Blower or a Constant-Air-Volume-Rate Indoor Blower, or a Coil-Only System Air Conditioner or Heat Pump

$SEER = PLF(0.5) * EER_B$
Where:

a. Evaluate the seasonal energy efficiency ratio, expressed in units of Btu/watt-hour, using:

$$EER_B = \frac{\dot{Q}_c(82)}{\dot{E}_c(82)} = \text{the energy efficiency ratio determined from the B test described in}$$

sections 3.2.1, 3.1.4.1, and 3.3 of this appendix, Btu/h per watt.

$PLF(0.5) = 1 - 0.5 \cdot C_D^c$, the part-load performance factor evaluated at a cooling load factor of 0.5, dimensionless.

b. Refer to section 3.3 of this appendix regarding the definition and calculation of $\dot{Q}_c(82)$ and $\dot{E}_c(82)$.

4.1.2 SEER Calculations for an Air Conditioner or Heat Pump Having a Single-Speed Compressor and a Variable-Speed Variable-Air-Volume-Rate Indoor Blower

with the outdoor dry bulb temperature. The manufacturer must provide information on how the indoor air volume rate or the indoor blower speed varies over the outdoor temperature range of 67 °F to 102 °F. Calculate SEER using Equation 4.1–1. Evaluate the quantity $q_c(T_j)/N$ in Equation 4.1–1 using,

4.1.2.1 Units covered by section 3.2.2.1 of this appendix where indoor blower capacity modulation correlates

$$\text{Equation 4.1.2-1 } \frac{q_c(T_j)}{N} = X(T_j) * \dot{Q}_c(T_j) * \frac{n_j}{N}$$

Where:

$$X(T_j) = \left\{ \begin{array}{l} BL(T_j)/\dot{Q}_c(T_j) \\ \text{or} \\ 1 \end{array} \right\} \text{ whichever is less; the cooling mode load factor for}$$

temperature bin j, dimensionless.

$\dot{Q}_c(T_j)$ = the space cooling capacity of the test unit when operating at outdoor temperature, T_j , Btu/h.

n_j/N = fractional bin hours for the cooling season; the ratio of the number of hours during the cooling season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the cooling season, dimensionless.

a. For the space cooling season, assign n_j/N as specified in Table 18. Use

Equation 4.1–2 to calculate the building load, $BL(T_j)$. Evaluate $\dot{Q}_c(T_j)$ using,

$$\text{Equation 4.1.2-2 } \dot{Q}_c(T_j) = \dot{Q}_c^{k=1}(T_j) + \frac{\dot{Q}_c^{k=2}(T_j) - \dot{Q}_c^{k=1}(T_j)}{FP_c^{k=2} - FP_c^{k=1}} * [FP_c(T_j) - FP_c^{k=1}]$$

where:

$$\dot{Q}_c^{k=1}(T_j) = \dot{Q}_c^{k=1}(82) + \frac{\dot{Q}_c^{k=1}(95) - \dot{Q}_c^{k=1}(82)}{95 - 82} * (T_j - 82)$$

the space cooling capacity of the test unit at outdoor temperature T_j if operated at the cooling minimum air volume rate, Btu/h.

$$\dot{Q}_c^{k=2}(T_j) = \dot{Q}_c^{k=2}(82) + \frac{\dot{Q}_c^{k=2}(95) - \dot{Q}_c^{k=2}(82)}{95 - 82} * (T_j - 82)$$

the space cooling capacity of the test unit at outdoor temperature T_j if operated at the Cooling full-load air volume rate, Btu/h.

b. For units where indoor blower speed is the primary control variable, $FP_c^{k=1}$ denotes the fan speed used during the required A₁ and B₁ tests (see section 3.2.2.1 of this appendix), $FP_c^{k=2}$ denotes the fan speed used during the required A₂ and B₂ tests, and $FP_c(T_j)$

denotes the fan speed used by the unit when the outdoor temperature equals T_j . For units where indoor air volume rate is the primary control variable, the three FP_c 's are similarly defined only now being expressed in terms of air volume rates rather than fan speeds. Refer to

sections 3.2.2.1, 3.1.4 to 3.1.4.2, and 3.3 of this appendix regarding the definitions and calculations of $\dot{Q}_c^{k=1}(82)$, $\dot{Q}_c^{k=1}(95)$, $\dot{Q}_c^{k=2}(82)$, and $\dot{Q}_c^{k=2}(95)$.

Calculate $e_c(T_j)/N$ in Equation 4.1-1 using, Equation 4.1.2-3

$$\frac{e_c(T_j)}{N} = \frac{X(T_j) * \dot{E}_c(T_j)}{PLF_j} * \frac{n_j}{N}$$

Where:

$PLF_j = 1 - C_D^c \cdot [1 - X(T_j)]$, the part load factor, dimensionless.

$\dot{E}_c(T_j)$ = the electrical power consumption of the test unit when operating at outdoor temperature T_j , W.

c. The quantities $X(T_j)$ and n_j/N are the same quantities as used in Equation 4.1.2-1.

d. Evaluate $\dot{E}_c(T_j)$ using,

$$\dot{E}_c(T_j) = \dot{E}_c^{k=1}(T_j) + \frac{\dot{E}_c^{k=2}(T_j) - \dot{E}_c^{k=1}(T_j)}{FP_c^{k=2} - FP_c^{k=1}} * [FP_c(T_j) - FP_c^{k=1}]$$

where:

$$\dot{E}_c^{k=1}(T_j) = \dot{E}_c^{k=1}(82) + \frac{\dot{E}_c^{k=1}(95) - \dot{E}_c^{k=1}(82)}{95-82} * (T_j - 82)$$

the electrical power consumption of the test unit at outdoor temperature T_j if operated at the Cooling Minimum Air Volume Rate, W.

$$\dot{E}_c^{k=2}(T_j) = \dot{E}_c^{k=2}(82) + \frac{\dot{E}_c^{k=2}(95) - \dot{E}_c^{k=2}(82)}{95-82} * (T_j - 82) \quad \text{the electrical power consumption}$$

of the test unit at outdoor temperature T_j if operated at the cooling full-load air volume rate, W.

e. The parameters $FP_c^{k=1}$, and $FP_c^{k=2}$, and $FP_c(T_j)$ are the same quantities that are used when evaluating Equation 4.1.2-2. Refer to sections 3.2.2.1, 3.1.4 to 3.1.4.2, and 3.3 of this appendix regarding the definitions and calculations of $\dot{E}_c^{k=1}(82)$, $\dot{E}_c^{k=1}(95)$, $\dot{E}_c^{k=2}(82)$, and $\dot{E}_c^{k=2}(95)$.

4.1.2.2 Units Covered by Section 3.2.2.2 of This Appendix Where Indoor Blower Capacity Modulation Is Used To Adjust the Sensible to Total Cooling Capacity Ratio

Calculate SEER as specified in section 4.1.1 of this appendix.

4.1.2.3 SEER Calculations for an Air Conditioner or Heat Pump Having a Two-Capacity Compressor

Calculate SEER using Equation 4.1-1. Evaluate the space cooling capacity, $\dot{Q}_c^{k=1}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=1}(T_j)$, of the test unit when operating at low compressor capacity and outdoor temperature T_j using,

$$\text{Equation 4.1.3-1} \quad \dot{Q}_c^{k=1}(T_j) = \dot{Q}_c^{k=1}(67) + \frac{\dot{Q}_c^{k=1}(82) - \dot{Q}_c^{k=1}(67)}{82-67} * (T_j - 67)$$

$$\text{Equation 4.1.3-2} \quad \dot{E}_c^{k=1}(T_j) = \dot{E}_c^{k=1}(67) + \frac{\dot{E}_c^{k=1}(82) - \dot{E}_c^{k=1}(67)}{82-67} * (T_j - 67)$$

where $\dot{Q}_c^{k=1}(82)$ and $\dot{E}_c^{k=1}(82)$ are determined from the B_1 test, $\dot{Q}_c^{k=1}(67)$ and $\dot{E}_c^{k=1}(67)$ are determined from the F_1 test, and all four quantities are

calculated as specified in section 3.3 of this appendix. Evaluate the space cooling capacity, $\dot{Q}_c^{k=2}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=2}(T_j)$,

of the test unit when operating at high compressor capacity and outdoor temperature T_j using,

$$\text{Equation 4.1.3-3} \quad \dot{Q}_c^{k=2}(T_j) = \dot{Q}_c^{k=2}(82) + \frac{\dot{Q}_c^{k=2}(95) - \dot{Q}_c^{k=2}(82)}{95-82} * (T_j - 82)$$

$$\text{Equation 4.1.3-4} \quad \dot{E}_c^{k=2}(T_j) = \dot{E}_c^{k=2}(82) + \frac{\dot{E}_c^{k=2}(95) - \dot{E}_c^{k=2}(82)}{95-82} * (T_j - 82)$$

where $\dot{Q}_c^{k=2}(95)$ and $\dot{E}_c^{k=2}(95)$ are determined from the A₂ test, $\dot{Q}_c^{k=2}(82)$, and $\dot{E}_c^{k=2}(82)$, are determined from the B₂ test, and all are calculated as specified in section 3.3 of this appendix.

The calculation of Equation 4.1-1 quantities $q_c(T_j)/N$ and $e_c(T_j)/N$ differs depending on whether the test unit would operate at low capacity (section

4.1.2.4 of this appendix), cycle between low and high capacity (section 4.1.2.5 of this appendix), or operate at high capacity (sections 4.1.2.6 and 4.1.2.7 of this appendix) in responding to the building load. For units that lock out low capacity operation at higher outdoor temperatures, the manufacturer must supply information regarding this

temperature so that the appropriate equations are used. Use Equation 4.1-2 to calculate the building load, BL(T_j), for each temperature bin.

4.1.2.4 Steady-state space cooling capacity at low compressor capacity is greater than or equal to the building cooling load at temperature T_j, $\dot{Q}_c^{k=1}(T_j) \geq BL(T_j)$.

$$\frac{q_c(T_j)}{N} = X^{k=1}(T_j) * \dot{Q}_c^{k=1}(T_j) * \frac{n_j}{N} \qquad \frac{e_c(T_j)}{N} = \frac{X^{k=1}(T_j) * \dot{E}_c^{k=1}(T_j)}{PLF_j} * \frac{n_j}{N}$$

Where:

$X^{k=1}(T_j) = BL(T_j)/\dot{Q}_c^{k=1}(T_j)$, the cooling mode low capacity load factor for temperature bin j, dimensionless.

$PLF_j = 1 - C_D^c \cdot [1 - X^{k=1}(T_j)]$, the part load factor, dimensionless.

$\frac{n_j}{N} =$ fractional bin hours for the cooling season; the ratio of the number of hours during the cooling season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the cooling season, dimensionless.

Obtain the fractional bin hours for the cooling season, n_j/N, from Table 18. Use

Equations 4.1.3-1 and 4.1.3-2, respectively, to evaluate $\dot{Q}_c^{k=1}(T_j)$ and $\dot{E}_c^{k=1}(T_j)$.

TABLE 18—DISTRIBUTION OF FRACTIONAL HOURS WITHIN COOLING SEASON TEMPERATURE BINS

Bin number, j	Bin temperature range, °F	Representative temperature for bin, °F	Fraction of total temperature bin hours, n _j /N
1	65–69	67	0.214
2	70–74	72	0.231
3	75–79	77	0.216
4	80–84	82	0.161
5	85–89	87	0.104
6	90–94	92	0.052
7	95–99	97	0.018
8	100–104	102	0.004

4.1.2.5 Unit alternates between high (k=2) and low (k=1) compressor capacity to satisfy the building cooling

load at temperature T_j, $\dot{Q}_c^{k=1}(T_j) < BL(T_j) < \dot{Q}_c^{k=2}(T_j)$.

$$\frac{q_c(T_j)}{N} = [X^{k=1}(T_j) * \dot{Q}_c^{k=1}(T_j) + X^{k=2}(T_j) * \dot{Q}_c^{k=2}(T_j)] * \frac{n_j}{N}$$

$$\frac{e_c(T_j)}{N} = [X^{k=1}(T_j) * \dot{E}_c^{k=1}(T_j) + X^{k=2}(T_j) * \dot{E}_c^{k=2}(T_j)] * \frac{n_j}{N}$$

where:

$$X^{k=1}(T_j) = \frac{\dot{Q}_c^{k=2}(T_j) - BL(T_j)}{\dot{Q}_c^{k=2}(T_j) - \dot{Q}_c^{k=1}(T_j)}$$

the cooling mode, low capacity load factor for temperature

bin j, dimensionless.

$X^{k=2}(T_j) = 1 - X^{k=1}(T_j)$, the cooling mode, high capacity load factor for temperature bin j, dimensionless.

Obtain the fractional bin hours for the cooling season, n_j/N , from Table 18. Use Equations 4.1.3-1 and 4.1.3-2,

respectively, to evaluate $\dot{Q}_c^{k=1}(T_j)$ and $\dot{E}_c^{k=1}(T_j)$. Use Equations 4.1.3-3 and 4.1.3-4, respectively, to evaluate $\dot{Q}_c^{k=2}(T_j)$ and $\dot{E}_c^{k=2}(T_j)$.
4.1.2.6 Unit only operates at high (k = 2) compressor capacity at temperature T_j

and its capacity is greater than the building cooling load, $BL(T_j) < \dot{Q}_c^{k=2}(T_j)$. This section applies to units that lock out low compressor capacity operation at higher outdoor temperatures.

$$\frac{q_c(T_j)}{N} = X^{k=2}(T_j) * \dot{Q}_c^{k=2}(T_j) * \frac{n_j}{N} \qquad \frac{e_c(T_j)}{N} = \frac{X^{k=2}(T_j) * \dot{E}_c^{k=2}(T_j)}{PLF_j} * \frac{n_j}{N}$$

Where:

$X^{k=2}(T_j) = BL(T_j) / \dot{Q}_c^{k=2}(T_j)$, the cooling mode high capacity load factor for temperature bin j, dimensionless.

$PLF_j = 1 - C_{D^c}(k=2) * [1 - X^{k=2}(T_j)]$ the part load factor, dimensionless.

Obtain the fraction bin hours for the cooling season, $\frac{n_j}{N}$, from Table 18. Use Equations 4.1.3-

3 and 4.1.3-4, respectively, to evaluate $\dot{Q}_c^{k=2}(T_j)$ and $\dot{E}_c^{k=2}(T_j)$. If the C_2 and D_2 tests described

in section 3.2.3 and Table 6 of this appendix are not conducted, set $C_{D^c}(k=2)$ equal to the default

value specified in section 3.5.3 of this appendix.

4.1.2.7 Unit must operate continuously at high (k = 2) compressor capacity at temperature T_j , $BL(T_j) \geq \dot{Q}_c^{k=2}(T_j)$.

$$\frac{q_c(T_j)}{N} = \dot{Q}_c^{k=2}(T_j) * \frac{n_j}{N} \qquad \frac{e_c(T_j)}{N} = \dot{E}_c^{k=2}(T_j) * \frac{n_j}{N}$$

Obtain the fractional bin hours for the cooling season, n_j/N , from Table 18. Use Equations 4.1.3-3 and 4.1.3-4, respectively, to evaluate $\dot{Q}_c^{k=2}(T_j)$ and $\dot{E}_c^{k=2}(T_j)$.

4.1.3 SEER Calculations for an Air Conditioner or Heat Pump Having a Variable-Speed Compressor

Calculate SEER using Equation 4.1-1. Evaluate the space cooling capacity,

$\dot{Q}_c^{k=1}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=1}(T_j)$, of the test unit when operating at minimum compressor speed and outdoor temperature T_j . Use,

$$\text{Equation 4.1.4-1 } \dot{Q}_c^{k=1}(T_j) = \dot{Q}_c^{k=1}(67) + \frac{\dot{Q}_c^{k=1}(82) - \dot{Q}_c^{k=1}(67)}{82 - 67} * (T_j - 67)$$

$$\text{Equation 4.1.4-2 } \dot{E}_c^{k=1}(T_j) = \dot{E}_c^{k=1}(67) + \frac{\dot{E}_c^{k=1}(82) - \dot{E}_c^{k=1}(67)}{82 - 67} * (T_j - 67)$$

where $\dot{Q}_c^{k=1}(82)$ and $\dot{E}_c^{k=1}(82)$ are determined from the B₁ test, $\dot{Q}_c^{k=1}(67)$ and $\dot{E}_c^{k=1}(67)$ are determined from the F1 test, and all four quantities are calculated as specified in section 3.3 of this appendix. Evaluate the space cooling capacity, $\dot{Q}_c^{k=2}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=2}(T_j)$, of the test unit when operating at full compressor speed and outdoor temperature T_j . Use Equations 4.1.3-3 and 4.1.3-4, respectively, where

$\dot{Q}_c^{k=2}(95)$ and $\dot{E}_c^{k=2}(95)$ are determined from the A₂ test, $\dot{Q}_c^{k=2}(82)$ and $\dot{E}_c^{k=2}(82)$ are determined from the B₂ test, and all four quantities are calculated as specified in section 3.3 of this appendix. Calculate the space cooling capacity, $\dot{Q}_c^{k=v}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=v}(T_j)$, of the test unit when operating at outdoor temperature T_j and the intermediate compressor speed used during the section 3.2.4 (and Table 7) E_v test of this appendix using,

$$\text{Equation 4.1.4-3 } \dot{Q}_c^{k=v}(T_j) = \dot{Q}_c^{k=v}(87) + M_Q * (T_j - 87)$$

$$\text{Equation 4.1.4-4 } \dot{E}_c^{k=v}(T_j) = \dot{E}_c^{k=v}(87) + M_E * (T_j - 87)$$

where $\dot{Q}_c^{k=v}(87)$ and $\dot{E}_c^{k=v}(87)$ are determined from the E_v test and calculated as specified in section 3.3 of this appendix. Approximate the slopes of the k=v intermediate speed cooling capacity and electrical power input curves, M_Q and M_E, as follows:

$$M_Q = \left[\frac{\dot{Q}_c^{k=1}(82) - \dot{Q}_c^{k=1}(67)}{82 - 67} * (1 - N_Q) \right] + \left[N_Q * \frac{\dot{Q}_c^{k=2}(95) - \dot{Q}_c^{k=2}(82)}{95 - 82} \right]$$

$$M_E = \left[\frac{\dot{E}_c^{k=1}(82) - \dot{E}_c^{k=1}(67)}{82 - 67} * (1 - N_E) \right] + \left[N_E * \frac{\dot{E}_c^{k=2}(95) - \dot{E}_c^{k=2}(82)}{95 - 82} \right]$$

where,

$$N_Q = \frac{\dot{Q}_c^{k=v}(87) - \dot{Q}_c^{k=1}(87)}{\dot{Q}_c^{k=2}(87) - \dot{Q}_c^{k=1}(87)} \quad N_E = \frac{\dot{E}_c^{k=v}(87) - \dot{E}_c^{k=1}(87)}{\dot{E}_c^{k=2}(87) - \dot{E}_c^{k=1}(87)}$$

Use Equations 4.1.4-1 and 4.1.4-2, respectively, to calculate $\dot{Q}_c^{k=1}(87)$ and $\dot{E}_c^{k=1}(87)$.

4.1.3.1 Steady-state space cooling capacity when operating at minimum compressor speed is greater than or

equal to the building cooling load at temperature T_j , $\dot{Q}_c^{k=1}(T_j) \geq BL(T_j)$.

$$\frac{q_c(T_j)}{N} = X^{k=1}(T_j) * \dot{Q}_c^{k=1}(T_j) * \frac{n_j}{N} \quad \frac{e_c(T_j)}{N} = \frac{X^{k=1}(T_j) * \dot{E}_c^{k=1}(T_j)}{PLF_j} * \frac{n_j}{N}$$

Where:

$X^{k=1}(T_j) = BL(T_j) / \dot{Q}_c^{k=1}(T_j)$, the cooling mode minimum speed load factor for temperature bin j, dimensionless.

$PLF_j = 1 - C_D^c * [1 - X^{k=1}(T_j)]$, the part load factor, dimensionless.

n_j/N = fractional bin hours for the cooling season; the ratio of the number of hours

during the cooling season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the cooling season, dimensionless.

Obtain the fractional bin hours for the cooling season, n_j/N , from Table 18. Use Equations 4.1.3-1 and 4.1.3-2,

respectively, to evaluate $\dot{Q}_c^{k=1}(T_j)$ and $\dot{E}_c^{k=1}(T_j)$.

4.1.3.2 Unit operates at an intermediate compressor speed (k=i) in order to match the building cooling load at temperature T_j , $\dot{Q}_c^{k=1}(T_j) < BL(T_j) < \dot{Q}_c^{k=2}(T_j)$.

$$\frac{q_c(T_j)}{N} = \dot{Q}_c^{k=i}(T_j) * \frac{n_j}{N} \quad \frac{e_c(T_j)}{N} = \dot{E}_c^{k=i}(T_j) * \frac{n_j}{N}$$

Where:

$\dot{Q}_c^{k=i}(T_j) = BL(T_j)$, the space cooling capacity delivered by the unit in matching the building load at temperature T_j , Btu/h.

The matching occurs with the unit operating at compressor speed $k = i$.

$$\dot{E}_c^{k=i}(T_j) = \frac{\dot{Q}_c^{k=i}(T_j)}{EER^{k=i}(T_j)}$$

the electrical power input required by the test unit when

operating at a compressor speed of $k = i$ and temperature T_j , W.

$EER^{k=i}(T_j)$ = the steady-state energy efficiency ratio of the test unit when operating at a compressor speed of $k = i$ and temperature T_j , Btu/h per W.

Obtain the fractional bin hours for the cooling season, n_j/N , from Table 18. For

each temperature bin where the unit operates at an intermediate compressor speed, determine the energy efficiency ratio $EER^{k=i}(T_j)$ using,

$$EER^{k=i}(T_j) = A + B \cdot T_j + C \cdot T_j^2.$$

For each unit, determine the coefficients A, B, and C by conducting the following calculations once:

$$D = \frac{T_2^2 - T_1^2}{T_v^2 - T_1^2} \quad B = \frac{EER^{k=1}(T_1) - EER^{k=2}(T_2) - D * [EER^{k=1}(T_1) - EER^{k=v}(T_v)]}{T_1 - T_2 - D * (T_1 - T_v)}$$

$$C = \frac{EER^{k=1}(T_1) - EER^{k=2}(T_2) - B * (T_1 - T_2)}{T_1^2 - T_2^2} \quad A = EER^{k=1}(T_2) - B * T_2 - C * T_2^2$$

Where:

T_1 = the outdoor temperature at which the unit, when operating at minimum compressor speed, provides a space cooling capacity that is equal to the building load ($Q_c^{k=1}(T_1) = BL(T_1)$), °F. Determine T_1 by equating Equations

4.1.3–1 and 4.1–2 and solving for outdoor temperature.
 T_v = the outdoor temperature at which the unit, when operating at the intermediate compressor speed used during the section 3.2.4 Ev test of this appendix, provides a space cooling capacity that is equal to the building load ($Q_c^{k=v}(T_v) = BL(T_v)$), °F. Determine T_v by equating

Equations 4.1.4–3 and 4.1–2 and solving for outdoor temperature.
 T_2 = the outdoor temperature at which the unit, when operating at full compressor speed, provides a space cooling capacity that is equal to the building load ($Q_c^{k=2}(T_2) = BL(T_2)$), °F. Determine T_2 by equating Equations 4.1.3–3 and 4.1–2 and solving for outdoor temperature.

$$EER^{k=1}(T_1) = \frac{\dot{Q}_c^{k=1}(T_j)[Eqn. 4.1.4 - 1, substituting T_1 for T_j]}{\dot{E}_c^{k=1}(T_j)[Eqn. 4.1.4 - 2, substituting T_1 for T_j]}, \text{ Btu/h per W}$$

$$EER^{k=v}(T_v) = \frac{\dot{Q}_c^{k=v}(T_v)[Eqn. 4.1.4 - 3, substituting T_v for T_j]}{\dot{E}_c^{k=v}(T_v)[Eqn. 4.1.4 - 4, substituting T_v for T_j]}, \text{ Btu/h per W}$$

$$EER^{k=2}(T_2) = \frac{\dot{Q}_c^{k=2}(T_2)[Eqn. 4.1.3 - 3, substituting T_2 for T_j]}{\dot{E}_c^{k=2}(T_2)[Eqn. 4.1.3 - 4, substituting T_2 for T_j]}, \text{ Btu/h per W}$$

4.1.3.3 Unit must operate continuously at full ($k = 2$) compressor speed at temperature T_j , $BL(T_j) \geq \dot{Q}_c^{k=2}(T_j)$. Evaluate the Equation 4.1–1 quantities

$$\frac{q_c(T_j)}{N} \text{ and } \frac{e_c(T_j)}{N}$$

as specified in section 4.1.2.7 of this appendix with the understanding that $\dot{Q}_c^{k=2}(T_j)$ and $\dot{E}_c^{k=2}(T_j)$ correspond to full compressor speed operation and are derived from the results of the tests specified in section 3.2.4 of this appendix.

4.1.4 SEER Calculations for an Air Conditioner or Heat Pump Having a Single Indoor Unit With Multiple Indoor Blowers

Calculate SEER using Eq. 4.1–1, where $q_c(T_j)/N$ and $e_c(T_j)/N$ are evaluated as specified in the applicable subsection.

4.1.4.1 For Multiple Indoor Blower Systems That Are Connected to a Single, Single-Speed Outdoor Unit

a. Calculate the space cooling capacity, $\dot{Q}_c^{k=1}(T_j)$, and electrical power consumption, $\dot{E}_c^{k=1}(T_j)$, of the test unit when operating at the cooling minimum air volume rate and outdoor temperature T_j using the equations given in section 4.1.2.1 of this appendix. Calculate the space cooling capacity, $\dot{Q}_c^{k=2}(T_j)$, and

electrical power consumption, $\dot{E}_c^{k=2}(T_j)$, of the test unit when operating at the cooling full-load air volume rate and outdoor temperature T_j using the equations given in section 4.1.2.1 of this appendix. In evaluating the section 4.1.2.1 equations, determine the quantities $\dot{Q}_c^{k=1}(82)$ and $\dot{E}_c^{k=1}(82)$ from the B1 test, $\dot{Q}_c^{k=1}(95)$ and $\dot{E}_c^{k=1}(95)$ from the A1 test, $\dot{Q}_c^{k=2}(82)$ and $\dot{E}_c^{k=2}(82)$ from the B2 test, and $\dot{Q}_c^{k=2}(95)$ and $\dot{E}_c^{k=2}(95)$ from the A2 test. Evaluate all eight quantities as specified in section 3.3 of this appendix. Refer to section 3.2.2.1 and Table 5 of this appendix for additional information on the four referenced laboratory tests.

b. Determine the cooling mode cyclic degradation coefficient, CD_c , as per sections 3.2.2.1 and 3.5 to 3.5.3 of this

appendix. Assign this same value to $CD_c(K=2)$.

c. Except for using the above values of $\dot{Q}_{c,k=1}(T_j)$, $\dot{E}_{c,k=1}(T_j)$, $\dot{E}_{c,k=2}(T_j)$, $\dot{Q}_{c,k=2}(T_j)$, CD_c , and $CD_c(K=2)$, calculate the quantities $q_c(T_j)/N$ and $e_c(T_j)/N$ as specified in section 4.1.3.1 of this appendix for cases where $\dot{Q}_{c,k=1}(T_j) \geq BL(T_j)$. For all other outdoor bin temperatures, T_j , calculate $q_c(T_j)/N$ and $e_c(T_j)/N$ as specified in section 4.1.3.3 of this appendix if $\dot{Q}_{c,k=2}(T_j) > BL(T_j)$ or as

specified in section 4.1.3.4 of this appendix if $\dot{Q}_{c,k=2}(T_j) \leq BL(T_j)$.

4.1.4.2 For multiple indoor blower systems that are connected to either a lone outdoor unit having a two-capacity compressor or to two separate single-speed outdoor units of identical model, calculate the quantities $q_c(T_j)/N$ and $e_c(T_j)/N$ as specified in section 4.1.3 of this appendix.

4.2 Heating Seasonal Performance Factor (HSPF) Calculations

Unless an approved alternative efficiency determination method is used, as set forth in 10 CFR 429.70(e), HSPF must be calculated as follows: Six generalized climatic regions are depicted in Figure 1 and otherwise defined in Table 19. For each of these regions and for each applicable standardized design heating requirement, evaluate the heating seasonal performance factor using,

$$\text{Equation 4.2-1 } HSPF = \frac{\sum_j n_j * BL(T_j)}{\sum_j e_h(T_j) + \sum_j RH(T_j)} * F_{def} = \frac{\sum_j \left[\frac{n_j}{N} * BL(T_j) \right]}{\sum_j \frac{e_h(T_j)}{N} + \sum_j \frac{RH(T_j)}{N}} * F_{def}$$

Where:

$e_h(T_j)/N$ = The ratio of the electrical energy consumed by the heat pump during periods of the space heating season when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the heating season (N), W. For heat pumps having a heat comfort controller, this ratio may also include electrical energy used by resistive elements to maintain a minimum air delivery temperature (see 4.2.5).

$RH(T_j)/N$ = The ratio of the electrical energy used for resistive space heating during periods when the outdoor temperature fell within the range represented by bin temperature T_j to the total number of hours in the heating season (N), W. Except as noted in section 4.2.5 of this appendix, resistive space heating is

modeled as being used to meet that portion of the building load that the heat pump does not meet because of insufficient capacity or because the heat pump automatically turns off at the lowest outdoor temperatures. For heat pumps having a heat comfort controller, all or part of the electrical energy used by resistive heaters at a particular bin temperature may be reflected in $e_h(T_j)/N$ (see section 4.2.5 of this appendix).

T_j = the outdoor bin temperature, °F. Outdoor temperatures are “binned” such that calculations are only performed based one temperature within the bin. Bins of 5 °F are used.

n_j/N = Fractional bin hours for the heating season; the ratio of the number of hours during the heating season when the outdoor temperature fell within the range represented by bin temperature T_j

to the total number of hours in the heating season, dimensionless. Obtain n_j/N values from Table 19.

j = the bin number, dimensionless.

J = for each generalized climatic region, the total number of temperature bins, dimensionless. Referring to Table 19, J is the highest bin number (j) having a nonzero entry for the fractional bin hours for the generalized climatic region of interest.

F_{def} = the demand defrost credit described in section 3.9.2 of this appendix, dimensionless.

$BL(T_j)$ = the building space conditioning load corresponding to an outdoor temperature of T_j ; the heating season building load also depends on the generalized climatic region’s outdoor design temperature and the design heating requirement, Btu/h.

TABLE 19—GENERALIZED CLIMATIC REGION INFORMATION

Region No.	I	II	III	IV	V	VI
Heating Load Hours, HLH	750	1,250	1,750	2,250	2,750	*2,750
Outdoor Design Temperature, T_{OD}	37	27	17	5	-10	30
j T_j (°F)	Fractional Bin Hours, n_j/N					
1 62291	.215	.153	.132	.106	.113
2 57239	.189	.142	.111	.092	.206
3 52194	.163	.138	.103	.086	.215
4 47129	.143	.137	.093	.076	.204
5 42081	.112	.135	.100	.078	.141
6 37041	.088	.118	.109	.087	.076
7 32019	.056	.092	.126	.102	.034
8 27005	.024	.047	.087	.094	.008
9 22001	.008	.021	.055	.074	.003
10 17	0	.002	.009	.036	.055	0
11 12	0	0	.005	.026	.047	0
12 7	0	0	.002	.013	.038	0
13 2	0	0	.001	.006	.029	0
14 -3	0	0	0	.002	.018	0
15 -8	0	0	0	.001	.010	0
16 -13	0	0	0	0	.005	0
17 -18	0	0	0	0	.002	0
18 -23	0	0	0	0	.001	0

* Pacific Coast Region.

Evaluate the building heating load using

$$\text{Equation 4.2-2} \quad BL(T_j) = \frac{(65-T_j)}{65-T_{OD}} * C * DHR$$

Where:

T_{OD} = the outdoor design temperature, °F. An outdoor design temperature is specified for each generalized climatic region in Table 19.

C = 0.77, a correction factor which tends to improve the agreement between calculated and measured building loads, dimensionless.
 DHR = the design heating requirement (see section 1.2 of this appendix, Definitions), Btu/h.

Calculate the minimum and maximum design heating requirements for each generalized climatic region as follows:

$$DHR_{min} = \begin{cases} \dot{Q}_h^k(47) * \left[\frac{65 - T_{OD}}{60} \right], & \text{for Regions I, II, III, IV, \& VI} \\ \dot{Q}_h^k(47), & \text{for Region V} \end{cases}$$

and

$$DHR_{max} = \begin{cases} 2 * \dot{Q}_h^k(47) * \left[\frac{65 - T_{OD}}{60} \right], & \text{for Regions I, II, III, IV, \& VI} \\ 2.2 * \dot{Q}_h^k(47), & \text{for Region V} \end{cases}$$

Rounded to the nearest standardized DHR given in Table 19

where $\dot{Q}_h^k(47)$ is expressed in units of Btu/h and otherwise defined as follows:

a. For a single-speed heat pump tested as per section 3.6.1 of this appendix, $\dot{Q}_h^k(47) = \dot{Q}_h(47)$, the space heating capacity determined from the H1 test.

b. For a variable-speed heat pump, a section 3.6.2 single-speed heat pump, or a two-capacity heat pump not covered by item 3, $\dot{Q}_h^k(47) = \dot{Q}_h^{k=2}(47)$, the space heating capacity determined from the H1₂ test.

c. For two-capacity, northern heat pumps (see section 1.2 of this appendix, Definitions), $\dot{Q}_h^k(47) = \dot{Q}_h^{k=1}(47)$, the space heating capacity determined from the H1₁ test.

If the optional H1_N test is conducted on a variable-speed heat pump, the manufacturer has the option of defining $\dot{Q}_h^k(47)$ as specified above in item 2 or as $\dot{Q}_h^k(47) = \dot{Q}_h^{k=N}(47)$, the space

heating capacity determined from the H1_N test.

For all heat pumps, HSPF accounts for the heating delivered and the energy consumed by auxiliary resistive elements when operating below the balance point. This condition occurs when the building load exceeds the space heating capacity of the heat pump condenser. For HSPF calculations for all heat pumps, see either section 4.2.1, 4.2.2, 4.2.3, or 4.2.4 of this appendix, whichever applies.

For heat pumps with heat comfort controllers (see section 1.2 of this appendix, Definitions), HSPF also accounts for resistive heating contributed when operating above the heat-pump-plus-comfort-controller balance point as a result of maintaining a minimum supply temperature. For heat pumps having a heat comfort controller, see section 4.2.5 of this

appendix for the additional steps required for calculating the HSPF.

TABLE 20—STANDARDIZED DESIGN HEATING REQUIREMENTS [Btu/h]

5,000	50,000
10,000	60,000
15,000	70,000
20,000	80,000
25,000	90,000
30,000	100,000
35,000	110,000
40,000	130,000

4.2.1 Additional steps for calculating the HSPF of a blower coil system heat pump having a single-speed compressor and either a fixed-speed indoor blower or a constant-air-volume indoor blower installed, or a coil-only system heat pump.

$$\text{Equation 4.2.1-1} \quad \frac{e_h(T_j)}{N} = \frac{X(T_j) * \dot{E}_h(T_j) * \delta(T_j)}{PLF_j} * \frac{n_j}{N}$$

$$\text{Equation 4.2.1-2 } \frac{RH(T_j)}{N} = \frac{BL(T_j) - [X(T_j) * \dot{Q}_h(T_j) * \delta(T_j)]}{3.413 \frac{\text{Btu/h}}{W}} * \frac{n_j}{N}$$

where:

$$X(T_j) = \left\{ \begin{array}{c} BL(T_j) / \dot{Q}_h(T_j) \\ \text{or} \\ 1 \end{array} \right\}$$

whichever is less; the heating mode load factor for temperature bin j, dimensionless.

whichever is less; the heating mode load factor for temperature bin j, dimensionless.

$\dot{Q}_h(T_j)$ = the space heating capacity of the heat pump when operating at outdoor temperature T_j , Btu/h.

$\dot{E}_h(T_j)$ = the electrical power consumption of the heat pump when operating at outdoor temperature T_j , W.

$\delta(T_j)$ = the heat pump low temperature cut-out factor, dimensionless.

$PLF_j = 1 - C_{D^h} \cdot [1 - X(T_j)]$ the part load factor, dimensionless.

Use Equation 4.2–2 to determine $BL(T_j)$. Obtain fractional bin hours for the heating season, n_j/N , from Table 19.

Determine the low temperature cut-out factor using

$$\text{Equation 4.2.1-3 } \delta(T_j) = \left\{ \begin{array}{l} 0, \text{ if } T_j \leq T_{off} \text{ and } \frac{\dot{Q}_h(T_j)}{3.413 * \dot{E}_h(T_j)} < 1 \\ 1/2, \text{ if } T_{off} < T_j \leq T_{on} \text{ and } \frac{\dot{Q}_h(T_j)}{3.413 * \dot{E}_h(T_j)} \geq 1 \\ 1, \text{ if } T_j > T_{on} \text{ and } \frac{\dot{Q}_h(T_j)}{3.413 * \dot{E}_h(T_j)} \geq 1 \end{array} \right\}$$

Where:

T_{off} = the outdoor temperature when the compressor is automatically shut off, °F.

(If no such temperature exists, T_j is always greater than T_{off} and T_{on}).
 T_{on} = the outdoor temperature when the compressor is automatically turned back

on, if applicable, following an automatic shut-off, °F.

Calculate $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ using,

$$\text{Equation 4.2.1-4 } \dot{Q}_h(T_j) = \left\{ \begin{array}{l} \dot{Q}_h(17) + \frac{[\dot{Q}_h(47) - \dot{Q}_h(17)] * (T_j - 17)}{47 - 17}, \text{ if } T_j \geq 45 \text{ °F or } T_j \leq 17 \text{ °F} \\ \dot{Q}_h(17) + \frac{[\dot{Q}_h(35) - \dot{Q}_h(17)] * (T_j - 17)}{35 - 17}, \text{ if } 17 \text{ °F} < T_j < 45 \text{ °F} \end{array} \right.$$

Equation 4.2.1-5

$$\dot{E}_h(T_j) = \left\{ \begin{array}{l} \dot{E}_h(17) + \frac{[\dot{E}_h(47) - \dot{E}_h(17)] * (T_j - 17)}{47 - 17}, \text{ if } T_j \geq 45 \text{ °F or } T_j \leq 17 \text{ °F} \\ \dot{E}_h(17) + \frac{[\dot{E}_h(35) - \dot{E}_h(17)] * (T_j - 17)}{35 - 17}, \text{ if } 17 \text{ °F} < T_j < 45 \text{ °F} \end{array} \right.$$

where $\dot{Q}_h(47)$ and $\dot{E}_h(47)$ are determined from the H1 test and calculated as specified in section 3.7 of this appendix; $\dot{Q}_h(35)$ and $\dot{E}_h(35)$ are determined from the H2 test and calculated as specified in section 3.9.1 of this appendix; and $\dot{Q}_h(17)$ and $\dot{E}_h(17)$ are determined from the H3 test and calculated as specified in section 3.10 of this appendix.

4.2.2 Additional steps for calculating the HSPF of a heat pump having a single-speed compressor and a variable-speed, variable-air-volume indoor blower.

The manufacturer must provide information about how the indoor air volume rate or the indoor blower speed varies over the outdoor temperature

range of 65 °F to –23 °F. Calculate the quantities

$$\frac{e_h(T_j)}{N} \text{ and } \frac{RH(T_j)}{N}$$

in Equation 4.2–1 as specified in section 4.2.1 of this appendix with the exception of replacing references to the

H1C test and section 3.6.1 of this appendix with the H1C₁ test and section 3.6.2 of this appendix. In addition, electrical power consumption of the heat pump $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ using

$$\text{Equation 4.2.2-1 } \dot{Q}_h(T_j) = \dot{Q}_h^{k=1}(T_j) + \frac{\dot{Q}_h^{k=2}(T_j) - \dot{Q}_h^{k=1}(T_j)}{FP_h^{k=2} - FP_h^{k=1}} * [FP_h(T_j) - FP_h^{k=1}]$$

$$\text{Equation 4.2.2-2 } \dot{E}_h(T_j) = \dot{E}_h^{k=1}(T_j) + \frac{\dot{E}_h^{k=2}(T_j) - \dot{E}_h^{k=1}(T_j)}{FP_h^{k=2} - FP_h^{k=1}} * [FP_h(T_j) - FP_h^{k=1}]$$

where the space heating capacity and electrical power consumption at both low capacity (k=1) and high capacity (k=2) at outdoor temperature T_j are determined using

$$\text{Equation 4.2.2-3 } \dot{Q}_h^k(T_j) = \begin{cases} \dot{Q}_h^k(17) + \frac{[\dot{Q}_h^k(47) - \dot{Q}_h^k(17)] * (T_j - 17)}{47 - 17}, & \text{if } T_j \geq 45 \text{ }^\circ\text{F or } T_j \leq 17 \text{ }^\circ\text{F} \\ \dot{Q}_h^k(17) + \frac{[\dot{Q}_h^k(35) - \dot{Q}_h^k(17)] * (T_j - 17)}{35 - 17}, & \text{if } 17 \text{ }^\circ\text{F} < T_j < 45 \text{ }^\circ\text{F} \end{cases}$$

Equation 4.2.2-4

$$\dot{E}_h^k(T_j) = \begin{cases} \dot{E}_h^k(17) + \frac{[\dot{E}_h^k(47) - \dot{E}_h^k(17)] * (T_j - 17)}{47 - 17}, & \text{if } T_j \geq 45 \text{ }^\circ\text{F or } T_j \leq 17 \text{ }^\circ\text{F} \\ \dot{E}_h^k(17) + \frac{[\dot{E}_h^k(35) - \dot{E}_h^k(17)] * (T_j - 17)}{35 - 17}, & \text{if } 17 \text{ }^\circ\text{F} < T_j < 45 \text{ }^\circ\text{F} \end{cases}$$

For units where indoor blower speed is the primary control variable, $FP_h^{k=1}$ denotes the fan speed used during the required H1₁ and H3₁ tests (see Table 11), $FP_h^{k=2}$ denotes the fan speed used during the required H1₂, H2₂, and H3₂ tests, and $FP_h(T_j)$ denotes the fan speed used by the unit when the outdoor temperature equals T_j . For units where indoor air volume rate is the primary control variable, the three FP_h 's are similarly defined only now being expressed in terms of air volume rates rather than fan speeds. Determine $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ from the H1₁ test, and $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the H1₂ test. Calculate all four quantities

as specified in section 3.7 of this appendix. Determine $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ as specified in section 3.6.2 of this appendix; determine $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ and from the H2₂ test and the calculation specified in section 3.9 of this appendix. Determine $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17)$ from the H3₁ test, and $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the H3₂ test. Calculate all four quantities as specified in section 3.10 of this appendix.

4.2.3 Additional Steps for Calculating the HSPF of a Heat Pump Having a Two-Capacity Compressor

The calculation of the Equation 4.2-1 quantities differ depending upon

whether the heat pump would operate at low capacity (section 4.2.3.1 of this appendix), cycle between low and high capacity (section 4.2.3.2 of this appendix), or operate at high capacity (sections 4.2.3.3 and 4.2.3.4 of this appendix) in responding to the building load. For heat pumps that lock out low capacity operation at low outdoor temperatures, the manufacturer must supply information regarding the cutoff temperature(s) so that the appropriate equations can be selected.

$$\frac{e_h(T_j)}{N} \text{ and } \frac{RH(T_j)}{N}$$

a. Evaluate the space heating capacity and electrical power consumption of the heat pump when operating at low

compressor capacity and outdoor temperature T_j using

$$\dot{Q}_h^{k=1}(T_j) = \begin{cases} \dot{Q}_h^{k=1}(47) + \frac{[\dot{Q}_h^{k=1}(62) - \dot{Q}_h^{k=1}(47)] * (T_j - 47)}{62 - 47}, & \text{if } T_j \geq 40 \text{ }^\circ\text{F} \\ \dot{Q}_h^{k=1}(17) + \frac{[\dot{Q}_h^{k=1}(35) - \dot{Q}_h^{k=1}(17)] * (T_j - 17)}{35 - 17}, & \text{if } 17 \text{ }^\circ\text{F} \leq T_j < 40 \text{ }^\circ\text{F} \\ \dot{Q}_h^{k=1}(17) + \frac{[\dot{Q}_h^{k=1}(47) - \dot{Q}_h^{k=1}(17)] * (T_j - 17)}{47 - 17}, & \text{if } T_j < 17 \text{ }^\circ\text{F} \end{cases}$$

$$\dot{E}_h^{k=1}(T_j) = \begin{cases} \dot{E}_h^{k=1}(47) + \frac{[\dot{E}_h^{k=1}(62) - \dot{E}_h^{k=1}(47)] * (T_j - 47)}{62 - 47}, & \text{if } T_j \geq 40 \text{ }^\circ\text{F} \\ \dot{E}_h^{k=1}(17) + \frac{[\dot{E}_h^{k=1}(35) - \dot{E}_h^{k=1}(17)] * (T_j - 17)}{35 - 17}, & \text{if } 17 \text{ }^\circ\text{F} \leq T_j < 40 \text{ }^\circ\text{F} \\ \dot{E}_h^{k=1}(17) + \frac{[\dot{E}_h^{k=1}(47) - \dot{E}_h^{k=1}(17)] * (T_j - 17)}{47 - 17}, & \text{if } T_j < 17 \text{ }^\circ\text{F} \end{cases}$$

b. Evaluate the space heating capacity and electrical power consumption ($\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$) of the heat pump when operating at high compressor capacity and outdoor temperature T_j by solving Equations 4.2.2-3 and 4.2.2-4, respectively, for $k=2$. Determine $\dot{Q}_h^{k=1}(62)$ and $\dot{E}_h^{k=1}(62)$ from the H0₁ test, $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ from the H1₁ test, and $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the H1₂

test. Calculate all six quantities as specified in section 3.7 of this appendix. Determine $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ from the H2₂ test and, if required as described in section 3.6.3 of this appendix, determine $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ from the H2₁ test. Calculate the required 35 °F quantities as specified in section 3.9 of this appendix. Determine $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the H3₂ test and, if required as described in section 3.6.3 of

this appendix, determine $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17)$ from the H3₁ test. Calculate the required 17 °F quantities as specified in section 3.10 of this appendix.

4.2.3.1 Steady-state space heating capacity when operating at low compressor capacity is greater than or equal to the building heating load at temperature T_j , $\dot{Q}_h^{k=1}(T_j) \geq BL(T_j)$.

$$\text{Equation 4.2.3-1 } \frac{e_h(T_j)}{N} = \frac{X^{k=1}(T_j) * \dot{E}_h^{k=1}(T_j) * \delta(T_j)}{PLF_j} * \frac{n_j}{N}$$

$$\text{Equation 4.2.3-2 } \frac{RH(T_j)}{N} = \frac{BL(T_j) * [1 - \delta(T_j)]}{3.413 \frac{Btu/h}{W}} * \frac{n_j}{N}$$

Where:

$X^{k=1}(T_j) = BL(T_j) / \dot{Q}_h^{k=1}(T_j)$, the heating mode low capacity load factor for temperature bin j , dimensionless.

$PLF_j = 1 - C_D^h \cdot [1 - X^{k=1}(T_j)]$, the part load factor, dimensionless.
 $\delta(T_j)$ = the low temperature cutoff factor, dimensionless.

Determine the low temperature cut-out factor using

$$\text{Equation 4.2.3-3 } \delta(T_j) = \begin{cases} 0, & \text{if } T_j \leq T_{off} \\ 1/2, & \text{if } T_{off} < T_j \leq T_{on} \\ 1, & \text{if } T_j > T_{on} \end{cases}$$

where T_{off} and T_{on} are defined in section 4.2.1 of this appendix. Use the calculations given in section 4.2.3.3 of this appendix, and not the above, if:

a. The heat pump locks out low capacity operation at low outdoor temperatures and
 b. T_j is below this lockout threshold temperature.

4.2.3.2 Heat pump alternates between high ($k=2$) and low ($k=1$) compressor capacity to satisfy the building heating load at a temperature T_j , $\dot{Q}_h^{k=1}(T_j) < BL(T_j) < \dot{Q}_h^{k=2}(T_j)$.

Calculate $\frac{RH(T_j)}{N}$ using Equation 4.2.3-2. Evaluate $\frac{e_h(T_j)}{N}$ using

$$\frac{e_h(T_j)}{N} = [X^{k=1}(T_j) * \dot{E}_h^{k=1}(T_j) + X^{k=2}(T_j) * \dot{E}_h^{k=2}(T_j)] * \delta(T_j) * \frac{n_j}{N}$$

where:

$$X^{k=1}(T_j) = \frac{\dot{Q}_h^{k=2}(T_j) - BL(T_j)}{\dot{Q}_h^{k=2}(T_j) - \dot{Q}_h^{k=1}(T_j)}$$

$X^{k=2}(T_j) = 1 - X^{k=1}(T_j)$ the heating mode, high capacity load factor for temperature bin j , dimensionless.

Determine the low temperature cut-out factor, $\delta'(T_j)$, using Equation 4.2.3-3.

4.2.3.3 Heat pump only operates at high (k=2) compressor capacity at temperature T_j and its capacity is greater than the building heating load, $BL(T_j)$

$< \dot{Q}_h^{k=2}(T_j)$. This section applies to units that lock out low compressor capacity operation at low outdoor temperatures.

Calculate $\frac{RH(T_j)}{N}$ using Equation 4.2.3-2. Evaluate $\frac{e_h(T_j)}{N}$ using

$$\frac{e_h(T_j)}{N} = \frac{X^{k=2}(T_j) * \dot{E}_h^{k=2}(T_j) * \delta(T_j)}{PLF_j} * \frac{n_j}{N}$$

where:

$$X^{k=2}(T_j) = BL(T_j) / \dot{Q}_h^{k=2}(T_j). \quad PLF_j = 1 - C_D^h(k=2) * [1 - X^{k=2}(T_j)]$$

If the H1C₂ test described in section 3.6.3 and Table 12 of this appendix is not conducted, set C_D^h (k=2) equal to

the default value specified in section 3.8.1 of this appendix.

Determine the low temperature cut-out factor, $\delta(T_j)$, using Equation 4.2.3-3.

4.2.3.4 Heat pump must operate continuously at high (k=2) compressor capacity at temperature T_j , $BL(T_j) \geq \dot{Q}_h^{k=2}(T_j)$.

$$\frac{e_h(T_j)}{N} = \dot{E}_h^{k=2}(T_j) * \delta'(T_j) * \frac{n_j}{N} \quad \frac{RH(T_j)}{N} = \frac{BL(T_j) * [\dot{Q}_h^{k=2}(T_j) * \delta'(T_j)]}{3.413 \frac{Btu/h}{W}} * \frac{n_j}{N}$$

where:

$$\delta'(T_j) = \begin{cases} 0, & \text{if } T_j \leq T_{off} \text{ or } \frac{\dot{Q}_h^{k=2}(T_j)}{3.413 * \dot{E}_h^{k=2}(T_j)} < 1 \\ 1/2, & \text{if } T_{off} < T_j \leq T_{on} \text{ and } \frac{\dot{Q}_h^{k=2}(T_j)}{3.413 * \dot{E}_h^{k=2}(T_j)} \geq 1 \\ 1, & \text{if } T_j > T_{on} \text{ and } \frac{\dot{Q}_h^{k=2}(T_j)}{3.413 * \dot{E}_h^{k=2}(T_j)} \geq 1 \end{cases}$$

4.2.4 Additional Steps for Calculating the HSPF of a Heat Pump Having a Variable-Speed Compressor

Calculate HSPF using Equation 4.2-1. Evaluate the space heating capacity,

$\dot{Q}_h^{k=1}(T_j)$, and electrical power consumption, $\dot{E}_h^{k=1}(T_j)$, of the heat pump when operating at minimum compressor speed and outdoor temperature T_j using

$$\text{Equation 4.2.4-1 } \dot{Q}_h^{k=1}(T_j) = \dot{Q}_h^{k=1}(47) + \frac{\dot{Q}_h^{k=1}(62) - \dot{Q}_h^{k=1}(47)}{62 - 47} * (T_j - 47)$$

$$\text{Equation 4.2.4-2 } \dot{E}_h^{k=1}(T_j) = \dot{E}_h^{k=1}(47) + \frac{\dot{E}_h^{k=1}(62) - \dot{E}_h^{k=1}(47)}{62 - 47} * (T_j - 47)$$

where $\dot{Q}_h^{k=1}(62)$ and $\dot{E}_h^{k=1}(62)$ are determined from the H0₁ test, $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ are determined from the H1₁ test, and all four quantities are calculated as specified in section 3.7 of this appendix.

Evaluate the space heating capacity, $\dot{Q}_h^{k=2}(T_j)$, and electrical power consumption, $\dot{E}_h^{k=2}(T_j)$, of the heat pump when operating at full compressor speed and outdoor temperature T_j by solving Equations 4.2.2-3 and 4.2.2-4, respectively, for $k=2$. Determine the Equation 4.2.2-3 and 4.2.2-4 quantities $\dot{Q}_h^{k=2}(47)$ and

$\dot{E}_h^{k=2}(47)$ from the H1₂ test and the calculations specified in section 3.7 of this appendix. Determine $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ from the H2₂ test and the calculations specified in section 3.9 of this appendix or, if the H2₂ test is not conducted, by conducting the calculations specified in section 3.6.4 of this appendix. Determine $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the H3₂ test and the calculations specified in section 3.10 of this appendix. Calculate the space heating capacity, $\dot{Q}_h^{k=v}(T_j)$, and electrical power consumption, $\dot{E}_h^{k=v}(T_j)$, of the heat pump when operating at

outdoor temperature T_j and the intermediate compressor speed used during the section 3.6.4 H2_v test of this appendix using

$$\text{Equation 4.2.4-3 } \dot{Q}_h^{k=v}(T_j) = \dot{Q}_h^{k=v}(35) + M_Q * (T_j - 35)$$

$$\text{Equation 4.2.4-4 } \dot{E}_h^{k=v}(T_j) = \dot{E}_h^{k=v}(35) + M_E * (T_j - 35)$$

where $\dot{Q}_h^{k=v}(35)$ and $\dot{E}_h^{k=v}(35)$ are determined from the H2_v test and calculated as specified in section 3.9 of this appendix. Approximate the slopes of the $k=v$ intermediate speed heating capacity and electrical power input curves, M_Q and M_E , as follows:

$$M_Q = \left[\frac{\dot{Q}_h^{k=1}(62) - \dot{Q}_h^{k=1}(47)}{62 - 47} * (1 - N_Q) \right] + \left[N_Q * \frac{\dot{Q}_h^{k=2}(35) - \dot{Q}_h^{k=2}(17)}{35 - 17} \right]$$

$$M_E = \left[\frac{\dot{E}_h^{k=1}(62) - \dot{E}_h^{k=1}(47)}{62 - 47} * (1 - N_E) \right] + \left[N_E * \frac{\dot{E}_h^{k=2}(35) - \dot{E}_h^{k=2}(17)}{35 - 17} \right]$$

where,

$$N_Q = \frac{\dot{Q}_h^{k=v}(35) - \dot{Q}_h^{k=1}(35)}{\dot{Q}_h^{k=2}(35) - \dot{Q}_h^{k=1}(35)} \quad N_E = \frac{\dot{E}_h^{k=v}(35) - \dot{E}_h^{k=1}(35)}{\dot{E}_h^{k=2}(35) - \dot{E}_h^{k=1}(35)}$$

Use Equations 4.2.4-1 and 4.2.4-2, respectively, to calculate $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$.

The calculation of Equation 4.2-1 quantities $\frac{RH(T_j)}{N}$ and $\frac{e_h(T_j)}{N}$ differs depending upon whether the heat pump would operate at minimum speed (section 4.2.4.1 of this appendix), operate at an intermediate speed (section 4.2.4.2 of this appendix), or operate at full speed (section 4.2.4.3 of this appendix) in responding to the building load.

4.2.4.1 Steady-state space heating capacity when operating at minimum compressor speed is greater than or

equal to the building heating load at temperature T_j , $\dot{Q}_h^{k=1}(T_j) \geq BL(T_j)$. Evaluate the Equation 4.2-1 quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

as specified in section 4.2.3.1 of this appendix. Except now use Equations 4.2.4-1 and 4.2.4-2 to evaluate $\dot{Q}_h^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j)$, respectively, and replace section 4.2.3.1 references to “low

capacity” and section 3.6.3 of this appendix with “minimum speed” and section 3.6.4 of this appendix. Also, the last sentence of section 4.2.3.1 of this appendix does not apply.

4.2.4.2 Heat pump operates at an intermediate compressor speed (k=i) in order to match the building heating load at a temperature T_j , $\dot{Q}_h^{k=1}(T_j) < BL(T_j) < \dot{Q}_h^{k=2}(T_j)$.

Calculate $\frac{RH(T_j)}{N}$ using Equation 4.2.3-2 while evaluating $\frac{e_h(T_j)}{N}$ using,

$$\frac{e_h(T_j)}{N} = \dot{E}_h^{k=i}(T_j) * \delta(T_j) * \frac{n_j}{N}$$

where:

$$\dot{E}_h^{k=i}(T_j) = \frac{\dot{Q}_h^{k=i}(T_j)}{3.413 \frac{\text{Btu/h}}{\text{W}} * COP^{k=i}(T_j)}$$

and $\delta(T_j)$ is evaluated using Equation 4.2.3-3 while,

$\dot{Q}_h^{k=i}(T_j) = BL(T_j)$, the space heating capacity delivered by the unit in matching the building load at temperature (T_j), Btu/h. The matching occurs with the heat pump operating at compressor speed k=i.

$COP^{k=i}(T_j)$ = the steady-state coefficient of performance of the heat pump when operating at compressor speed k=i and temperature T_j , dimensionless.

For each temperature bin where the heat pump operates at an intermediate

compressor speed, determine $COP^{k=i}(T_j)$ using,

$$COP^{k=i}(T_j) = A + B \cdot T_j + C \cdot T_j^2.$$

For each heat pump, determine the coefficients A, B, and C by conducting the following calculations once:

$$D = \frac{T_3^2 - T_4^2}{T_{vh}^2 - T_4^2} \quad B = \frac{COP^{k=2}(T_4) - COP^{k=1}(T_3) - D * [COP^{k=2}(T_4) - COP^{k=v}(T_{vh})]}{T_4 - T_3 - D * (T_4 - T_{vh})}$$

$$C = \frac{COP^{k=2}(T_4) - COP^{k=2}(T_3) - B * (T_4 - T_3)}{T_4^2 - T_3^2} \quad A = COP^{k=2}(T_4) - B * T_4 - C * T_4^2$$

Where:

T_3 = the outdoor temperature at which the heat pump, when operating at minimum compressor speed, provides a space heating capacity that is equal to the building load ($\dot{Q}_h^{k=1}(T_3) = BL(T_3)$), °F. Determine T_3 by equating Equations 4.2.4-1 and 4.2-2 and solving for outdoor temperature.

T_{vh} = the outdoor temperature at which the heat pump, when operating at the intermediate compressor speed used during the section 3.6.4 H2v test of this appendix, provides a space heating capacity that is equal to the building load ($\dot{Q}_h^{k=v}(T_{vh}) = BL(T_{vh})$), °F. Determine T_{vh} by equating Equations 4.2.4-3 and 4.2-2 and solving for outdoor temperature.

T_4 = the outdoor temperature at which the heat pump, when operating at full compressor speed, provides a space heating capacity that is equal to the building load ($\dot{Q}_h^{k=2}(T_4) = BL(T_4)$), °F. Determine T_4 by equating Equations 4.2.2-3 (k=2) and 4.2-2 and solving for outdoor temperature.

$$COP^{k=1}(T_3) = \frac{\dot{Q}_h^{k=1}(T_3)[Eqn. 4.2.4 - 1, substituting T_3 for T_j]}{3.413 \frac{Btu/h}{W} * E_h^{k=1}(T_3)[Eqn. 4.2.4 - 2, substituting T_3 for T_j]}$$

$$COP^{k=v}(T_{vh}) = \frac{\dot{Q}_h^{k=v}(T_{vh})[Eqn. 4.2.4 - 3, substituting T_{vh} for T_j]}{3.413 \frac{Btu/h}{W} * \dot{E}_h^{k=v}(T_{vh})[Eqn. 4.2.4 - 4, substituting T_{vh} for T_j]}$$

$$COP^{k=2}(T_4) = \frac{\dot{Q}_h^{k=2}(T_4)[Eqn. 4.2.2 - 3, substituting T_4 for T_j]}{3.413 \frac{Btu/h}{W} * \dot{E}_h^{k=2}(T_4)[Eqn. 4.2.2 - 4, substituting T_4 for T_j]}$$

For multiple-split heat pumps (only), the following procedures supersede the above

requirements for calculating $COP_h^{k=i}(T_j)$. For each temperature bin where $T_3 > T_j > T_{vh}$,

$$COP_h^{k=i}(T_j) = COP_h^{k=1}(T_3) + \frac{COP_h^{k=v}(T_{vh}) - COP_h^{k=1}(T_3)}{T_{vh} - T_3} * (T_j - T_3)$$

For each temperature bin where $T_{vh} \geq T_j > T_4$,

$$COP_h^{k=i}(T_j) = COP_h^{k=v}(T_{vh}) + \frac{COP_h^{k=2}(T_4) - COP_h^{k=v}(T_{vh})}{T_4 - T_{vh}} * (T_j - T_{vh})$$

4.2.4.3 Heat pump must operate continuously at full (k=2) compressor speed

at temperature T_j , $BL(T_j) \geq \dot{Q}_h^{k=2}(T_j)$. Evaluate the Equation 4.2-1 quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

as specified in section 4.2.3.4 of this appendix with the understanding that $\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$ correspond to full compressor speed operation and are derived from the results of the specified section 3.6.4 tests of this appendix.

4.2.5 Heat Pumps Having a Heat Comfort Controller

Heat pumps having heat comfort controllers, when set to maintain a typical minimum air delivery temperature, will cause the heat pump condenser to operate less because of a greater contribution from the resistive elements. With a conventional heat pump, resistive heating is only initiated if the heat pump condenser cannot meet the

building load (*i.e.*, is delayed until a second stage call from the indoor thermostat). With a heat comfort controller, resistive heating can occur even though the heat pump condenser has adequate capacity to meet the building load (*i.e.*, both on during a first stage call from the indoor thermostat). As a result, the outdoor temperature where the heat pump compressor no longer cycles (*i.e.*, starts to run continuously), will be lower than if the heat pump did not have the heat comfort controller.

4.2.5.1 Blower coil system heat pump having a heat comfort controller: Additional steps for calculating the HSPF of a heat pump having a single-speed compressor and either

a fixed-speed indoor blower or a constant-air-volume-rate indoor blower installed, or a coil-only system heat pump.

Calculate the space heating capacity and electrical power of the heat pump without the heat comfort controller being active as specified in section 4.2.1 of this appendix (Equations 4.2.1-4 and 4.2.1-5) for each outdoor bin temperature, T_j , that is listed in Table 19. Denote these capacities and electrical powers by using the subscript "hp" instead of "h." Calculate the mass flow rate (expressed in pounds-mass of dry air per hour) and the specific heat of the indoor air (expressed in Btu/lbm_{da} · °F) from the results of the H1 test using:

$$\dot{m}_{da} = \bar{V}_s * 0.075 \frac{lbm_{da}}{ft^3} * \frac{60_{min}}{hr} = \frac{\bar{V}_{mx}}{v'_n * [1 + W_n]} * \frac{60_{min}}{hr} = \frac{\bar{V}_{mx}}{v_n} * \frac{60_{min}}{hr}$$

where \bar{V}_s , \bar{V}_{mx} , v'_n (or v_n), and W_n are defined following Equation 3-1. For each outdoor bin temperature listed in Table 19, calculate the

nominal temperature of the air leaving the heat pump condenser coil using,

$$T_o(T_j) = 70^\circ\text{F} + \frac{\dot{Q}_{hp}(T_j)}{\dot{m}_{da} * C_{p,da}}$$

Evaluate $e_h(T_j)/N$, $RH(T_j)/N$, $X(T_j)$, PLF_j , and $\delta(T_j)$ as specified in section 4.2.1 of this appendix. For each bin calculation, use the space heating capacity and electrical power from Case 1 or Case 2, whichever applies.

Case 1. For outdoor bin temperatures where $T_o(T_j)$ is equal to or greater than T_{cc} (the maximum supply temperature

determined according to section 3.1.9 of this appendix), determine $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ as specified in section 4.2.1 of this appendix (i.e., $\dot{Q}_h(T_j) = \dot{Q}_{hp}(T_j)$ and $\dot{E}_h(T_j) = \dot{E}_{hp}(T_j)$).

Note: Even though $T_o(T_j) \geq T_{cc}$, resistive heating may be required; evaluate Equation 4.2.1–2 for all bins.

Case 2. For outdoor bin temperatures where $T_o(T_j) > T_{cc}$, determine $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ using $\dot{Q}_h(T_j) = \dot{Q}_{hp}(T_j) + \dot{Q}_{cc}(T_j)$ $\dot{E}_h(T_j) = \dot{E}_{hp}(T_j) + \dot{E}_{cc}(T_j)$ where:

$$\dot{Q}_{cc}(T_j) = \dot{m}_{da} * C_{p,da} * [T_{cc} - T_o(T_j)] \quad \dot{E}_{cc}(T_j) = \frac{\dot{Q}_{cc}(T_j)}{3.413 \frac{\text{Btu/h}}{\text{W}}}$$

Note: Even though $T_o(T_j) < T_{cc}$, additional resistive heating may be required; evaluate Equation 4.2.1–2 for all bins.

4.2.5.2 Heat pump having a heat comfort controller: Additional steps for calculating the HSPF of a heat pump having a single-speed compressor and a variable-speed, variable-air-volume indoor blower.

Calculate the space heating capacity and electrical power of the heat pump without the heat comfort controller being active as specified in section 4.2.2 of this appendix (Equations 4.2.2–1 and 4.2.2–2) for each outdoor bin temperature, T_j , that is listed in Table 19. Denote these capacities and electrical powers by using the subscript “hp”

instead of “h.” Calculate the mass flow rate (expressed in pounds-mass of dry air per hour) and the specific heat of the indoor air (expressed in Btu/lbm_{da} · °F) from the results of the H1₂ test using:

$$\dot{m}_{da} = \bar{V}_s * 0.075 \frac{\text{lbm}_{da}}{\text{ft}^3} * \frac{60 \text{ min}}{\text{hr}} = \frac{\bar{V}_{mx}}{v'_n * [1 + W_n]} * \frac{60 \text{ min}}{\text{hr}} = \frac{\bar{V}_{mx}}{v_n} * \frac{60 \text{ min}}{\text{hr}}$$

$$C_{p,da} = 0.24 + 0.444 * W_n$$

where \bar{V}_s , \bar{V}_{mx} , v'_n (or v_n), and W_n are defined following Equation 3–1. For each outdoor bin temperature listed in Table 19, calculate the

nominal temperature of the air leaving the heat pump condenser coil using,

$$T_o(T_j) = 70^\circ\text{F} + \frac{\dot{Q}_{hp}(T_j)}{\dot{m}_{da} * C_{p,da}}$$

Evaluate $e_h(T_j)/N$, $RH(T_j)/N$, $X(T_j)$, PLF_j , and $\delta(T_j)$ as specified in section 4.2.1 of this appendix with the exception of replacing references to the H1C test and section 3.6.1 of this appendix with the H1C₁ test and section 3.6.2 of this appendix. For each bin calculation, use the space heating capacity and electrical power from Case 1 or Case 2, whichever applies.

Case 1. For outdoor bin temperatures where $T_o(T_j)$ is equal to or greater than T_{cc} (the maximum supply temperature determined according to section 3.1.9 of this appendix), determine $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ as specified in section 4.2.2 of this appendix (i.e., $\dot{Q}_h(T_j) = \dot{Q}_{hp}(T_j)$ and $\dot{E}_h(T_j) = \dot{E}_{hp}(T_j)$).

Note: Even though $T_o(T_j) \geq T_{cc}$, resistive heating may be required; evaluate Equation 4.2.1–2 for all bins.

Case 2. For outdoor bin temperatures where $T_o(T_j) < T_{cc}$, determine $\dot{Q}_h(T_j)$ and $\dot{E}_h(T_j)$ using $\dot{Q}_h(T_j) = \dot{Q}_{hp}(T_j) + \dot{Q}_{cc}(T_j)$ $\dot{E}_h(T_j) = \dot{E}_{hp}(T_j) + \dot{E}_{cc}(T_j)$

$$\dot{Q}_{cc}(T_j) = \dot{m}_{da} * C_{p,da} * [T_{cc} - T_o(T_j)] \quad \dot{E}_{cc}(T_j) = \frac{\dot{Q}_{cc}(T_j)}{3.413 \frac{\text{Btu/h}}{\text{W}}}$$

Note: Even though $T_o(T_j) < T_{cc}$, additional resistive heating may be required; evaluate Equation 4.2.1–2 for all bins.

4.2.5.3 Heat pumps having a heat comfort controller: Additional steps for calculating the HSPF of a heat pump having a two-capacity compressor.

Calculate the space heating capacity and electrical power of the heat pump without the heat comfort controller being active as specified in section 4.2.3 of this appendix for both high and low capacity and at each outdoor bin temperature, T_j , that is listed in Table 19. Denote these capacities and

electrical powers by using the subscript “hp” instead of “h.” For the low capacity case, calculate the mass flow rate (expressed in pounds-mass of dry air per hour) and the specific heat of the indoor air (expressed in Btu/lbm_{da} · °F) from the results of the H1₁ test using:

$$\dot{m}_{da}^{k=1} = \bar{V}_s * 0.075 \frac{lbm_{da}}{ft^3} * \frac{60min}{hr} = \frac{\bar{V}_{mx}}{v'_n * [1 + W_n]} * \frac{60min}{hr} = \frac{\bar{V}_{mx}}{v_n} * \frac{60min}{hr}$$

$$C_{p,da}^{k=1} = 0.24 + 0.444 * W_n$$

where \bar{V}_s , \bar{V}_{mx} , v'_n (or v_n), and W_n are defined following Equation 3-1. For each outdoor bin

temperature listed in Table 19, calculate the nominal temperature of the air leaving the

heat pump condenser coil when operating at low capacity using,

$$T_0^{k=1}(T_j) = 70^\circ F + \frac{\dot{Q}_{hp}^{k=1}(T_j)}{\dot{m}_{da}^{k=1} * C_{p,da}^{k=1}}$$

Repeat the above calculations to determine the mass flow rate ($\dot{m}_{da}^{k=2}$) and the specific heat of the indoor air ($C_{p,da}^{k=2}$) when

operating at high capacity by using the results of the H1₂ test. For each outdoor bin temperature listed in Table 19, calculate the

nominal temperature of the air leaving the heat pump condenser coil when operating at high capacity using,

$$T_0^{k=2}(T_j) = 70^\circ F + \frac{\dot{Q}_{hp}^{k=2}(T_j)}{\dot{m}_{da}^{k=2} * C_{p,da}^{k=2}}$$

Evaluate $e_h(T_j)/N$, $RH(T_j)/N$, $X^{k=1}(T_j)$, and/or $X^{k=2}(T_j)$, PLF_j , and $\delta'(T_j)$ or $\delta''(T_j)$ as specified in section 4.2.3.1, 4.2.3.2, 4.2.3.3, or 4.2.3.4 of this appendix, whichever applies, for each temperature bin. To evaluate these quantities, use the low-capacity space heating capacity and the low-capacity electrical power from Case 1 or Case 2, whichever applies; use the high-capacity space heating capacity and the high-capacity

electrical power from Case 3 or Case 4, whichever applies.
 Case 1. For outdoor bin temperatures where $T_o^{k=1}(T_j)$ is equal to or greater than T_{CC} (the maximum supply temperature determined according to section 3.1.9 of this appendix), determine $\dot{Q}_h^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j)$ as specified in section 4.2.3 of this appendix (i.e., $\dot{Q}_h^{k=1}(T_j) = \dot{Q}_{hp}^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j) = \dot{E}_{hp}^{k=1}(T_j)$).

Note: Even though $T_o^{k=1}(T_j) \geq T_{CC}$, resistive heating may be required; evaluate $RH(T_j)/N$ for all bins.
 Case 2. For outdoor bin temperatures where $T_o^{k=1}(T_j) < T_{CC}$, determine $\dot{Q}_h^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j)$ using $\dot{Q}_h^{k=1}(T_j) = \dot{Q}_{hp}^{k=1}(T_j) + \dot{Q}_{CC}^{k=1}(T_j)$ $\dot{E}_h^{k=1}(T_j) = \dot{E}_{hp}^{k=1}(T_j) + \dot{E}_{CC}^{k=1}(T_j)$ where,

$$\dot{Q}_{CC}(T_j) = \dot{m}_{da} * C_{p,da} * [T_{CC} - T_0(T_j)] \quad \dot{E}_{CC}(T_j) = \frac{\dot{Q}_{CC}(T_j)}{3.413 \frac{Btu/h}{W}}$$

Note: Even though $T_o^{k=1}(T_j) \geq T_{CC}$, additional resistive heating may be required; evaluate $RH(T_j)/N$ for all bins.
 Case 3. For outdoor bin temperatures where $T_o^{k=2}(T_j)$ is equal to or greater than T_{CC} , determine $\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$ as

specified in section 4.2.3 of this appendix (i.e., $\dot{Q}_h^{k=2}(T_j) = \dot{Q}_{hp}^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j) = \dot{E}_{hp}^{k=2}(T_j)$).
Note: Even though $T_o^{k=2}(T_j) < T_{CC}$, resistive heating may be required; evaluate $RH(T_j)/N$ for all bins.

Case 4. For outdoor bin temperatures where $T_o^{k=2}(T_j) < T_{CC}$, determine $\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$ using $\dot{Q}_h^{k=2}(T_j) = \dot{Q}_{hp}^{k=2}(T_j) + \dot{Q}_{CC}^{k=2}(T_j)$ $\dot{E}_h^{k=2}(T_j) = \dot{E}_{hp}^{k=2}(T_j) + \dot{E}_{CC}^{k=2}(T_j)$ where,

$$\dot{Q}_{CC}^{k=2}(T_j) = \dot{m}_{da}^{k=2} * C_{p,da}^{k=2} * [T_{CC} - T_0^{k=2}(T_j)] \quad \dot{E}_{CC}^{k=2}(T_j) = \frac{\dot{Q}_{CC}^{k=2}(T_j)}{3.413 \frac{Btu/h}{W}}$$

Note: Even though $T_o^{k=2}(T_j) < T_{CC}$, additional resistive heating may be required; evaluate $RH(T_j)/N$ for all bins.
 4.2.5.4 Heat pumps having a heat comfort controller: Additional steps for calculating

the HSPF of a heat pump having a variable-speed compressor. [Reserved]
 4.2.6 Additional steps for calculating the HSPF of a heat pump having a triple-capacity compressor.

The only triple-capacity heat pumps covered are triple-capacity, northern heat pumps. For such heat pumps, the calculation of the Eq. 4.2-1 quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

differ depending on whether the heat pump would cycle on and off at low capacity (section 4.2.6.1 of this appendix), cycle on and off at high capacity (section 4.2.6.2 of this appendix), cycle on and off at booster

capacity (section 4.2.6.3 of this appendix), cycle between low and high capacity (section 4.2.6.4 of this appendix), cycle between high and booster capacity (section 4.2.6.5 of this appendix), operate continuously at low

capacity (4.2.6.6 of this appendix), operate continuously at high capacity (section 4.2.6.7 of this appendix), operate continuously at booster capacity (section 4.2.6.8 of this appendix), or heat solely using resistive

heating (also section 4.2.6.8 of this appendix) in responding to the building load. As applicable, the manufacturer must supply information regarding the outdoor temperature range at which each stage of compressor capacity is active. As an informative example, data may be submitted in this manner: At the low ($k = 1$) compressor capacity, the outdoor temperature range of operation is $40\text{ °F} \leq T \leq 65\text{ °F}$; At the high ($k = 2$) compressor capacity, the outdoor temperature range of operation is $20\text{ °F} \leq T \leq 50\text{ °F}$; At the booster ($k = 3$) compressor capacity, the outdoor temperature range of operation is $-20\text{ °F} \leq T \leq 30\text{ °F}$.

a. Evaluate the space heating capacity and electrical power consumption of the heat pump when operating at low compressor

capacity and outdoor temperature T_j using the equations given in section 4.2.3 of this appendix for $\dot{Q}_h^{k=1}(T_j)$ and $\dot{E}_h^{k=1}(T_j)$. In evaluating the section 4.2.3 equations, Determine $\dot{Q}_h^{k=1}(62)$ and $\dot{E}_h^{k=1}(62)$ from the H0₁ test, $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ from the H1₁ test, and $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the H1₂ test. Calculate all four quantities as specified in section 3.7 of this appendix. If, in accordance with section 3.6.6 of this appendix, the H3₁ test is conducted, calculate $\dot{Q}_h^{k=1}(17)$ and $\dot{E}_h^{k=1}(17)$ as specified in section 3.10 of this appendix and determine $\dot{Q}_h^{k=1}(35)$ and $\dot{E}_h^{k=1}(35)$ as specified in section 3.6.6 of this appendix.

b. Evaluate the space heating capacity and electrical power consumption ($\dot{Q}_h^{k=2}(T_j)$ and $\dot{E}_h^{k=2}(T_j)$) of the heat pump when operating

at high compressor capacity and outdoor temperature T_j by solving Equations 4.2.2–3 and 4.2.2–4, respectively, for $k = 2$. Determine $\dot{Q}_h^{k=1}(62)$ and $\dot{E}_h^{k=1}(62)$ from the H0₁ test, $\dot{Q}_h^{k=1}(47)$ and $\dot{E}_h^{k=1}(47)$ from the H1₁ test, and $\dot{Q}_h^{k=2}(47)$ and $\dot{E}_h^{k=2}(47)$ from the H1₂ test, evaluated as specified in section 3.7 of this appendix. Determine the equation input for $\dot{Q}_h^{k=2}(35)$ and $\dot{E}_h^{k=2}(35)$ from the H2₂ test, evaluated as specified in section 3.9.1 of this appendix. Also, determine $\dot{Q}_h^{k=2}(17)$ and $\dot{E}_h^{k=2}(17)$ from the H3₂ test, evaluated as specified in section 3.10 of this appendix.

c. Evaluate the space heating capacity and electrical power consumption of the heat pump when operating at booster compressor capacity and outdoor temperature T_j using

$$\dot{Q}_h^{k=3}(T_j) = \begin{cases} \dot{Q}_h^{k=3}(17) + \frac{[\dot{Q}_h^{k=3}(35) - \dot{Q}_h^{k=3}(17)] * (T_j - 17)}{35 - 17}, & \text{if } 17\text{ °F} < T_j \leq 45\text{ °F} \\ \dot{Q}_h^{k=3}(2) + \frac{[\dot{Q}_h^{k=3}(17) - \dot{Q}_h^{k=3}(2)] * (T_j - 2)}{17 - 2}, & \text{if } T_j \leq 17\text{ °F} \end{cases}$$

$$\dot{E}_h^{k=3}(T_j) = \begin{cases} \dot{E}_h^{k=3}(17) + \frac{[\dot{E}_h^{k=3}(35) - \dot{E}_h^{k=3}(17)] * (T_j - 17)}{35 - 17}, & \text{if } 17\text{ °F} < T_j \leq 45\text{ °F} \\ \dot{E}_h^{k=3}(2) + \frac{[\dot{E}_h^{k=3}(17) - \dot{E}_h^{k=3}(2)] * (T_j - 2)}{17 - 2}, & \text{if } T_j \leq 17\text{ °F} \end{cases}$$

Determine $\dot{Q}_h^{k=3}(17)$ and $\dot{E}_h^{k=3}(17)$ from the H3₃ test and determine $\dot{Q}_h^{k=2}(2)$ and $\dot{E}_h^{k=3}(2)$ from the H4₃ test. Calculate all four quantities as specified in section 3.10 of this appendix. Determine the equation input for

$\dot{Q}_h^{k=3}(35)$ and $\dot{E}_h^{k=3}(35)$ as specified in section 3.6.6 of this appendix.

4.2.6.1 Steady-state space heating capacity when operating at low compressor capacity is greater than or equal to the building

heating load at temperature T_j , $\dot{Q}_h^{k=1}(T_j) \geq BL(T_j)$, and the heat pump permits low compressor capacity at T_j .

Evaluate the quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

using Eqs. 4.2.3–1 and 4.2.3–2, respectively. Determine the equation inputs $X^{k=1}(T_j)$, PLF_j , and $\delta'(T_j)$ as specified in section 4.2.3.1 of this appendix. In calculating the part load factor, PLF_j , use the low-capacity cyclic-

degradation coefficient C_{D^h} , [or equivalently, $C_{D^h}(k = 1)$] determined in accordance with section 3.6.6 of this appendix.

4.2.6.2 Heat pump only operates at high ($k = 2$) compressor capacity at temperature T_j

and its capacity is greater than or equal to the building heating load, $BL(T_j) < \dot{Q}_h^{k=2}(T_j)$.

Evaluate the quantities

$$\frac{RH(T_j)}{N} \quad \text{and} \quad \frac{e_h(T_j)}{N}$$

as specified in section 4.2.3.3 of this appendix. Determine the equation inputs $X^{k=2}(T_j)$, PLF_j , and $\delta'(T_j)$ as specified in section 4.2.3.3 of this appendix. In

calculating the part load factor, PLF_j , use the high-capacity cyclic-degradation coefficient, $C_{D^h}(k = 2)$ determined in accordance with section 3.6.6 of this appendix.

4.2.6.3 Heat pump only operates at high ($k = 3$) compressor capacity at temperature T_j and its capacity is greater than or equal to the building heating load, $BL(T_j) \leq \dot{Q}_h^{k=3}(T_j)$.

Calculate $\frac{RH(T_j)}{N}$ and using Eq. 4.2.3-2. Evaluate $\frac{e_h(T_j)}{N}$ using

$$\frac{e_h(T_j)}{N} = \frac{X^{k=3}(T_j) * \dot{E}_h^{k=3}(T_j) * \delta'(T_j)}{PLF_j} * \frac{n_j}{N}$$

where

$$X^{k=3}(T_j) = BL(T_j) / \dot{Q}_h^{k=3}(T_j) \text{ and } PLF_j = 1 - C_D^h(k=3) * [1 - X^{k=3}(T_j)]$$

Determine the low temperature cut-out factor, $\delta'(T_j)$, using Eq. 4.2.3-3. Use the

booster-capacity cyclic-degradation coefficient, $C_D^h(k=3)$ determined in accordance with section 3.6.6 of this appendix.

4.2.6.4 Heat pump alternates between high ($k=2$) and low ($k=1$) compressor capacity to satisfy the building heating load at a temperature T_j , $\dot{Q}_h^{k=1}(T_j) < BL(T_j) < \dot{Q}_h^{k=2}(T_j)$. Evaluate the quantities

$$\frac{RH(T_j)}{N} \text{ and } \frac{e_h(T_j)}{N}$$

as specified in section 4.2.3.2 of this appendix. Determine the equation inputs $X^{k=1}(T_j)$, $X^{k=2}(T_j)$, and $\delta'(T_j)$ as specified in section 4.2.3.2 of this appendix.

4.2.6.5 Heat pump alternates between high ($k=2$) and booster ($k=3$) compressor capacity to satisfy the building heating load

at a temperature T_j , $\dot{Q}_h^{k=2}(T_j) < BL(T_j) < \dot{Q}_h^{k=3}(T_j)$.

Calculate $\frac{RH(T_j)}{N}$ and using Eq. 4.2.3-2. Evaluate $\frac{e_h(T_j)}{N}$ using

$$\frac{e_h(T_j)}{N} = [X^{k=2}(T_j) * \dot{E}_h^{k=2}(T_j) + X^{k=3}(T_j) * \dot{E}_h^{k=3}(T_j)] * \delta'(T_j) * \frac{n_j}{N}$$

where:

$$X^{k=2}(T_j) = \frac{\dot{Q}_h^{k=3}(T_j) - BL(T_j)}{\dot{Q}_h^{k=3}(T_j) - \dot{Q}_h^{k=2}(T_j)}$$

and $X^{k=3}(T_j) = X^{k=2}(T_j) =$ the heating mode, booster capacity load factor for temperature bin j , dimensionless. Determine the low

temperature cut-out factor, $\delta'(T_j)$, using Eq. 4.2.3-3.

4.2.6.6 Heat pump only operates at low ($k=1$) capacity at temperature T_j and its capacity is less than the building heating load, $BL(T_j) > \dot{Q}_h^{k=1}(T_j)$.

$$\frac{e_h(T_j)}{N} = \dot{E}_h^{k=1}(T_j) * \delta'(T_j) * \frac{n_j}{N} \text{ and } \frac{RH(T_j)}{N} = \frac{BL(T_j) - [\dot{Q}_h^{k=1}(T_j) * \delta'(T_j)]}{3.413 \frac{Btu/h}{W}} * \frac{n_j}{N}$$

where the low temperature cut-out factor, $\delta'(T_j)$, is calculated using Eq. 4.2.3-3.

4.2.6.7 Heat pump only operates at high ($k=2$) capacity at temperature T_j and its

capacity is less than the building heating load, $BL(T_j) > \dot{Q}_h^{k=2}(T_j)$. Evaluate the quantities

$$\frac{RH(T_j)}{N} \text{ and } \frac{e_h(T_j)}{N}$$

as specified in section 4.2.3.4 of this appendix. Calculate $\delta'(T_j)$ using the equation given in section 4.2.3.4 of this appendix.

4.2.6.8 Heat pump only operates at booster ($k=3$) capacity at temperature T_j and its capacity is less than the building heating

load, $BL(T_j) > \dot{Q}_h^{k=3}(T_j)$ or the system converts to using only resistive heating.

$$\frac{e_h(T_j)}{N} = \dot{E}_h^{k=1}(T_j) * \delta'(T_j) * \frac{n_j}{N} \text{ and } \frac{RH(T_j)}{N} = \frac{BL(T_j) - [\dot{Q}_h^{k=1}(T_j) * \delta'(T_j)]}{3.413 \frac{Btu/h}{W}} * \frac{n_j}{N}$$

where $\delta'(T_j)$ is calculated as specified in section 4.2.3.4 of this appendix if the heat pump is operating at its booster compressor capacity. If the heat pump system converts to

using only resistive heating at outdoor temperature T_j , set $\delta'(T_j)$ equal to zero.

4.2.7 Additional steps for calculating the HSPF of a heat pump having a single indoor unit with multiple indoor blowers. The

calculation of the Eq. 4.2-1 quantities $e_h(T_j)/N$ and $RH(T_j)/N$ are evaluated as specified in the applicable subsection.

4.2.7.1 For multiple indoor blower heat pumps that are connected to a singular, single-speed outdoor unit:

a. Calculate the space heating capacity, $\dot{Q}_{h,k=1}(T_j)$, and electrical power consumption, $\dot{E}_{h,k=1}(T_j)$, of the heat pump when operating at the heating minimum air volume rate and outdoor temperature T_j using Eqs. 4.2.2–3 and 4.2.2–4, respectively. Use these same equations to calculate the space heating capacity, $\dot{Q}_{h,k=2}(T_j)$ and electrical power consumption, $\dot{E}_{h,k=2}(T_j)$, of the test unit when operating at the heating full-load air volume rate and outdoor temperature T_j . In evaluating Eqs. 4.2.2–3 and 4.2.2–4, determine the quantities $\dot{Q}_{h,k=1}(47)$ and $\dot{E}_{h,k=1}(47)$ from the H1₁ test; determine $\dot{Q}_{h,k=2}(47)$ and $\dot{E}_{h,k=2}(47)$ from the H1₂ test. Evaluate all four quantities according to section 3.7 of this appendix. Determine the

quantities $\dot{Q}_{h,k=1}(35)$ and $\dot{E}_{h,k=1}(35)$ as specified in section 3.6.2 of this appendix. Determine $\dot{Q}_{h,k=2}(35)$ and $\dot{E}_{h,k=2}(35)$ from the H2₂ frost accumulation test as calculated according to section 3.9.1 of this appendix. Determine the quantities $\dot{Q}_{h,k=1}(17)$ and $\dot{E}_{h,k=1}(17)$ from the H3₁ test, and $\dot{Q}_{h,k=2}(17)$ and $\dot{E}_{h,k=2}(17)$ from the H3₂ test. Evaluate all four quantities according to section 3.10 of this appendix. Refer to section 3.6.2 and Table 11 of this appendix for additional information on the referenced laboratory tests.

b. Determine the heating mode cyclic degradation coefficient, CD_h , as per sections 3.6.2 and 3.8 to 3.8.1 of this appendix. Assign this same value to $CD_h(k=2)$.

c. Except for using the above values of $\dot{Q}_{h,k=1}(T_j)$, $\dot{E}_{h,k=1}(T_j)$, $\dot{Q}_{h,k=2}(T_j)$, $\dot{E}_{h,k=2}(T_j)$, CD_h , and $CD_h(k=2)$, calculate the quantities $e_h(T_j)/N$ as specified in section 4.2.3.1 of this appendix for cases where $\dot{Q}_{h,k=1}(T_j) \geq BL(T_j)$.

For all other outdoor bin temperatures, T_j , calculate $e_h(T_j)/N$ and $RH_h(T_j)/N$ as specified in section 4.2.3.3 of this appendix if $\dot{Q}_{h,k=2}(T_j) > BL(T_j)$ or as specified in section 4.2.3.4 of this appendix if $\dot{Q}_{h,k=2}(T_j) \leq BL(T_j)$.

4.2.7.2 For multiple indoor blower heat pumps connected to either a single outdoor unit with a two-capacity compressor or to two separate single-speed outdoor units of identical model, calculate the quantities $e_h(T_j)/N$ and $RH_h(T_j)/N$ as specified in section 4.2.3 of this appendix.

4.3 Calculations of Off-Mode Power Consumption

For central air conditioners and heat pumps with a cooling capacity of: Less than 36,000 Btu/h, determine the off mode represented value, $P_{W,OFF}$, with the following equation:

$$P_{W,OFF} = \frac{P1 + P2}{2};$$

greater than or equal to 36,000 Btu/h, calculate the capacity scaling factor according to:

$$F_{scale} = \frac{\dot{Q}_C(95)}{36,000},$$

where $\dot{Q}_C(95)$ is the total cooling capacity at the A or A₂ test condition, and determine the

off mode represented value, $P_{W,OFF}$, with the following equation:

$$P_{W,OFF} = \frac{P1 + P2}{2 \times F_{scale}};$$

4.4 Rounding of SEER and HSPF for Reporting Purposes

After calculating SEER according to section 4.1 of this appendix and HSPF according to

section 4.2 of this appendix round the values off as specified per § 430.23(m) of title 10 of the Code of Federal Regulations.




Figure 1—Heating Load Hours (HLH_A) for the United States




Figure 2—Cooling Load Hours (CLH_A) for the United States

TABLE 21—REPRESENTATIVE COOLING AND HEATING LOAD HOURS FOR EACH GENERALIZED CLIMATIC REGION

TABLE 21—REPRESENTATIVE COOLING AND HEATING LOAD HOURS FOR EACH GENERALIZED CLIMATIC REGION—Continued

TABLE 21—REPRESENTATIVE COOLING AND HEATING LOAD HOURS FOR EACH GENERALIZED CLIMATIC REGION—Continued

Climatic region	Cooling load hours CLH _R	Heating load hours HLH _R	Climatic region	Cooling load hours CLH _R	Heating load hours HLH _R	Climatic region	Cooling load hours CLH _R	Heating load hours HLH _R
I	2,400	750	II	1,800	1,250	III	1,200	1,750

TABLE 21—REPRESENTATIVE COOLING AND HEATING LOAD HOURS FOR EACH GENERALIZED CLIMATIC REGION—Continued

Climatic region	Cooling load hours CLH _R	Heating load hours HLH _R
IV	800	2,250
Rating Values	1,000	2,080

TABLE 21—REPRESENTATIVE COOLING AND HEATING LOAD HOURS FOR EACH GENERALIZED CLIMATIC REGION—Continued

Climatic region	Cooling load hours CLH _R	Heating load hours HLH _R
V	400	2,750
VI	200	2,750

4.5 Calculations of the SHR, which should be computed for different equipment configurations and test conditions specified in Table 22.

TABLE 22—APPLICABLE TEST CONDITIONS FOR CALCULATION OF THE SENSIBLE HEAT RATIO

Equipment configuration	Reference table No. of Appendix M	SHR computation with results from	Computed values
Units Having a Single-Speed Compressor and a Fixed-Speed Indoor blower, a Constant Air Volume Rate Indoor blower, or No Indoor blower.	4	B Test	SHR(B)
Units Having a Single-Speed Compressor That Meet the section 3.2.2.1 Indoor Unit Requirements.	5	B2 and B1 Tests	SHR(B1), SHR(B2)
Units Having a Two-Capacity Compressor	6	B2 and B1 Tests	SHR(B1), SHR(B2)
Units Having a Variable-Speed Compressor	7	B2 and B1 Tests	SHR(B1), SHR(B2)

The SHR is defined and calculated as follows:

$$SHR = \frac{\text{Sensible Cooling Capacity}}{\text{Total Cooling Capacity}}$$

$$= \frac{\dot{Q}_{sc}^k(T)}{\dot{Q}_c^k(T)}$$

Where both the total and sensible cooling capacities are determined from the same cooling mode test and calculated from data

collected over the same 30-minute data collection interval.

4.6 Calculations of the Energy Efficiency Ratio (EER). Calculate the energy efficiency ratio using,

$$EER = \frac{\text{Total Cooling Capacity}}{\text{Total Electrical Power Consumption}}$$

$$= \frac{\dot{Q}_c^k(T)}{\dot{E}_c^k(T)}$$

where $\dot{Q}_c^k(T)$ and $\dot{E}_c^k(T)$ are the space cooling capacity and electrical power consumption

determined from the 30-minute data collection interval of the same steady-state

wet coil cooling mode test and calculated as specified in section 3.3 of this appendix. Add the letter identification for each steady-state test as a subscript (e.g., EER_{A2}) to differentiate among the resulting EER values.

[FR Doc. 2016-12592 Filed 6-7-16; 8:45 am]

BILLING CODE 6450-01-P