

generator units located on the bank next to the Corps' existing spillway; (5) a tailrace; and (6) a 15-mile-long, 24.5 kV transmission line interconnecting to the Central Electric Cooperative facilities. The Bowman Dam Project would have an average annual generation of 17.6 MWh.

*Applicant Contact:* Mr. Russell Rhoden, Manager, Ochoco Irrigation District, 1001 NW. Deer Street, Prineville, OR 97754. (541) 447-6449.

*FERC Contact:* Kim Nguyen, [kim.nguyen@ferc.gov](mailto:kim.nguyen@ferc.gov), (202) 502-6105.

Deadline for filing comments, motions to intervene, competing applications (without notices of intent), or notices of intent to file competing applications: 60 Days from the issuance of this notice. Competing applications and notices of intent must meet the requirements of 18 CFR 4.36.

The Commission strongly encourages electronic filing. Please file comments, motions to intervene, notices of intent, and competing applications using the Commission's eFiling system at <http://www.ferc.gov/docs-filing/efiling.asp>. Commenters can submit brief comments up to 6,000 characters, without prior registration, using the eComment system at <http://www.ferc.gov/docs-filing/ecomment.asp>. You must include your name and contact information at the end of your comments. For assistance, please contact FERC Online Support at [FERCOnlineSupport@ferc.gov](mailto:FERCOnlineSupport@ferc.gov), (866) 208-3676 (toll free), or (202) 502-8659 (TTY). In lieu of electronic filing, please send a paper copy to: Secretary, Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426. The first page of any filing should include docket number P-14453-001 and P-14791-000.

More information about this project, including a copy of the application, can be viewed or printed on the "eLibrary" link of the Commission's Web site at <http://www.ferc.gov/docs-filing/elibrary.asp>. Enter the docket number (P-14453-001, or P-14791-000) in the docket number field to access the document. For assistance, contact FERC Online Support.

Dated: September 2, 2016.

**Kimberly D. Bose,**  
*Secretary.*

[FR Doc. 2016-21747 Filed 9-8-16; 8:45 am]

BILLING CODE 6717-01-P

## DEPARTMENT OF ENERGY

### Federal Energy Regulatory Commission

[Docket No. ER16-2520-000]

#### Grand View PV Solar Two LLC; Supplemental Notice That Initial Market-Based Rate Filing Includes Request for Blanket Section 204 Authorization

This is a supplemental notice in the above-referenced proceeding of Grand View PV Solar Two LLC's application for market-based rate authority, with an accompanying rate tariff, noting that such application includes a request for blanket authorization, under 18 CFR part 34, of future issuances of securities and assumptions of liability.

Any person desiring to intervene or to protest should file with the Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426, in accordance with Rules 211 and 214 of the Commission's Rules of Practice and Procedure (18 CFR 385.211 and 385.214). Anyone filing a motion to intervene or protest must serve a copy of that document on the Applicant.

Notice is hereby given that the deadline for filing protests with regard to the applicant's request for blanket authorization, under 18 CFR part 34, of future issuances of securities and assumptions of liability, is September 21, 2016.

The Commission encourages electronic submission of protests and interventions in lieu of paper, using the FERC Online links at <http://www.ferc.gov>. To facilitate electronic service, persons with Internet access who will eFile a document and/or be listed as a contact for an intervenor must create and validate an eRegistration account using the eRegistration link. Select the eFiling link to log on and submit the intervention or protests.

Persons unable to file electronically should submit an original and 5 copies of the intervention or protest to the Federal Energy Regulatory Commission, 888 First Street NE., Washington, DC 20426.

The filings in the above-referenced proceeding are accessible in the Commission's eLibrary system by clicking on the appropriate link in the above list. They are also available for electronic review in the Commission's Public Reference Room in Washington, DC. There is an eSubscription link on the Web site that enables subscribers to receive email notification when a document is added to a subscribed docket(s). For assistance with any FERC

Online service, please email [FERCOnlineSupport@ferc.gov](mailto:FERCOnlineSupport@ferc.gov). or call (866) 208-3676 (toll free). For TTY, call (202) 502-8659.

Dated: September 1, 2016.

**Nathaniel J. Davis, Sr.,**  
*Deputy Secretary.*

[FR Doc. 2016-21684 Filed 9-8-16; 8:45 am]

BILLING CODE 6717-01-P

## DEPARTMENT OF ENERGY

### Federal Energy Regulatory Commission

[Project No. 4285-046]

#### The City of Logan, Utah; Notice of Availability of Environmental Assessment

In accordance with the National Environmental Policy Act of 1969, as amended, and the Federal Energy Regulatory Commission's regulations (18 CFR part 380), Commission staff has reviewed the application for non-capacity amendment of license, filed May 8, 2015, to replace or rehabilitate several portions of the Third Dam facilities that are part of the Logan No. 2 Project, which is located on the Logan River, near the City of Logan, in Cache County, Utah.

The project licensee, the City of Logan (City), is proposing to: (1) Replace the spillway crest gates with Obermeyer weirs; (2) replace spillway abutment walls; (3) armor the abutments of the dam, which may consist of a combination of riprap and/or roller compacted concrete; (4) replace the penstock isolation gate (radial gate) with an Obermeyer weir gate; (5) replace the trash rack at the intake structure; (6) replace the low level sluice gatehouse; (7) rehabilitate the upstream face of dam; (8) dredge about 100,000 cubic yards of sediment from the reservoir; (9) refurbish the electrical generating equipment, which includes replacing the existing runners, wicket gates, and associated parts that are damaged; (10) recoat the interior and exterior of the steel portion of the penstock to reduce corrosion potential; and (11) replace the roof and repair the walls of the existing surge tank.

An environmental assessment (EA) has been prepared as part of staff's review of the proposal. In the EA, Commission staff analyzed the probable environmental effects of the planned work and concluded that approval of the work, with appropriate environmental measures, would not constitute a major federal action