

select “*Begin Web-based ADAMS Search.*” For problems with ADAMS, please contact the NRC’s Public Document Room (PDR) reference staff at 1–800–397–4209, 301–415–4737, or by email to pdr.resource@nrc.gov. The ADAMS accession number for each document referenced (if it is available in ADAMS) is provided the first time that it is mentioned in this document. The entire NuScale application is available in ADAMS under Accession No. ML17013A229.

• **NRC’s PDR:** You may examine and purchase copies of public documents at the NRC’s PDR, Room O1–F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

FOR FURTHER INFORMATION CONTACT: Bruce Bavol, Office of New Reactors, U.S. Nuclear Regulatory Commission, Washington, DC 20555–0001; telephone: 301–415–6715, email: Bruce.Bavol@nrc.gov.

SUPPLEMENTARY INFORMATION: By letter dated December 31, 2016, NuScale filed an application for a design certification of the NuScale SMR with the NRC, pursuant to Section 103 of the Atomic Energy Act of 1954, as amended, and part 52 of title 10 of the *Code of Federal Regulations* (10 CFR), “Licenses, Certifications, and Approvals for Nuclear Power Plants.” A notice of receipt and availability of this application was previously published in the **Federal Register** on February 22, 2017 (82 FR 11372).

The NRC staff has determined that NuScale has submitted information in accordance with 10 CFR part 2, “Rules of Practice for Domestic Licensing Proceedings and Issuance of Orders,” and 10 CFR part 52 that is acceptable for docketing. The docket number established for this application is 52–048.

The NRC staff will perform a detailed technical review of the design certification application. Docketing of the design certification application does not preclude the NRC from requesting additional information from the applicant as the review proceeds, nor does it predict whether the Commission will grant or deny the application. A notice relating to the rulemaking pursuant to 10 CFR 52.51 for design certification, including provisions for participation of the public and other parties, will be published in the future.

The NuScale SMR is a pressurized-water reactor (PWR). The design is based on the Multi-Application Small Light Water Reactor (MASLWR) developed at Oregon State University in the early 2000s. The NuScale SMR is a natural circulation light-water reactor

with the reactor core and helical coil steam generator located in a common reactor vessel in a cylindrical steel containment. The NuScale power module is immersed in water in a safety-related pool. The reactor pool is located below grade and is designed to hold up to 12 power modules. Each NuScale SMR has a rated thermal output of 160 megawatts thermal (MWT) and electrical output of 50 megawatts electric (MWE). Each plant can hold up to 12 modules yielding a total capacity of 600 MWE.

Dated at Rockville, Maryland, this 20th day of March, 2017.

For the Nuclear Regulatory Commission.
Frank Akstulewicz,
Director, Division of New Reactor Licensing,
Office of New Reactors.

[FR Doc. 2017–06309 Filed 3–29–17; 8:45 am]

BILLING CODE 7590–01–P

NUCLEAR REGULATORY COMMISSION

[NRC–2017–0001]

Sunshine Act Meeting Notice

DATE: Weeks of April 3, 10, 17, 24, May 1, 8, 2017.

PLACE: Commissioners’ Conference Room, 11555 Rockville Pike, Rockville, Maryland.

STATUS: Public and Closed.

Week of April 3, 2017—Tentative

Tuesday, April 4, 2017

9:55 a.m. Affirmation Session (Public Meeting) (Tentative)

Tennessee Valley Authority (Browns Ferry Nuclear Plant Units 1, 2, and 3), Petitioner’s Appeal of LBP–16–11 (Tentative)

This meeting will be webcast live at the Web address—<http://www.nrc.gov/>.

10:00 a.m. Meeting with the Organization of Agreement States and the Conference of Radiation Control Program Directors (Public Meeting) (Contact: Paul Michalak: 301–415–5804)

This meeting will be webcast live at the Web address—<http://www.nrc.gov/>.

Thursday, April 6, 2017

10:00 a.m. Meeting with Advisory Committee on Reactor Safeguards (Public Meeting) (Contact: Mark Banks: 301–415–3718)

This meeting will be webcast live at the Web address—<http://www.nrc.gov/>.

Week of April 10, 2017—Tentative

There are no meetings scheduled for the week of April 10, 2017.

Week of April 17, 2017—Tentative

There are no meetings scheduled for the week of April 17, 2017.

Week of April 24, 2017—Tentative

Wednesday, April 26, 2017

9:00 a.m. Briefing on the Status of Subsequent License Renewal Preparations (Public Meeting) (Contact: Steven Bloom: 301–415–2431)

This meeting will be webcast live at the Web address—<http://www.nrc.gov/>.

Thursday, April 27, 2017

10:00 a.m. Meeting with the Advisory Committee on the Medical Uses of Isotopes (Public Meeting) (Contact: Douglas Bollock: 301–415–6609)

This meeting will be webcast live at the Web address—<http://www.nrc.gov/>.

Week of May 1, 2017—Tentative

There are no meetings scheduled for the week of May 1, 2017.

Week of May 8, 2017—Tentative

Tuesday, May 9, 2017

10:00 a.m. Briefing on Security Issues (Closed Ex. 1)

2:00 p.m. Briefing on Security Issues (Closed Ex. 1)

Thursday, May 11, 2017

9:00 a.m. Briefing on Risk-Informed Regulation (Public Meeting) (Contact: Steve Ruffin: 301–415–1985)

This meeting will be webcast live at the Web address—<http://www.nrc.gov/>.

* * * * *

The schedule for Commission meetings is subject to change on short notice. For more information or to verify the status of meetings, contact Denise McGovern at 301–415–0681 or via email at Denise.McGovern@nrc.gov.

* * * * *

The NRC Commission Meeting Schedule can be found on the Internet at: <http://www.nrc.gov/public-involve/public-meetings/schedule.html>.

* * * * *

The NRC provides reasonable accommodation to individuals with disabilities where appropriate. If you need a reasonable accommodation to participate in these public meetings, or need this meeting notice or the transcript or other information from the public meetings in another format (*e.g.*, braille, large print), please notify Kimberly Meyer, NRC Disability Program Manager, at 301–287–0739, by videophone at 240–428–3217, or by email at Kimberly.Meyer-Chambers@nrc.gov. Determinations on requests for

reasonable accommodation will be made on a case-by-case basis.

* * * * *

Members of the public may request to receive this information electronically. If you would like to be added to the distribution, please contact the Nuclear Regulatory Commission, Office of the Secretary, Washington, DC 20555 (301-415-1969), or email Brenda.Akstulewicz@nrc.gov or Patricia.Jimenez@nrc.gov.

Dated: March 28, 2017.

Denise L. McGovern,
Policy Coordinator, Office of the Secretary.
[FR Doc. 2017-06374 Filed 3-28-17; 4:15 pm]
BILLING CODE 7590-01-P

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-311 NRC-2017-0082]

PSEG Nuclear LLC; Salem Nuclear Generating Station, Unit No. 2

AGENCY: Nuclear Regulatory Commission.

ACTION: License amendment application; opportunity to comment, request a hearing, and petition for leave to intervene.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is considering issuance of an amendment to Facility Operating License No. DPR-75, issued to PSEG Nuclear LLC (PSEG or the licensee) for operation of the Salem Nuclear Generating Station (Salem), Unit No. 2. The amendment would extend the Salem, Unit No. 2, implementation period for Amendment No. 294 from the spring 2017 refueling outage to prior to restart from the fall 2018 refueling outage. Amendment No. 294, which was issued by the NRC staff on April 28, 2016, revised the Salem, Unit No. 2, Technical Specifications in support of replacement of the source range and intermediate range neutron monitoring systems.

DATES: Submit comments by May 1, 2017. Requests for a hearing or petition for leave to intervene must be filed by May 30, 2017.

ADDRESSES: You may submit comment by any of the following methods (unless this document describes a different method for submitting comments on a specific subject):

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2017-0082. Address questions about NRC dockets to Carol Gallagher; telephone: 301-415-3463; email: Carol.Gallagher@nrc.gov. For technical questions, contact the

individual listed in the **FOR FURTHER INFORMATION CONTACT** section of this document.

- *Mail comments to:* Cindy Bladey, Office of Administration, Mail Stop: OWFN-12-H08, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001.

For additional direction on accessing information and submitting comments, see "Obtaining Information and Submitting Comments" in the **SUPPLEMENTARY INFORMATION** section of this document.

FOR FURTHER INFORMATION CONTACT: Carleen J. Parker, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington DC 20555-0001; telephone: 301-415-1603, email: Carleen.Parker@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Obtaining Information and Submitting Comments

A. Obtaining Information

Please refer to Docket ID NRC-2017-0082 when contacting the NRC about the availability of information for this action. You may obtain publicly-available information related to this action by any of the following methods:

- *Federal Rulemaking Web site:* Go to <http://www.regulations.gov> and search for Docket ID NRC-2017-0082.

- *NRC's Agencywide Documents Access and Management System (ADAMS):* You may obtain publicly-available documents online in the ADAMS Public Documents collection at <http://www.nrc.gov/reading-rm/adams.html>. To begin the search, select "ADAMS Public Documents" and then select "Begin Web-based ADAMS Search." For problems with ADAMS, please contact the NRC's Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by email to pdr.resource@nrc.gov. The license amendment request dated March 13, 2017, is available in ADAMS under Accession No. ML17072A443.

- *NRC's PDR:* You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

B. Submitting Comments

Please include Docket ID NRC-2017-0082 in the subject line of your comment submission, in order to ensure that the NRC is able to make your comment submission available to the public in this docket.

The NRC cautions you not to include identifying or contact information that you do not want to be publicly disclosed in your comment submission.

The NRC posts all comment submissions at <http://www.regulations.gov> as well as entering the comment submissions into ADAMS. The NRC does not routinely edit comment submissions to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the NRC, then you should inform those persons not to include identifying or contact information that they do not want to be publicly disclosed in their comment submission. Your request should state that the NRC does not routinely edit comment submissions to remove such information before making the comment submissions available to the public or entering the comment submissions into ADAMS.

II. Introduction

The NRC is considering issuance of an amendment to Facility Operating License No. DPR-75, issued to PSEG for operation of Salem, Unit No. 2, located in Salem County, New Jersey.

The proposed amendment would extend the Salem, Unit No. 2, implementation period for Amendment No. 294 from the spring 2017 refueling outage to prior to restart from the fall 2018 refueling outage. Amendment No. 294, which was issued by the NRC staff on April 28, 2016 (ADAMS Accession No. ML16096A419), revised the Salem, Unit No. 2, Technical Specifications in support of replacement of the source range and intermediate range neutron monitoring systems.

Before any issuance of the proposed license amendment, the NRC will need to make the findings required by the Atomic Energy Act of 1954, as amended (the Act), and NRC's regulations.

The NRC has made a proposed determination that the license amendment request involves no significant hazards consideration. Under the NRC's regulations in § 50.92 of title 10 of the *Code of Federal Regulations* (10 CFR), this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Do the proposed changes involve a significant increase in the probability or